

VENTILATION AUDIT REPORT

SCHOOL:	Athelstane Public School (3453)
AMU REGION:	Sydney
STATE ELECTORATE:	Rockdale
LOCAL GOVERNMENT AREA:	Bayside

3453 - Athelstane Public School
Site Plan (10194)




























1:732

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Communal Space - (164.23 SQM)	● Student Space (76)	
B001 - R0005 - Movement - (27.84 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Canteen - (28.61 SQM)	Not Applicable	Circulation or storage space.
B001 - R0011 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Raised Platform - (34.86 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Duplicating Workroom - (12.89 SQM)	● Office (3)	
B002 - R0002 - Clerical Office - (12.89 SQM)	● Office (3)	
B002 - R0003 - Entry Vestibule - (8.1 SQM)	Not Applicable	Circulation or storage space.
B002 - R0004 - Principal - (21.77 SQM)	● Office (5)	
B002 - R0005 - Staff Room Annexe - (13.82 SQM)	● Office (3)	
B002 - R0006 - Staff Room Annexe - (13.78 SQM)	● Office (3)	
B002 - R0007 - Staff Room Annexe - (14.11 SQM)	● Office (3)	
B002 - R0010 - Interview - (16.08 SQM)	● Office (4)	
B002 - R0015 - Clerical Office - (10.76 SQM)	● Office (2)	
B002 - R0017 - Movement - (36.8 SQM)	Not Applicable	Circulation or storage space.
B002 - R0019 - Staff Room - (51.33 SQM)	● Office (12)	
B002 - R0020 - Staff Kitchen - (10.1 SQM)	● Office (2)	
B002 - R1005 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B002 - R1011 - Reading Area - (173.32 SQM)	● Student Space (80)	
B002 - R1012 - Seminar/Study - (25.79 SQM)	● Office (6)	
B002 - R1015 - Movement - (56.91 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Practical Activities - 1hb - (13.92 SQM)	● Student Space (6)	
B003 - R0002 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0006 - Movement - (51.64 SQM)	Not Applicable	Circulation or storage space.
B003 - R0009 - Practical Activities - 1hb - (13.92 SQM)	● Student Space (6)	
B003 - R0010 - Home Base - (55.68 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0011 - Home Base - (55.68 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0012 - Practical Activities - 1hb - (13.92 SQM)	● Student Space (6)	
B003 - R1001 - Practical Activities - 1hb - (10.73 SQM)	● Student Space (4)	
B003 - R1002 - Home Base - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R1003 - Home Base - (55.71 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R1004 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B003 - R1005 - Movement - (35.74 SQM)	Not Applicable	Circulation or storage space.
B003 - R1007 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B003 - R1008 - Home Base - (55.71 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R1009 - Home Base - (55.7 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R1010 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B004 - R0001 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B004 - R0002 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R0005 - Withdrawal Space - 1hb - (13.65 SQM)	● Student Space (6)	
B004 - R0009 - Movement - (50.68 SQM)	Not Applicable	Circulation or storage space.
B004 - R0014 - Practical Activities - 1hb - (13.92 SQM)	● Student Space (6)	
B004 - R0015 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R1001 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B004 - R1002 - Home Base - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R1006 - Practical Activities - 1hb - (10.73 SQM)	● Student Space (4)	
B004 - R1007 - Home Base - (51.73 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R1008 - Home Base - (55.7 SQM) - Teaching Space: 1	 Student Space (25)	
B004 - R1009 - Practical Activities - 1hb - (13.92 SQM)	 Student Space (6)	
B004 - R1010 - Movement - (35.46 SQM)	Not Applicable	Circulation or storage space.
B004 - R1012 - Practical Activities - 1hb - (13.93 SQM)	 Student Space (6)	
B004 - R1013 - Home Base - (55.69 SQM) - Teaching Space: 1	 Student Space (25)	
B005 - R0002 - Home Base - (91.16 SQM) - Teaching Space: 1	 Student Space (42)	
B005 - R0003 - Practical Activities - 1hb - (11.38 SQM)	 Student Space (5)	
B005 - R0005 - Home Base - (91.59 SQM) - Teaching Space: 1	 Student Space (42)	
B005 - R0006 - Practical Activities - 1hb - (11.41 SQM)	 Student Space (5)	
B005 - R1001 - Practical Activities - 1hb - (15.3 SQM)	 Student Space (7)	
B005 - R1002 - Home Base - (56.67 SQM) - Teaching Space: 1	 Student Space (26)	
B005 - R1003 - Home Base - (56.64 SQM) - Teaching Space: 1	 Student Space (26)	
B005 - R1004 - Practical Activities - 1hb - (15.31 SQM)	 Student Space (7)	
B005 - R1006 - Staff Room Annexe - (9.98 SQM)	 Office (2)	
B005 - R1008 - Movement - (12.25 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - Home Base - M - (49.47 SQM) - Teaching Space: 1	 Student Space (22)	
B006 - R0004 - Home Base - (51.35 SQM) - Teaching Space: 1	 Student Space (23)	
B006 - R0007 - Staff Room Annexe - (21.33 SQM)	 Office (5)	
B006 - R0008 - Home Base - (52.94 SQM) - Teaching Space: 1	 Student Space (24)	
B007 - R0002 - Home Base - (44.35 SQM) - Teaching Space: 1	 Student Space (20)	
B007 - R0003 - Home Base - (44.6 SQM) - Teaching Space: 1	 Student Space (20)	
B008 - R0001 - Home Base - (60.5 SQM) - Teaching Space: 1	 Student Space (28)	
B008 - R0002 - Home Base - (60.75 SQM) - Teaching Space: 1	 Student Space (28)	
B008 - R0003 - Special Programs Room - (30.29 SQM)	 Student Space (14)	
B008 - R0004 - Practical Activities - 1hb - (19 SQM)	 Student Space (8)	
B008 - R0005 - Practical Activities - 1hb - (19.07 SQM)	 Student Space (8)	
B008 - R0006 - Withdrawal Space - 2hb - (13.2 SQM)	 Student Space (6)	
B008 - R0011 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.