


VENTILATION AUDIT REPORT

SCHOOL:	Auburn Girls High School (8253)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Auburn
LOCAL GOVERNMENT AREA:	Cumberland

8253 - Auburn Girls High School
Site Plan (12293)



1:1,047
















Printed: 19-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0002 - Movement - (13.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Multi-Purpose Space - (223.68 SQM)	● Student Space (103)	
B00A - R0010 - Stage - (79.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - General Assistants - (13.21 SQM)	● Office (3)	
B00B - R0B01 - Administration - Clerical - (18.24 SQM)	● Office (4)	
B00B - R0B02 - Commonroom - (70.95 SQM)	● Office (17)	
B00B - R0B03 - Staff Kitchen - (14.04 SQM)	● Office (3)	
B00B - R0B06 - Deputy Principal Office - (16.92 SQM)	● Office (4)	
B00B - R0B12 - Principal Office - (16.85 SQM)	● Office (4)	
B00B - R0B13 - Administration - Clerical - (14.71 SQM)	● Office (3)	
B00B - R0B15 - Pupil Entry - (25.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0B19 - Administration - Clerical - (19.44 SQM)	● Office (4)	
B00B - R0B22 - Clinic - Girls - (8.56 SQM)	● Office (2)	
B00B - R0B25 - Deputy Principal Office - (15.72 SQM)	● Office (3)	
B00B - R0B28 - Movement - (91.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C01 - Staff Study - (12.42 SQM)	● Office (3)	
B00B - R0C03 - Staff Kitchen - (11.33 SQM)	● Office (2)	
B00B - R0C05 - Staff Study - (20.32 SQM)	● Office (5)	
B00B - R0C06 - Tea Room - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C10 - General Learning Space - (43.68 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0C11 - General Learning Space - (53.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0C12 - Preparation - Materials - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C14 - Food Technology L.S. - (66.6 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0C17 - Computer Learning Space - (66.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0C20 - Laboratory L.S. - (89 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0C21 - Preparation - Science - (26.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C24 - Public Entry - (71.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C28 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0C29 - General Learning Space - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0C30 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0C32 - Movement - (217.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C35 - Movement - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0C36 - Staff Study - (23.49 SQM)	● Office (5)	
B00B - R0D01 - Food Technology L.S. - (66.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0D03 - Preparation - Materials - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0D04 - Music Learning Space - (66.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0D06 - Music Learning Space - (79.89 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0D08 - Movement - (18.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0D10 - Movement - (47.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0E01 - Laboratory L.S. - (105.71 SQM) - Teaching Space: 1	● Student Space (49)	
B00B - R0E04 - General Learning Space - (51.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0E05 - Movement - (38.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0E08 - Staff Study - (39.1 SQM)	● Office (9)	
B00B - R1B02 - General Learning Space - (55.87 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1B03 - General Learning Space - (55.94 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1B04 - General Learning Space - (55.86 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1B05 - Computer Learning Space - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1B06 - Computer Learning Space - (70.67 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1B10 - Movement - (65.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R1B12 - Tea Room - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1B13 - Staff Study - (22.49 SQM)	● Office (5)	
B00B - R1C01 - Performance Workshop - (68.79 SQM)	● Student Space (31)	
B00B - R1C04 - Staff Study - (24.83 SQM)	● Office (6)	
B00B - R1C05 - Materials Technology L.S. - (73.05 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1C09 - Materials Technology L.S. - (66.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1C10 - Staff Study - (21 SQM)	● Office (5)	
B00B - R1C11 - Computer Learning Space - (65.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1C12 - General Learning Space - (66.35 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1C13 - General Learning Space - (66.42 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1C14 - General Learning Space - (71.92 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1C15 - Staff Study - (26.58 SQM)	● Office (6)	
B00B - R1C18 - Interview/Office - Type 1 - (13.56 SQM)	● Office (3)	
B00B - R1C19 - Staff Study - (26.98 SQM)	● Office (6)	
B00B - R1C20 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1C21 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1C22 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1C24 - Interview/Office - Type 1 - (12.62 SQM)	● Office (3)	
B00B - R1C25 - Staff Study - (11.27 SQM)	● Office (2)	
B00B - R1C26 - Movement - (262.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R1D01 - General Learning Space - (66.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1D04 - General Learning Space - (66.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1D07 - General Learning Space - (79.75 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1D09 - Movement - (48.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R1D11 - Movement - (18.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R1E01 - Art Learning Space - (70.45 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1E02 - Art Learning Space - (100.7 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1E05 - Art Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1E07 - Movement - (23.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Laboratory L.S. - (85.3 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0002 - Preparation - Science - (47.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Laboratory L.S. - (84.73 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0005 - Administration - Clerical - (10.29 SQM)	● Office (2)	
B00F - R0007 - Movement - (42.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Main Area - (408.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Tea Room - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Audio Visual Workroom - (15.14 SQM)	● Student Space (7)	
B00F - R1001 - Laboratory L.S. - (85.06 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R1005 - Laboratory L.S. - (84.45 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R1010 - General Learning Space - (35.48 SQM) - Teaching Space: 1	● Student Space (16)	
B00F - R1018 - Staff Study - (43.8 SQM)	● Office (10)	
B00F - R1020 - Staff Study - (29.09 SQM)	● Office (7)	
B00F - R1022 - Staff Study - (91.67 SQM)	● Office (22)	
B00F - R1025 - Preparation - Science - (17.04 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1026 - Movement - (41.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R1029 - Dark Room - (24.54 SQM)	 Office (6)	
B00G - R0003 - Gymnasium - (297.07 SQM)	 Student Space (137)	
B00G - R0005 - Movement - (8.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Student Canteen - (36.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Movement - (114.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Food Technology L.S. - (108.74 SQM) - Teaching Space: 1	 Student Space (50)	
B00G - R0032 - Seminar/Technology Space - (24.69 SQM)	 Office (6)	
B00G - R0036 - Gymnasium - (80.65 SQM)	 Student Space (37)	
B00H - R0001 - Staff Kitchen - (16.08 SQM)	 Office (4)	
B00H - R0008 - Child Care Centre - (11.83 SQM)	 Student Space (5)	
B00H - R0009 - Seminar - (17.21 SQM)	 Office (4)	
B00H - R0011 - Child Care Centre - (13.58 SQM)	 Student Space (6)	
B00H - R0012 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Study Space - (49.56 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0002 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
BOB2 - R0001 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
NS 280 14592 - NS 280 14592 - Wood Metal Technics/Heat Area/Storage - (114 SQM)	Not Applicable	Circulation or storage space.
OS 600 10845 - OS 600 10845 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11175 - OS 601 11175 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11295 - OS 601 11295 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12326 - OS 601 12326 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 19428 - OS 601 19428 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 751 14591 - OS 751 14591 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	