

VENTILATION AUDIT REPORT

SCHOOL:	Auburn North Public School (1073)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Auburn
LOCAL GOVERNMENT AREA:	Cumberland

1073 - Auburn North Public School
Site Plan (12294)



1:1,225

Printed: 23-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0009 - Interview - (11.78 SQM)	Office (2)	
B00A - R0010 - Interview - (12.39 SQM)	Office (3)	
B00A - R0011 - Principal - (25.17 SQM)	Office (6)	
B00A - R0020 - Movement - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (23.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Entry Vestibule - (18.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview - (13.73 SQM)	Office (3)	
B00A - R0026 - Clerical Office - (62.13 SQM)	Office (15)	
B00A - R0027 - Sick Bay - (6.93 SQM)	Student Space (3)	
B00A - R0029 - Movement - (77.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Clerical Office - (12.61 SQM)	Office (3)	
B00A - R0031 - Deputy Principal - (12.19 SQM)	Office (3)	
B00A - R0032 - Deputy Principal - (14.71 SQM)	Office (3)	
B00A - R0033 - Study Annexe - (27.22 SQM)	Office (6)	
B00A - R0034 - Staff Kitchen - (12.72 SQM)	Office (3)	
B00A - R0035 - Staff Room - (71.45 SQM)	Office (17)	
B00A - R1001 - Seminar/Study - (14.82 SQM)	Office (3)	
B00A - R1002 - Seminar/Study - (14.44 SQM)	Office (3)	
B00A - R1003 - Reading Area - (253.08 SQM)	Student Space (117)	
B00A - R1007 - Movement - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (258.44 SQM)	Student Space (119)	
B00B - R0004 - Raised Platform - (78.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Canteen - (30.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (12.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (24.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (37.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (75.33 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0004 - Practical Activities - 1hb - (13.74 SQM)	Student Space (6)	
B00C - R0006 - Home Base - (75.27 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0007 - Practical Activities - 1hb - (13.88 SQM)	Student Space (6)	
B00D - R0003 - Movement - (32.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (26.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (21.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (46.75 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0004 - Home Base - (46.26 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0005 - Home Base - (45.61 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0006 - Home Base - (46.7 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0007 - Home Base - (46.26 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0008 - Interview - (16.26 SQM)	Office (4)	
B00F - R0010 - Movement - (19.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Raised Platform - (23.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Practical Activities - 1hb - (104.82 SQM)	Student Space (48)	
B00F - R0021 - Movement - (63.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Movement - (92.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Home Base - (48.39 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1004 - Home Base - (48.58 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1005 - Home Base - (48.57 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1006 - Home Base - (48.5 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1007 - Home Base - (48.59 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1008 - Withdrawal Space - 1hb - (25.24 SQM)	Student Space (11)	
B00F - R1010 - Interview - (17.56 SQM)	Office (4)	
B00F - R1011 - Practical Activities - 1hb - (86.31 SQM)	Student Space (40)	
B00F - R1013 - Staff Room Annexe - (12.34 SQM)	Office (3)	
B00G - R0002 - Withdrawal Space - 2hb - (37.69 SQM)	Student Space (17)	
B00G - R0003 - Home Base - (48.93 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0005 - Home Base - (48.83 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0006 - Home Base - (45.4 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0008 - Movement - (46.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Movement - (30.39 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (11.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (38.81 SQM) - Teaching Space: 1	Student Space (18)	
B00H - R0004 - Withdrawal Space - 1hb - (24.19 SQM)	Student Space (11)	
B00H - R0005 - Withdrawal Space - 1hb - (24.15 SQM)	Student Space (11)	
B00H - R0006 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Staff Room Annexe - (20.35 SQM)	Office (5)	
B00I - R0002 - Home Base - (47.25 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0003 - Home Base - (46.85 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0004 - Home Base - (47.45 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R0005 - Home Base - (47.33 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0010 - Movement - (82.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Practical Activities - 1hb - (96.77 SQM)	Student Space (44)	
B00I - R0015 - Movement - (24.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Home Base - (49.57 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R1002 - Special Programs Room - (48.68 SQM)	Student Space (22)	
B00I - R1003 - Special Programs Room - (49.15 SQM)	Student Space (22)	
B00I - R1004 - Home Base - (49.22 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R1005 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00I - R1007 - Movement - (74.18 SQM)	Not Applicable	Circulation or storage space.
B00I - R1008 - Practical Activities - 1hb - (113.27 SQM)	Student Space (52)	
B00I - R1010 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities/Movement - 1hb - (18.35 SQM)	Student Space (8)	
B00K - R0004 - Home Base - (60.07 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.82 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (60.03 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0008 - Practical Activities/Movement - 1hb - (19.33 SQM)	Student Space (8)	
B00K - R1002 - Practical Activities/Movement - 1hb - (19.09 SQM)	Student Space (8)	
B00K - R1004 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R1005 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00K - R1006 - Home Base - (61.25 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R1008 - Practical Activities/Movement - 1hb - (19.05 SQM)	Student Space (8)	
B00L - R0002 - Practical Activities/Movement - 1hb - (19.16 SQM)	Student Space (8)	
B00L - R0004 - Home Base - (61.38 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00L - R0006 - Home Base - (61.3 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0008 - Practical Activities/Movement - 1hb - (18.69 SQM)	● Student Space (8)	
B00N - R0001 - Practical Activities - 2hb - (38.35 SQM)	● Student Space (17)	
B00N - R0002 - Home Base - (58.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0003 - Withdrawal Space - 2hb - (11.63 SQM)	● Student Space (5)	
B00N - R0004 - Home Base - (63.42 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R0011 - Practical Activities - 3hb - (41.69 SQM)	● Student Space (19)	
B00N - R0013 - Home Base - (58.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00N - R0014 - Home Base - (63.21 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R0016 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00N - R0017 - Home Base - (63.51 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R0018 - Withdrawal Space - 1hb - (7.5 SQM)	● Student Space (3)	
B00N - R0022 - Movement - (18.35 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - Practical Activities - 2hb - (38.35 SQM)	● Student Space (17)	
B00N - R1002 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R1003 - Withdrawal Space - 2hb - (11.63 SQM)	● Student Space (5)	
B00N - R1004 - Home Base - (63.42 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R1011 - Practical Activities - 3hb - (41.69 SQM)	● Student Space (19)	
B00N - R1013 - Home Base - (58.73 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R1014 - Home Base - (63.21 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R1015 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00N - R1016 - Movement - (18.35 SQM)	Not Applicable	Circulation or storage space.
B00N - R1017 - Home Base - (63.97 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R1018 - Withdrawal Space - 1hb - (7.96 SQM)	● Student Space (3)	
OS 534 11471 - OS 534 11471 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	