

VENTILATION AUDIT REPORT

SCHOOL:	Auburn Public School (7403)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Auburn
LOCAL GOVERNMENT AREA:	Cumberland

7403 - Auburn Public School
Site Plan (10258)



1:668

Printed: 08-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (17.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - (47.53 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0006 - Home Base - (47 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0007 - Home Base - (47.13 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0008 - Home Base - (47.21 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0012 - Movement - (124.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Sick Bay - (12.44 SQM)	● Student Space (5)	
B00A - R0017 - Entry Vestibule - (22.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clerical Office/Workroom - (21.93 SQM)	● Office (5)	
B00A - R0019 - Deputy Principal - (19.29 SQM)	● Office (4)	
B00A - R0024 - Staff Room - (36.1 SQM)	● Office (9)	
B00A - R0025 - Staff Kitchen - (11.12 SQM)	● Office (2)	
B00A - R1001 - Movement - (42.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (48.92 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1003 - Home Base - (48.86 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1004 - Home Base - (48.99 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1005 - Special Programs Room - (101.96 SQM)	● Student Space (47)	
B00A - R1006 - Home Base - (49.12 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - Movement - (39.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Communal Space - (127.9 SQM)	● Student Space (59)	
B00A - R1011 - Raised Platform - (25.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (47.8 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0002 - Home Base - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Practical Activities - 1hb - (36.97 SQM)	● Student Space (17)	
B00B - R0005 - Interview - (10.15 SQM)	● Office (2)	
B00B - R0007 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Communal Space - (118.73 SQM)	● Student Space (55)	
B00B - R0011 - Home Base - (86.02 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0012 - Practical Activities - 1hb - (6.74 SQM)	● Student Space (3)	
B00B - R0014 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Practical Activities - 1hb - (11.8 SQM)	● Student Space (5)	
B00B - R0017 - Home Base - (81.5 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0018 - Movement - (26.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Home Base - (49.6 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1004 - Home Base - (54.12 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1005 - Practical Activities - 1hb - (35.71 SQM)	● Student Space (16)	
B00C - R0002 - Canteen - (34.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (8.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Special Programs Room - (35.68 SQM)	● Student Space (16)	
B00C - R0007 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (29.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (38.94 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (61.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Canteen - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00I - R0006 - Home Base - (60.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0007 - Withdrawal Space - 2hb - (11.57 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0008 - Practical Activities - 1hb - (19.16 SQM)	● Student Space (8)	
B00I - R0010 - Home Base - (60.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0001 - Entry Vestibule - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Deputy Principal - (21.06 SQM)	● Office (5)	
B00J - R0005 - Principal - (25.5 SQM)	● Office (6)	
B00J - R0007 - Deputy Principal - (17.68 SQM)	● Office (4)	
B00J - R0008 - Clerical Office - (19.79 SQM)	● Office (4)	
B00J - R0009 - Clerical Office/Workroom - (34.06 SQM)	● Office (8)	
B00J - R0012 - Sick Bay - (14.71 SQM)	● Student Space (6)	
B00J - R0014 - Staff Room Annexe - (25.24 SQM)	● Office (6)	
B00J - R0016 - Movement - (84.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Movement - (11.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0025 - Interview - (13.03 SQM)	● Office (3)	
B00J - R0027 - Movement - (11.37 SQM)	Not Applicable	Circulation or storage space.
B00J - R0032 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00J - R0033 - Staff Room - (40.27 SQM)	● Office (10)	
B00J - R0034 - Staff Kitchen - (8.26 SQM)	● Office (2)	
B00J - R0035 - Movement - (62.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Movement - (17.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Home Base - (48.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R1003 - Movement - (73.68 SQM)	Not Applicable	Circulation or storage space.
B00J - R1004 - Home Base - (48.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R1005 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R1007 - Practical Activities - 1hb - (49.29 SQM)	● Student Space (22)	
B00J - R1008 - Withdrawal Space - 1hb - (22.35 SQM)	● Student Space (10)	
B00J - R1009 - Home Base - (49.74 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R1010 - Home Base - (48.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R1012 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (89.06 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (28.96 SQM)	● Student Space (13)	
B00L - R0003 - Home Base - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0005 - Withdrawal Space - 1hb - (6.79 SQM)	● Student Space (3)	
B00L - R0006 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Practical Activities - 1hb - (28.49 SQM)	● Student Space (13)	
B00L - R0008 - Home Base - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0010 - Withdrawal Space - 1hb - (6.91 SQM)	● Student Space (3)	
B00L - R0011 - Movement - (11.2 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Practical Activities - 1hb - (28 SQM)	● Student Space (12)	
B00L - R0014 - Home Base - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0016 - Withdrawal Space - 1hb - (6.89 SQM)	● Student Space (3)	
B00L - R0017 - Practical Activities - 1hb - (28.22 SQM)	● Student Space (13)	
B00L - R0018 - Home Base - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0020 - Withdrawal Space - 1hb - (6.86 SQM)	● Student Space (3)	
B00L - R0021 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00L - R0024 - Movement - (47.44 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Movement - (80.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Practical Activities - 1hb - (27.91 SQM)	● Student Space (12)	
B00L - R1004 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00L - R1005 - Withdrawal Space - 1hb - (10.63 SQM)	● Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1006 - Home Base - (55.39 SQM) - Teaching Space: 1	● Student Space (25)	
B00L - R1008 - Practical Activities - 1hb - (24.06 SQM)	● Student Space (11)	
B00L - R1010 - Practical Activities - 1hb - (24.04 SQM)	● Student Space (11)	
B00L - R1012 - Home Base - (55.52 SQM) - Teaching Space: 1	● Student Space (25)	
B00L - R1013 - Withdrawal Space - 1hb - (10.63 SQM)	● Student Space (4)	
B00L - R1014 - Home Base - (55.37 SQM) - Teaching Space: 1	● Student Space (25)	
B00L - R1016 - Practical Activities - 1hb - (27.86 SQM)	● Student Space (12)	
B00M - R0001 - Special Programs Room - (42.71 SQM)	● Student Space (19)	
B00M - R0002 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Reading Area - (221.45 SQM)	● Student Space (102)	
B00P - R0001 - Canteen - (42.22 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Interview - (13.39 SQM)	● Office (3)	
B00P - R0010 - Communal Space - (202.67 SQM)	● Student Space (94)	
B00P - R0018 - Raised Platform - (48.42 SQM)	Not Applicable	Circulation or storage space.
B00P - R0020 - Movement - (12.72 SQM)	Not Applicable	Circulation or storage space.
B00P - R0021 - Movement - (12.76 SQM)	Not Applicable	Circulation or storage space.
B00P - R0023 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00Q - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00Q - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00R - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00R - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00R - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00T - R0002 - Practical Activities/Movement - 1hb - (18.9 SQM)	● Student Space (8)	
B00T - R0003 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00T - R0005 - Home Base - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0006 - Special Programs Room - (31.43 SQM)	● Student Space (14)	
OS 601 13736 - OS 601 13736 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14038 - OS 601 14038 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 750 14044 - OS 750 14044 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 751 11812 - OS 751 11812 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	