

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Avalon Public School (3792)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Pittwater</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

3792 - Avalon Public School  
Site Plan (11890)



1:1,156

Printed: 13-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (102.19 SQM)	Office (25)	
B00A - R0003 - Interview - (12.63 SQM)	Office (3)	
B00A - R0006 - Duplicating Workroom - (12.38 SQM)	Office (3)	
B00A - R0008 - Clerical Office - (12.82 SQM)	Office (3)	
B00A - R0009 - Clerical Office - (12.82 SQM)	Office (3)	
B00A - R0010 - Principal - (20.74 SQM)	Office (5)	
B00A - R0011 - Sick Bay - (10.98 SQM)	Student Space (5)	
B00A - R0012 - Deputy Principal - (14.73 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (12.74 SQM)	Office (3)	
B00A - R0018 - Movement - (61.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Reading Area - (255.2 SQM)	Student Space (118)	
B00A - R1010 - Movement - (10.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Movement - (16.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Special Programs Room - (13.26 SQM)	Student Space (6)	
B00B - R0001 - Home Base - (73.76 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0002 - Withdrawal Space - 1hb - (9.18 SQM)	Student Space (4)	
B00B - R0008 - Special Programs Room - (66.67 SQM)	Student Space (30)	
B00B - R0011 - Movement - (40.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Special Programs Room - (40.59 SQM)	Student Space (18)	
B00B - R0013 - Special Programs Room - (39.97 SQM)	Student Space (18)	
B00C - R0002 - Home Base - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - Home Base - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Movement - (22.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (53.47 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Home Base - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0004 - Movement - (23.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0002 - Home Base - (53.03 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0004 - Movement - (22.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0007 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0003 - Home Base - (58.06 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0004 - Home Base - (86.54 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R0008 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (106.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - (67.62 SQM) - Teaching Space: 1	Student Space (31)	
B00J - R0004 - Home Base - (57.28 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0010 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0011 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0017 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0019 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Interview - (20.74 SQM)	Office (5)	
B00K - R0006 - Duplicating Workroom - (21.38 SQM)	Office (5)	
B00K - R0008 - Staff Room Annexe - (24.45 SQM)	Office (6)	
B00K - R0010 - Movement - (37.64 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Canteen - (39.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Raised Platform - (115.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Communal Space - (257.69 SQM)	Student Space (119)	
B00L - R0018 - Movement - (24.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0021 - Movement - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0022 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0023 - Movement - (26.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Deputy Principal - (20 SQM)	Office (5)	
B00M - R0003 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0015 - Home Base - (57.48 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0016 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0019 - Movement - (43.1 SQM)	Not Applicable	Circulation or storage space.
B00M - R0020 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00M - R0021 - Movement - (36.78 SQM)	Not Applicable	Circulation or storage space.
B00M - R1004 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00M - R1007 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R1012 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R1013 - Home Base - (57.88 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R1016 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00M - R1017 - Movement - (46.97 SQM)	Not Applicable	Circulation or storage space.
B00M - R1018 - Movement - (36.78 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Withdrawal Space - 1hb - (14.1 SQM)	Student Space (6)	
B00N - R0005 - Movement - (11.1 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00N - R0010 - Home Base - (57.65 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R0013 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R0017 - Home Base - (57.66 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R0018 - Home Base - (57.65 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R0021 - Movement - (72.98 SQM)	Not Applicable	Circulation or storage space.
B00N - R0022 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00N - R0023 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - Staff Room - (23.78 SQM)	Office (5)	
B00N - R1005 - Sick Bay - (6.7 SQM)	Student Space (3)	
B00N - R1007 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R1010 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R1013 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R1016 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R1019 - Movement - (6.96 SQM)	Not Applicable	Circulation or storage space.
B00N - R1020 - Movement - (81.29 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Practical Activities - 1hb - (47.16 SQM)	Student Space (21)	
B00O - R0002 - Movement - (14.84 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Movement - (14.83 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Movement - (32.14 SQM)	Not Applicable	Circulation or storage space.
B00R - R0005 - Home Base - (57.57 SQM) - Teaching Space: 1	Student Space (26)	
B00R - R0006 - Home Base - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00R - R0007 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00R - R0008 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00R - R0012 - Home Base - (57.01 SQM) - Teaching Space: 1	Student Space (26)	
B00S - R0002 - Communal Space - (293.22 SQM)	Student Space (136)	
OS 602 13016 - OS 602 13016 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13551 - OS 602 13551 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15987 - OS 602 15987 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	