

VENTILATION AUDIT REPORT

SCHOOL:	Balgowlah North Public School (3984)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Manly
LOCAL GOVERNMENT AREA:	Northern Beaches

3984 - Balgowlah North Public School
Site Plan (12298)







1:1,013

Printed: 24-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0019 - Special Programs Room - (43.18 SQM)	Student Space (20)	
B00A - R0022 - Home Base - (62.24 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0025 - Special Programs Room - (48.77 SQM)	Student Space (22)	
B00A - R0026 - Home Base - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0010 - Staff Room - (73.67 SQM)	Office (18)	
B00B - R0011 - Interview - (13.67 SQM)	Office (3)	
B00B - R0012 - Principal - (21.94 SQM)	Office (5)	
B00B - R0013 - Deputy Principal - (20.6 SQM)	Office (5)	
B00B - R0015 - Duplicating Workroom - (18.01 SQM)	Office (4)	
B00B - R0016 - Sick Bay - (8.84 SQM)	Student Space (4)	
B00B - R0017 - Clerical Office - (31.68 SQM)	Office (7)	
B00B - R0019 - Movement - (26.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (32.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Withdrawal Space - 1hb - (21.61 SQM)	Student Space (10)	
B00C - R0006 - Staff Room Annexe - (20.47 SQM)	Office (5)	
B00C - R0008 - Home Base - (56.37 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (78.33 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0002 - Canteen - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (51 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0006 - Home Base - (51.2 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00G - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0003 - Staff Kitchen - (8.5 SQM)	Office (2)	
B00I - R0006 - Interview - (17.06 SQM)	Office (4)	
B00I - R0007 - Clerical Office - (8.36 SQM)	Office (2)	
B00I - R0008 - Home Base - (61.71 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0002 - Practical Activities - 1hb - (16.92 SQM)	Student Space (7)	
B00J - R0003 - Home Base - (60.06 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0004 - Withdrawal Space - 2hb - (11.51 SQM)	Student Space (5)	
B00J - R0005 - Home Base - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0006 - Practical Activities - 1hb - (19.17 SQM)	Student Space (8)	
B00J - R0009 - Practical Activities - 1hb - (19.75 SQM)	Student Space (9)	
B00J - R0010 - Home Base - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0011 - Withdrawal Space - 2hb - (11.29 SQM)	Student Space (5)	
B00J - R0012 - Home Base - (60.09 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0013 - Practical Activities - (19.82 SQM)	Student Space (9)	
B00L - R0001 - Communal Space - (223.07 SQM)	Student Space (103)	
B00L - R0014 - Raised Platform - (53.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Reading Area - (166.66 SQM)	Student Space (77)	
OS 602 10481 - OS 602 10481 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11310 - OS 602 11310 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12783 - OS 602 12783 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 13050 - OS 602 13050 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13726 - OS 602 13726 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13839 - OS 602 13839 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17676 - OS 602 17676 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	