

VENTILATION AUDIT REPORT

SCHOOL:	Ballina Public School (1112)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Ballina

1112 - Ballina Public School
Site Plan (13250)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (169.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (53.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0006 - Practical Activities - 1hb - (18.29 SQM)	● Student Space (8)	
B00A - R0013 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Canteen - (34.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Special Programs Room - (69.8 SQM)	● Student Space (32)	
B00A - R0023 - Home Base - (64.04 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0024 - Withdrawal Space - 1hb - (8.93 SQM)	● Student Space (4)	
B00A - R0025 - Practical Activities - 1hb - (21.02 SQM)	● Student Space (9)	
B00A - R1001 - Movement - (80.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Practical Activities - 1hb - (18.34 SQM)	● Student Space (8)	
B00A - R1003 - Home Base - (53.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1004 - Home Base - (53.92 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1005 - Practical Activities - 1hb - (18.34 SQM)	● Student Space (8)	
B00A - R1006 - Practical Activities - 1hb - (18.04 SQM)	● Student Space (8)	
B00A - R1007 - Home Base - (54.53 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1008 - Home Base - (54.06 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1009 - Practical Activities - 1hb - (18.12 SQM)	● Student Space (8)	
B00B - R0002 - Principal - (19.97 SQM)	● Office (4)	
B00B - R0003 - Deputy Principal - (13.41 SQM)	● Office (3)	
B00B - R0004 - Entry Vestibule - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (23.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Sick Bay - (9.48 SQM)	● Student Space (4)	
B00B - R0010 - Clerical Office - (26.69 SQM)	● Office (6)	
B00B - R0012 - Duplicating Workroom - (7.97 SQM)	● Office (1)	
B00B - R0015 - Movement - (40.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Staff Kitchen - (11.22 SQM)	● Office (2)	
B00B - R0023 - Staff Room - (44.36 SQM)	● Office (11)	
B00C - R0009 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Reading Area - (113.31 SQM)	● Student Space (52)	
B00D - R0001 - Home Base - (46.58 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0002 - Home Base - (51.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0003 - Movement - (68.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (28.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Withdrawal Space - 1hb - (11.26 SQM)	● Student Space (5)	
B00D - R0007 - Interview - (10.07 SQM)	● Office (2)	
B00D - R0008 - Practical Activities - 1hb - (36.05 SQM)	● Student Space (16)	
B00D - R0009 - Home Base - (47.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0010 - Home Base - (47.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1001 - Home Base - (48.39 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1002 - Home Base - (53.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1004 - Movement - (27.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Practical Activities - 1hb - (36.92 SQM)	● Student Space (17)	
B00D - R1006 - Home Base - (49.38 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1007 - Home Base - (50.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0005 - Home Base - (93.03 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0008 - Staff Room Annexe - (6.74 SQM)	● Office (1)	
B00H - R0002 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Movement - (177.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Canteen - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Movement - (66.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Special Programs Room - (44.74 SQM)	● Student Space (20)	
B00H - R1001 - Movement - (71.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Entry Vestibule - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Staff Room - (28.8 SQM)	● Office (7)	
B00H - R1005 - Movement - (15.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R1006 - Deputy Principal - (12.8 SQM)	● Office (3)	
B00H - R1007 - Clerical Office - (8.38 SQM)	● Office (2)	
B00H - R1009 - Home Base - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1012 - Practical Activities - 1hb - (8.95 SQM)	● Student Space (4)	
B00H - R1013 - Home Base - (58.45 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1014 - Home Base - (88.06 SQM) - Teaching Space: 1	● Student Space (40)	
B00H - R1015 - Practical Activities - 1hb - (12.63 SQM)	● Student Space (5)	
B00I - R0007 - Home Base - (81.8 SQM) - Teaching Space: 1	● Student Space (37)	
B00I - R0013 - Home Base - (52.35 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0016 - Movement - (26.6 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Special Programs Room - (15.97 SQM)	● Student Space (7)	
B00I - R0018 - Movement - (40.34 SQM)	Not Applicable	Circulation or storage space.
B00I - R0019 - Movement - (57.04 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Sick Bay - (21.92 SQM)	● Student Space (10)	
B00I - R1004 - Home Base - (51.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R1008 - Home Base - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R1012 - Home Base - (51.58 SQM) - Teaching Space: 1	● Student Space (23)	
B00I - R1016 - Movement - (82.99 SQM)	Not Applicable	Circulation or storage space.
B00I - R1017 - Interview - (13.42 SQM)	● Office (3)	
B00L - R0001 - Communal Space - (147.11 SQM)	● Student Space (68)	
B00L - R0002 - Raised Platform - (61.36 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (12.16 SQM)	Not Applicable	Circulation or storage space.