

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--------------------------------------|
| SCHOOL: | Bangalow Public School (1118) |
| AMU REGION: | North Coast |
| STATE ELECTORATE: | Ballina |
| LOCAL GOVERNMENT AREA: | Byron |

1118 - Bangalow Public School
Site Plan (12304)



Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R0004 - Practical Activities - 1hb - (69.85 SQM) | ● Student Space (32) | |
| B00A - R0005 - Home Base - (45.54 SQM) - Teaching Space: 1 | ● Student Space (21) | |
| B00A - R0006 - Home Base - (45.6 SQM) - Teaching Space: 1 | ● Student Space (21) | |
| B00A - R0007 - Staff Room Annexe - (11.1 SQM) | ● Office (2) | |
| B00A - R0008 - Staff Room Annexe - (11.1 SQM) | ● Office (2) | |
| B00A - R0011 - Withdrawal Space - 1hb - (20.84 SQM) | ● Student Space (9) | |
| B00A - R0013 - Home Base - (92.24 SQM) - Teaching Space: 1 | ● Student Space (42) | |
| B00B - R0002 - Home Base - (80.56 SQM) - Teaching Space: 1 | ● Student Space (37) | |
| B00B - R0006 - Canteen - (14.51 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0014 - Movement - (31.42 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Staff Room Annexe - (5.89 SQM) | ● Office (1) | |
| B00C - R0003 - Practical Activities - 1hb - (24.32 SQM) | ● Student Space (11) | |
| B00C - R0004 - Home Base - (51.46 SQM) - Teaching Space: 1 | ● Student Space (23) | |
| B00C - R0008 - Home Base - (51.54 SQM) - Teaching Space: 1 | ● Student Space (23) | |
| B00C - R0009 - Practical Activities - 1hb - (23.63 SQM) | ● Student Space (10) | |
| B00C - R0010 - Withdrawal Space - 1hb - (5.93 SQM) | ● Student Space (2) | |
| B00E - R0004 - Special Programs Room - (38.76 SQM) | ● Student Space (17) | |
| B00F - R0002 - Practical Activities - 1hb - (19.4 SQM) | ● Student Space (9) | |
| B00F - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0005 - Withdrawal Space - 2hb - (11.36 SQM) | ● Student Space (5) | |
| B00F - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0008 - Practical Activities - 1hb - (19.4 SQM) | ● Student Space (9) | |
| B00G - R0001 - Communal Space - (145.29 SQM) | ● Student Space (67) | |
| B00G - R0002 - Raised Platform - (62.55 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0016 - Movement - (5.46 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0018 - Movement - (11.57 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0002 - Reading Area - (92.72 SQM) | ● Student Space (43) | |
| OS 501 15575 - OS 501 15575 - Admin Staff/Principal/Deputy/Dup/Clinic - (209 SQM) | ● Office (52) | |
| OS 602 10880 - OS 602 10880 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 602 14288 - OS 602 14288 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 602 14828 - OS 602 14828 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 602 18059 - OS 602 18059 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |