


VENTILATION AUDIT REPORT

SCHOOL:	Banks Public School (4571)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Penrith

4571 - Banks Public School
Site Plan (10166)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (16.93 SQM)	Office (4)	
B00A - R0002 - Interview - (12.13 SQM)	Office (3)	
B00A - R0003 - Staff Room Annexe - (26.56 SQM)	Office (6)	
B00A - R0004 - Staff Room - (71.61 SQM)	Office (17)	
B00A - R0007 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Sick Bay - (8.45 SQM)	Student Space (3)	
B00A - R0011 - Entry Vestibule - (24.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (20.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Deputy Principal - (12.07 SQM)	Office (3)	
B00A - R0015 - Deputy Principal - (12.07 SQM)	Office (3)	
B00A - R0018 - Duplicating Workroom - (29.63 SQM)	Office (7)	
B00A - R0021 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Practical Activities - 1hb - (46.54 SQM)	Student Space (21)	
B00A - R0025 - Home Base - (58.7 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0026 - Movement - (18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Withdrawal Space - 1hb - (12.7 SQM)	Student Space (5)	
B00A - R0028 - Movement - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Home Base - (57.23 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0032 - Movement - (66.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Clerical Office/Workroom - (38.95 SQM)	Office (9)	
B00B - R0001 - Movement - (17.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Practical Activities - 1hb - (47.48 SQM)	Student Space (22)	
B00B - R0007 - Withdrawal Space - 1hb - (12.66 SQM)	Student Space (5)	
B00B - R0008 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0010 - Movement - (36.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (58.68 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0015 - Movement - (9.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Practical Activities - 1hb - (47.75 SQM)	Student Space (22)	
B00B - R0018 - Movement - (17.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Withdrawal Space - 1hb - (12.73 SQM)	Student Space (5)	
B00B - R0022 - Home Base - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Movement - (51.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Practical Activities - 1hb - (47.41 SQM)	Student Space (21)	
B00C - R0011 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0012 - Movement - (17.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Withdrawal Space - 1hb - (12.73 SQM)	Student Space (5)	
B00C - R0014 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0016 - Movement - (17.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (17.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Home Base - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0022 - Practical Activities - 1hb - (47.31 SQM)	Student Space (21)	
B00C - R0024 - Movement - (51.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Withdrawal Space - 1hb - (12.74 SQM)	Student Space (5)	
B00C - R0026 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0028 - Movement - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Reading Area - (262.3 SQM)	Student Space (121)	
B00C - R0035 - Special Programs Room - (44.27 SQM)	Student Space (20)	
B00C - R0041 - Movement - (111.41 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Practical Activities - 1hb - (47.37 SQM)	● Student Space (21)	
B00D - R0005 - Home Base - (57.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Movement - (17.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Withdrawal Space - 1hb - (12.63 SQM)	● Student Space (5)	
B00D - R0011 - Home Base - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0012 - Movement - (36.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0015 - Withdrawal Space - 1hb - (12.66 SQM)	● Student Space (5)	
B00D - R0017 - Practical Activities - 1hb - (47.33 SQM)	● Student Space (21)	
B00D - R0022 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0023 - Movement - (17.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (9.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (102.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Communal Space - (230.14 SQM)	● Student Space (106)	
B00E - R0005 - Raised Platform - (32.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Canteen - (40.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (18.39 SQM)	● Student Space (8)	
B00G - R0003 - Withdrawal Space - 1hb - (8.67 SQM)	● Student Space (4)	
B00G - R0005 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0006 - Practical Activities - 1hb - (18.42 SQM)	● Student Space (8)	
B00G - R0008 - Home Base - (59.57 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0009 - Withdrawal Space - 2hb - (11.16 SQM)	● Student Space (5)	
B00G - R0010 - Practical Activities - 1hb - (18.51 SQM)	● Student Space (8)	
B00G - R0012 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0013 - Special Programs Room - (33.14 SQM)	● Student Space (15)	