


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Banksia Road Public School (4217)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Lakemba</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

4217 - Banksia Road Public School  
Site Plan (10864)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Deputy Principal - (10.95 SQM)	Office (2)	
B001 - R0003 - Deputy Principal - (15.04 SQM)	Office (3)	
B001 - R0005 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B001 - R0006 - Staff Room Annexe - (7.97 SQM)	Office (1)	
B001 - R0008 - Principal - (17.38 SQM)	Office (4)	
B001 - R0013 - Sick Bay - (6.31 SQM)	Student Space (2)	
B001 - R0014 - Clerical Office - (17.63 SQM)	Office (4)	
B001 - R0016 - Entry Vestibule - (30.46 SQM)	Not Applicable	Circulation or storage space.
B001 - R0017 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Duplicating Workroom - (18.64 SQM)	Office (4)	
B001 - R0030 - Movement - (7.92 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Home Base - (67.86 SQM) - Teaching Space: 1	Student Space (31)	
B001 - R0036 - Collaboration Space - (27.65 SQM)	Student Space (12)	
B001 - R0039 - Home Base X2 - (132.37 SQM) - Teaching Space: 2	Student Space (61)	
B001 - R0040 - Practical Activities - (8.56 SQM)	Student Space (3)	
B001 - R0041 - Practical Activities - (8.93 SQM)	Student Space (4)	
B001 - R0043 - Movement - (16.31 SQM)	Not Applicable	Circulation or storage space.
B001 - R0044 - Home Base - (27.4 SQM) - Teaching Space: 1	Student Space (12)	
B002 - R0005 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0006 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0009 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B002 - R0013 - Home Base - (58.64 SQM) - Teaching Space: 1	Student Space (27)	
B003 - R0004 - Canteen - (18.12 SQM)	Not Applicable	Circulation or storage space.
B003 - R0005 - Movement - (24.2 SQM)	Not Applicable	Circulation or storage space.
B003 - R0011 - Reading Area - (145.8 SQM)	Student Space (67)	
B003 - R0012 - Reading Area - (13.9 SQM)	Student Space (6)	
B003 - R0014 - Home Base - (57.53 SQM) - Teaching Space: 1	Student Space (26)	
B003 - R0019 - Movement - (75.68 SQM)	Not Applicable	Circulation or storage space.
B004 - R0005 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B004 - R0007 - Movement - (82.36 SQM)	Not Applicable	Circulation or storage space.
B004 - R0008 - Home Base - (92.65 SQM) - Teaching Space: 1	Student Space (42)	
B004 - R0009 - Home Base - (66.06 SQM) - Teaching Space: 1	Student Space (30)	
B004 - R0011 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B004 - R0014 - Home Base - (66.23 SQM) - Teaching Space: 1	Student Space (30)	
B004 - R0018 - Movement - (15.92 SQM)	Not Applicable	Circulation or storage space.
B004 - R0021 - Seminar/Study - (20.47 SQM)	Office (5)	
B004 - R0022 - Special Programs Room - (32.66 SQM)	Student Space (15)	
B004 - R0023 - Home Base - (66.24 SQM) - Teaching Space: 1	Student Space (30)	
B004 - R0025 - Movement - (5.34 SQM)	Not Applicable	Circulation or storage space.
B004 - R0027 - Home Base - (68.25 SQM) - Teaching Space: 1	Student Space (31)	
B009 - R0001 - Movement - (23.03 SQM)	Not Applicable	Circulation or storage space.
B010 - R0004 - Movement - (18.15 SQM)	Not Applicable	Circulation or storage space.
B011 - R0001 - Communal Space - (144.89 SQM)	Student Space (67)	
B011 - R0002 - Raised Platform - (59.77 SQM)	Not Applicable	Circulation or storage space.
B011 - R0016 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B011 - R0017 - Movement - (12.08 SQM)	Not Applicable	Circulation or storage space.
B011 - R0018 - Canteen - (26.54 SQM)	Not Applicable	Circulation or storage space.
B012 - R0001 - Special Programs Room - (34.56 SQM)	Student Space (16)	
B012 - R0002 - Staff Kitchen - (9 SQM)	Office (2)	
B013 - R0001 - Entry Vestibule - (26.49 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B013 - R0002 - Clerical Office - (42.28 SQM)	Office (10)	
B013 - R0005 - Clerical/Printing - (24.3 SQM)	Not Applicable	Circulation or storage space.
B013 - R0006 - Sick Bay - (10.88 SQM)	Student Space (5)	
B013 - R0008 - Interview - (12.79 SQM)	Office (3)	
B013 - R0009 - Deputy Principal - Type 1 - (13.13 SQM)	Office (3)	
B013 - R0010 - Deputy Principal - Type 1 - (13.13 SQM)	Office (3)	
B013 - R0011 - Principal - (17.68 SQM)	Office (4)	
B013 - R0012 - Deputy Principal - Type 1 - (13.51 SQM)	Office (3)	
B013 - R0015 - Interview/Office - Type 3 - (17.38 SQM)	Office (4)	
B013 - R0016 - Staff Room Annexe - (79.27 SQM)	Office (19)	
B013 - R0022 - Interview - (13.86 SQM)	Office (3)	
B013 - R0026 - Breakout Area - (20 SQM)	Not Applicable	Circulation or storage space.
B013 - R0027 - Movement - (65.95 SQM)	Not Applicable	Circulation or storage space.
B013 - R0030 - Staff Kitchen - (22.03 SQM)	Office (5)	
B013 - R1005 - Collaboration Space - (171.62 SQM)	Student Space (79)	
B013 - R1006 - Home Base X3 - (153.35 SQM) - Teaching Space: 3	Student Space (71)	
B013 - R1007 - Special Programs Room - Type 1 - (29.8 SQM)	Student Space (13)	
B013 - R1008 - Practical Activities - 4hb - (45.98 SQM)	Student Space (21)	
B013 - R1009 - Home Base X3 - (155.4 SQM) - Teaching Space: 3	Student Space (72)	
OS 602 11464 - OS 602 11464 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11637 - OS 602 11637 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11679 - OS 602 11679 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12546 - OS 602 12546 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12813 - OS 602 12813 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15984 - OS 602 15984 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 15834 - OS 603 15834 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 19017 - OS 606 19017 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19021 - OS 606 19021 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19022 - OS 606 19022 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19074 - OS 606 19074 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19093 - OS 606 19093 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19193 - OS 606 19193 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 750 17819 - OS 750 17819 - Learning Unit - ESL - (38 SQM)	Student Space (17)	
OS 750 18308 - OS 750 18308 - Learning Unit - ESL - (38 SQM)	Student Space (17)	