


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Banksmeadow Public School (1121)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Maroubra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bayside</b>

1121 - Banksmeadow Public School  
Site Plan (12305)



1:1,082

Printed: 29-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (43.09 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0003 - Home Base - (48.07 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0004 - Home Base - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0005 - Special Programs Room - (32.44 SQM)	Student Space (15)	
B00A - R0006 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Practical Activities - 1hb - (7.63 SQM)	Student Space (3)	
B00A - R0008 - Home Base - (43.89 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0009 - Home Base - (81.5 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0010 - Deputy Principal - (8.99 SQM)	Office (2)	
B00A - R0011 - Movement - (64.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Duplicating Workroom - (15.72 SQM)	Office (3)	
B00B - R0003 - Clerical Office - (32.27 SQM)	Office (8)	
B00B - R0004 - Staff Room - (32.95 SQM)	Office (8)	
B00B - R0005 - Withdrawal Space - 1hb - (15 SQM)	Student Space (6)	
B00B - R0006 - Home Base - (47.41 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0014 - Principal - (22.31 SQM)	Office (5)	
B00B - R0016 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (78.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Withdrawal - M - (49.75 SQM)	Student Space (23)	
B00B - R1002 - Home Base - (49.34 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1004 - Movement - (104.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Home Base - (49.74 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1012 - Home Base - (51.76 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R9007 - Movement - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - Pre - (35.7 SQM)	Student Space (16)	
B00D - R0003 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - Pre - (38.86 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R0005 - Withdrawal - Pre - (10.46 SQM)	Student Space (4)	
B00D - R0016 - Withdrawal - Pre - (10.46 SQM)	Student Space (4)	
B00D - R0017 - Home Base - Pre - (38.48 SQM) - Teaching Space: 1	Student Space (17)	
B00D - R0018 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Practical Activities - 1hb - (35.48 SQM)	Student Space (16)	
B00X - R0001 - Reading Area - (90.56 SQM)	Student Space (42)	
B00Y - R0001 - Communal Space - (113.93 SQM)	Student Space (52)	
B00Z - R0002 - Practical Activities - (20.29 SQM)	Student Space (9)	
B00Z - R0004 - Home Base - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00Z - R0005 - Withdrawal Space - 2hb - (11.11 SQM)	Student Space (5)	
B00Z - R0006 - Home Base - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00Z - R0008 - Practical Activities - (20.29 SQM)	Student Space (9)	
OS 602 11422 - OS 602 11422 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14525 - OS 602 14525 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16281 - OS 602 16281 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19702 - OS 602 19702 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	