

VENTILATION AUDIT REPORT

SCHOOL:	Bankstown North Public School (1124)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

1124 - Bankstown North Public School
Site Plan (11916)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (36.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Special Programs Room - (47.55 SQM)	● Student Space (22)	
B00A - R0011 - Movement - (15.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Kitchen - (7.07 SQM)	● Office (1)	
B00A - R0023 - Reading Area - (152 SQM)	● Student Space (70)	
B00A - R1022 - Clerical Office - (99.75 SQM)	● Office (24)	
B00A - R1023 - Entry Vestibule - (14.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (65.06 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0008 - Home Base - (65.06 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0013 - Staff Room - (15.71 SQM)	● Office (3)	
B00B - R0016 - Staff Room Annexe - (8.09 SQM)	● Office (2)	
B00B - R0017 - Staff Kitchen - (8.56 SQM)	● Office (2)	
B00D - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00D - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00D - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00I - R0004 - Home Base - (64.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00I - R0006 - Home Base - (51.3 SQM) - Teaching Space: 1	● Student Space (23)	
B00I - R0007 - Home Base - (51.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00I - R0008 - Home Base - (51.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00I - R0009 - Withdrawal Space - 1hb - (10.6 SQM)	● Student Space (4)	
B00I - R0016 - Movement - (95.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Raised Platform - (33.74 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Communal Space - (146.07 SQM)	● Student Space (67)	
B00N - R0002 - Raised Platform - (61.1 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00N - R0018 - Canteen - (26.41 SQM)	Not Applicable	Circulation or storage space.
B00N - R0020 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
NS 002 15886 - NS 002 15886 - Admin 14 Principal/Deputy/Dup/Work - (152 SQM)	● Office (38)	
NS 100 11377 - NS 100 11377 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 101 11072 - NS 101 11072 - Learning Unit - Double Primary/PAA - (133 SQM)	● Student Space (61)	
NS 110 15243 - NS 110 15243 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 250 15125 - NS 250 15125 - Learning Unit - Single E.S.L./Store - (38 SQM)	● Student Space (17)	
OS 601 11532 - OS 601 11532 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13994 - OS 601 13994 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 14500 - OS 602 14500 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15583 - OS 602 15583 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18361 - OS 602 18361 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19252 - OS 606 19252 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19255 - OS 606 19255 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19267 - OS 606 19267 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19576 - OS 606 19576 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19593 - OS 606 19593 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	