


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bankstown Senior College (8381)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Bankstown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

8381 - Bankstown Senior College  
Site Plan (10167)



1:2,295

Printed: 30-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0006 - Principal Office - (22.74 SQM)	Office (5)	
B00A - R0021 - General Learning Space - (54.19 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0022 - Computer Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0028 - Deputy Principal Office - (19.71 SQM)	Office (4)	
B00A - R0032 - Public Reception - (57.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Interview/Meeting - (8.23 SQM)	Office (2)	
B00A - R0036 - Interview/Meeting - (8.3 SQM)	Office (2)	
B00A - R0039 - Interview/Office - Type 1 - (16.67 SQM)	Office (4)	
B00A - R0046 - Administration - Clerical - (48.23 SQM)	Office (12)	
B00A - R0047 - Seminar - Type 2 - (24.22 SQM)	Office (6)	
B00A - R0048 - Tea Room - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Pupil Entry - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (16.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (53.97 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1007 - General Learning Space - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1013 - General Learning Space - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1020 - General Learning Space - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1022 - Staff Study - (80.36 SQM)	Office (20)	
B00A - R1023 - Staff Study - (98.63 SQM)	Office (24)	
B00A - R1024 - Staff Study - (12.75 SQM)	Office (3)	
B00A - R1026 - Computer Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1030 - Commonroom - (75.75 SQM)	Office (18)	
B00A - R1031 - Tea Room - (10.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Wood Technology L.S. - (97.5 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R0022 - Laboratory L.S. - (100.22 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R0023 - Laboratory L.S. - (86.66 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0025 - Preparation - Science - (28.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Workshop Area - (124.85 SQM)	Student Space (57)	
B00B - R0037 - Outdoor Learning Area - (68.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Computer Learning Space - (93.14 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R1012 - Music Learning Space - (86.73 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1019 - Art Learning Space - (28.73 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R1020 - Computer Learning Space - (26.17 SQM) - Teaching Space: 1	Student Space (12)	
B00B - R1021 - Music Learning Space - (26.14 SQM) - Teaching Space: 1	Student Space (12)	
B00B - R1023 - Music Learning Space - (27.17 SQM) - Teaching Space: 1	Student Space (12)	
B00B - R1024 - Staff Study - (67.36 SQM)	Office (16)	
B00B - R1025 - Metal Technology L.S. - (66.56 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1028 - Dark Room - (25.13 SQM)	Office (6)	
B00C - R0001 - Movement - (20.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (20.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Student Canteen - (46.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Food/Research Space - (30.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Food Technology L.S. - (106.89 SQM) - Teaching Space: 1	Student Space (49)	
B00C - R0029 - Movement - (32.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Student Canteen - (159.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - General Assistants - (17.05 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1008 - Seminar/Study - (62.5 SQM)	Office (15)	
B00C - R1012 - Tiered Learning Area - (63.29 SQM)	Student Space (29)	
B00C - R1020 - Movement - (86.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Interview/Office - Type 1 - (21.03 SQM)	Office (5)	
B00C - R1024 - Staff Study - (13.44 SQM)	Office (3)	
B00C - R1025 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R1026 - Movement - (8.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Computer Learning Space - (51.99 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0018 - Art Learning Space - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0020 - Art Learning Space - (53.08 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0033 - Laboratory L.S. - (100.43 SQM) - Teaching Space: 1	Student Space (46)	
B00D - R0034 - Preparation - Science - (29.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Laboratory L.S. - (85.66 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R1001 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1006 - General Learning Space - (54.12 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1008 - General Learning Space - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1009 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1010 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1011 - General Learning Space - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1014 - General Learning Space - (54.12 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1018 - General Learning Space - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1020 - Art Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Study Space - (14.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Study Space - (14.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Study Space - (14.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Seminar - (29.84 SQM)	Office (7)	
B00E - R0007 - Study Space - (14.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Entry - (19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Audio Visual Workroom - (26.71 SQM)	Student Space (12)	
B00E - R0016 - Study Space - (18.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Main Area - (290 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Computer Learning Space - (44.81 SQM) - Teaching Space: 1	Student Space (20)	
B00F - R0003 - Stage - (85.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Kitchen - (11.48 SQM)	Office (2)	
B00F - R0010 - Multi-Purpose Space - (439.7 SQM)	Student Space (204)	
B00F - R0025 - Movement - (17.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Main Area - (91.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Interview/Office - Type 1 - (20.53 SQM)	Office (5)	
NS 111 15278 - NS 111 15278 - Learning Unit - Double Secondary/Secure - (114 SQM)	Student Space (52)	
OS 520 11524 - OS 520 11524 - Staff Study - (57 SQM)	Office (14)	
OS 600 11689 - OS 600 11689 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 14740 - OS 600 14740 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11527 - OS 601 11527 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11548 - OS 601 11548 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11549 - OS 601 11549 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11685 - OS 601 11685 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11782 - OS 601 11782 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 751 15888 - OS 751 15888 - Learning Unit - ESL - (76 SQM)	Student Space (35)	