


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bankstown South Infants School (5246)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Bankstown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

5246 - Bankstown South Infants School  
Site Plan (10168)



1:815

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room - (52.59 SQM)	Office (13)	
B00A - R0003 - Clerical Office - (25.93 SQM)	Office (6)	
B00A - R0004 - Duplicating Workroom - (11.32 SQM)	Office (2)	
B00A - R0005 - Principal - (14.61 SQM)	Office (3)	
B00A - R0009 - Clerical Office/Workroom - (16.85 SQM)	Office (4)	
B00A - R0012 - Staff Room Annexe - (10.31 SQM)	Office (2)	
B00C - R0001 - Reading Area - (47.1 SQM)	Student Space (21)	
B00C - R0002 - Home Base - (47.1 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0005 - Movement - (15.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (12.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - Pre - (69.44 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0005 - Withdrawal - Pre - (13.24 SQM)	Student Space (6)	
B00D - R0012 - Movement - (22.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Practical Activities - Pre - (10.62 SQM)	Student Space (4)	
B00H - R0001 - Special Programs Room - (55.15 SQM)	Student Space (25)	
B00J - R0002 - Reading Area - (91.53 SQM)	Student Space (42)	
OS 601 15981 - OS 601 15981 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15983 - OS 601 15983 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 12380 - OS 602 12380 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14120 - OS 602 14120 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14218 - OS 602 14218 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 18170 - OS 603 18170 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 11193 - OS 606 11193 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 811 12047 - OS 811 12047 - FSU/Shelter/Stores - (209 SQM)	Not Applicable	Circulation or storage space.