

VENTILATION AUDIT REPORT

SCHOOL:	Bankstown West Public School (4142)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

4142 - Bankstown West Public School
Site Plan (11825)



1:798

Printed: 13-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (18.98 SQM)	● Student Space (8)	
B00A - R0002 - Interview - (8.94 SQM)	● Office (2)	
B00A - R0005 - Withdrawal Space - 1hb - (13.36 SQM)	● Student Space (6)	
B00A - R0008 - Home Base - (53.89 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0009 - Home Base - (62.46 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0011 - Home Base - (67.34 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0012 - Movement - (22.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Kitchen - (13.18 SQM)	● Office (3)	
B00A - R0015 - Staff Room - (108.17 SQM)	● Office (27)	
B00A - R0016 - Movement - (46.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Deputy Principal - (22.33 SQM)	● Office (5)	
B00B - R0001 - Home Base - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0003 - Home Base - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Movement - (25.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (54.34 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0002 - Home Base - (54.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0006 - Withdrawal Space - 1hb - (13.22 SQM)	● Student Space (6)	
B00E - R0001 - Home Base - (47.27 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0002 - Special Programs Room - (47.15 SQM)	● Student Space (21)	
B00E - R0003 - Staff Kitchen - (17.72 SQM)	● Office (4)	
B00E - R0006 - Movement - (24.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (136.29 SQM)	● Student Space (63)	
B00H - R0002 - Raised Platform - (61.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (15.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (16.4 SQM)	Not Applicable	Circulation or storage space.
NS 100 15930 - NS 100 15930 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 502 11075 - OS 502 11075 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 534 14449 - OS 534 14449 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 602 11975 - OS 602 11975 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13844 - OS 602 13844 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14530 - OS 602 14530 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14771 - OS 602 14771 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15744 - OS 602 15744 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19673 - OS 606 19673 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	