

VENTILATION AUDIT REPORT

SCHOOL:	Baradine Central School (1130)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warrumbungle

1130 - Baradine Central School
Site Plan (13241)



Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Sick Bay - (6.49 SQM)	● Student Space (3)	
B00A - R0002 - Principal - (17.76 SQM)	● Office (4)	
B00A - R0003 - Public Entry - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - General Learning Space - (56.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0011 - Movement - (81.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Interview - (9.67 SQM)	● Office (2)	
B00A - R0022 - Movement - (35.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (10.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Reading Area - (165.19 SQM)	● Student Space (76)	
B00A - R0036 - Clerical Office/Workroom - (32.37 SQM)	● Office (8)	
B00A - R0037 - Clerical Office - (5.09 SQM)	● Office (1)	
B00A - R0039 - Kitchen - Type 1 - (88.98 SQM)	● Student Space (41)	
B00A - R0042 - Preparation - Materials - (15.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Room Annexe - (24.82 SQM)	● Office (6)	
B00A - R1003 - Movement - (74.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Preparation - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Laboratory L.S. - (82 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1017 - Materials Technology L.S. - (118.58 SQM) - Teaching Space: 1	● Student Space (55)	
B00B - R0001 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (45.7 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0003 - Withdrawal Space - 1hb - (45.7 SQM)	● Student Space (21)	
B00B - R0004 - Home Base - (48.03 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0005 - General Learning Space - (48.04 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0006 - Staff Room Annexe - (13.43 SQM)	● Office (3)	
B00B - R0009 - Home Base - (58.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Home Base - (55.42 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0011 - General Learning Space - (54.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0014 - Staff Room - (47.24 SQM)	● Office (11)	
B00B - R0015 - Movement - (104.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (55.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Practical Activities - 1hb - (38.75 SQM)	● Student Space (17)	
B00B - R0021 - Principal Office - (18.99 SQM)	● Office (4)	
B00C - R0002 - Special Programs Room - (47.67 SQM)	● Student Space (22)	
B00C - R0003 - Special Programs Room - (9.98 SQM)	● Student Space (4)	
B00D - R0002 - Raised Platform - (41.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Canteen - (26.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Communal Space - (189.88 SQM)	● Student Space (88)	
B00H - R0001 - Movement - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Practical Activities - E - (10.52 SQM)	● Student Space (4)	
B00H - R0011 - Home Base - Pre - (71.45 SQM) - Teaching Space: 1	● Student Space (33)	
OS 600 18256 - OS 600 18256 - Learning Unit - Small - (57 SQM)	● Student Space (26)	