


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bargo Public School (1134)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

1134 - Bargo Public School  
Site Plan (12535)










1:1,067

Printed: 23-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Canteen - (16.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (61.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Sick Bay - (8.62 SQM)	● Student Space (3)	
B00A - R0010 - Clerical Office - (13.03 SQM)	● Office (3)	
B00A - R0014 - Entry Vestibule - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal - (17.35 SQM)	● Office (4)	
B00A - R0017 - Duplicating Workroom - (21.1 SQM)	● Office (5)	
B00A - R0018 - Staff Kitchen - (8.45 SQM)	● Office (2)	
B00A - R0021 - Staff Room - (50.71 SQM)	● Office (12)	
B00A - R0022 - Home Base - (63.43 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0003 - Home Base - (51.25 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0006 - Home Base - (50.55 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0007 - Home Base - (51.34 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0010 - Staff Room Annexe - (13.03 SQM)	● Office (3)	
B00B - R0013 - Movement - (8.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Practical Activities - 1hb - (11.55 SQM)	● Student Space (5)	
B00B - R0017 - Practical Activities - 1hb - (11.02 SQM)	● Student Space (5)	
B00B - R0020 - Practical Activities - 1hb - (11.07 SQM)	● Student Space (5)	
B00C - R0002 - Staff Room Annexe - (20.71 SQM)	● Office (5)	
B00C - R0003 - Home Base - (47.88 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0006 - Practical Activities - 1hb - (16.1 SQM)	● Student Space (7)	
B00C - R0007 - Withdrawal Space - 1hb - (27 SQM)	● Student Space (12)	
B00C - R0008 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0009 - Special Programs Room - (47.33 SQM)	● Student Space (21)	
B00C - R0010 - Movement - (48.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (23.46 SQM)	● Student Space (10)	
B00D - R0002 - Special Programs Room - (15.09 SQM)	● Student Space (7)	
B00E - R0003 - Practical Activities - 1hb - (13.07 SQM)	● Student Space (6)	
B00E - R0004 - Home Base - (58.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0006 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Withdrawal Space - 1hb - (11.89 SQM)	● Student Space (5)	
B00E - R0008 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Home Base - (58.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0011 - Practical Activities - 1hb - (13.05 SQM)	● Student Space (6)	
B00G - R0001 - Entry Vestibule - (8.39 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (58.5 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0003 - Practical Activities - 1hb - (18.16 SQM)	● Student Space (8)	
B00H - R0004 - Movement - (14.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Withdrawal Space - 1hb - (11.95 SQM)	● Student Space (5)	
B00H - R0007 - Practical Activities - 1hb - (18.18 SQM)	● Student Space (8)	
B00H - R0008 - Home Base - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0010 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (59.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00J - R0004 - Movement - (14.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Withdrawal Space - 1hb - (11.95 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0007 - Practical Activities - 1hb - (18.18 SQM)	 Student Space (8)	
B00J - R0008 - Home Base - (58.36 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0010 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Reading Area - (165.71 SQM)	 Student Space (76)	
B00L - R0001 - Communal Space - (143.08 SQM)	 Student Space (66)	
B00L - R0002 - Raised Platform - (62.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (24.8 SQM)	Not Applicable	Circulation or storage space.
OS 602 10462 - OS 602 10462 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12934 - OS 602 12934 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12990 - OS 602 12990 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	