

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Barmedman Public School (1137)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bland</b>

1137 - Barmedman Public School  
Site Plan (10684)












1:780

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (47.46 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0004 - Home Base - (47.39 SQM) - Teaching Space: 1	 Student Space (21)	
B00A - R0005 - Principal - (15.77 SQM)	 Office (3)	
B00A - R0006 - Clerical Office - (7.61 SQM)	 Office (1)	
B00A - R0007 - Movement - (44.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Staff Kitchen - (22.32 SQM)	 Office (5)	
B00A - R0009 - Movement - (36.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (73.45 SQM) - Teaching Space: 1	 Student Space (34)	
B00B - R0004 - Withdrawal Space - 1hb - (40.35 SQM)	 Student Space (18)	
B00B - R0005 - Movement - (30.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (26.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Darkroom Space - (13.74 SQM)	 Office (3)	
B00C - R0003 - Reading Area - (51.99 SQM)	 Student Space (24)	
B00D - R0001 - Movement - (19.97 SQM)	Not Applicable	Circulation or storage space.