

VENTILATION AUDIT REPORT

SCHOOL:	Barrack Heights Public School (4501)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Shellharbour
LOCAL GOVERNMENT AREA:	Shellharbour

4501 - Barrack Heights Public School
Site Plan (12999)



1:1,354











Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Canteen - (43.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (44.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (122.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (38.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (22.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Duplicating Workroom - (12.78 SQM)	Office (3)	
B00A - R0021 - Staff Room Annexe - (12.81 SQM)	Office (3)	
B00A - R0022 - Staff Room Annexe - (14.25 SQM)	Office (3)	
B00A - R0025 - Movement - (70.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Raised Platform - (42.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Communal Space - (236.58 SQM)	Student Space (109)	
B00A - R0039 - Movement - (57.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Movement - (9.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Home Base - (58.41 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0043 - Practical Activities - 1hb - (11.65 SQM)	Student Space (5)	
B00A - R0044 - Outdoor Learning Area - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Home Base - (57.6 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0046 - Practical Activities - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R0047 - Outdoor Learning Area - (12.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Home Base - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0049 - Practical Activities - 1hb - (11.65 SQM)	Student Space (5)	
B00A - R0050 - Outdoor Learning Area - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Movement - (36.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Movement - (50.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Interview - (12.71 SQM)	Office (3)	
B00A - R0058 - Movement - (26.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Movement - (19.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0074 - Principal - (22.7 SQM)	Office (5)	
B00A - R0075 - Clerical/Printing - (21.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0076 - Clerical Office - (28.05 SQM)	Office (7)	
B00A - R0077 - Staff Room - (80.18 SQM)	Office (20)	
B00A - R1003 - Home Base - (58.31 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1004 - Practical Activities - 1hb - (12.05 SQM)	Student Space (5)	
B00A - R1005 - Movement - (12.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Home Base - (57.8 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1007 - Practical Activities - 1hb - (11.7 SQM)	Student Space (5)	
B00A - R1008 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Home Base - (57.6 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1010 - Practical Activities - 1hb - (11.65 SQM)	Student Space (5)	
B00A - R1011 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (90.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Withdrawal Space - 1hb - (6.94 SQM)	Student Space (3)	
B00A - R1022 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (230.14 SQM)	Student Space (106)	
B00B - R0004 - Seminar/Study - (14.74 SQM)	Office (3)	
B00B - R0008 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (19.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (92.75 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0017 - Duplicating Workroom - (13.14 SQM)	Office (3)	
B00B - R0018 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (21.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Special Programs Room - (19.75 SQM)	Student Space (9)	
B00B - R0029 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Home Base - (58.82 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0033 - Practical Activities - 1hb - (11.6 SQM)	Student Space (5)	
B00B - R0034 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Home Base - (58.35 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0037 - Practical Activities - 1hb - (11.58 SQM)	Student Space (5)	
B00B - R0038 - Movement - (12.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Movement - (12.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0043 - Home Base - (61.01 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0044 - Practical Activities - 1hb - (11.82 SQM)	Student Space (5)	
B00B - R0045 - Movement - (13.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Home Base - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0048 - Practical Activities - 1hb - (11.7 SQM)	Student Space (5)	
B00B - R0049 - Movement - (13.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Home Base - (57.54 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0051 - Practical Activities - 1hb - (11.65 SQM)	Student Space (5)	
B00B - R0052 - Movement - (13.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0053 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0055 - Practical Activities - 1hb - (11.73 SQM)	Student Space (5)	
B00B - R0056 - Movement - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Movement - (15.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Movement - (99.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Home Base - (61.61 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1012 - Practical Activities - 1hb - (11.8 SQM)	Student Space (5)	
B00B - R1013 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Home Base - (61.65 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1015 - Practical Activities - 1hb - (11.77 SQM)	Student Space (5)	
B00B - R1016 - Movement - (13.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (41.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Special Programs Room - (13.47 SQM)	Student Space (6)	
B00C - R0005 - Movement - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (61.43 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (11.7 SQM)	Student Space (5)	
B00C - R0008 - Movement - (22.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (61.62 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0010 - Practical Activities - 1hb - (11.66 SQM)	Student Space (5)	
B00C - R0011 - Movement - (13.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (57.54 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Practical Activities - 1hb - (11.72 SQM)	Student Space (5)	
B00C - R0014 - Movement - (26.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0016 - Practical Activities - 1hb - (11.63 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0017 - Movement - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Special Programs Room - (9.4 SQM)	 Student Space (4)	
B00C - R0020 - Movement - (123.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (12.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Special Programs Room - (19.75 SQM)	 Student Space (9)	
B00C - R0034 - Home Base - (71.37 SQM) - Teaching Space: 1	 Student Space (33)	
B00C - R0037 - Practical Activities - 1hb - (11.63 SQM)	 Student Space (5)	
B00C - R0038 - Movement - (26.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Home Base - (79.6 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0040 - Practical Activities - 1hb - (11.75 SQM)	 Student Space (5)	
B00C - R0042 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0043 - Home Base - (76.55 SQM) - Teaching Space: 1	 Student Space (35)	
B00C - R0046 - Practical Activities - 1hb - (11.73 SQM)	 Student Space (5)	
B00C - R0047 - Movement - (13.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0048 - Home Base - (76.59 SQM) - Teaching Space: 1	 Student Space (35)	
B00C - R0049 - Practical Activities - 1hb - (11.75 SQM)	 Student Space (5)	
B00C - R0051 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.