

# VENTILATION AUDIT REPORT

SCHOOL:	Barramurra Public School (4671)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden

4671 - Barramurra Public School  
Site Plan (15718)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (21.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Interview - (12.72 SQM)	Office (3)	
B00A - R0003 - Interview - (12.8 SQM)	Office (3)	
B00A - R0004 - Deputy Principal - Type 2 - (25.73 SQM)	Office (6)	
B00A - R0005 - Special Programs Room - (33.93 SQM)	Student Space (15)	
B00A - R0006 - Special Programs Room - (34.03 SQM)	Student Space (15)	
B00A - R0009 - Reading Area - (88.04 SQM)	Student Space (40)	
B00A - R0010 - Sick Bay - (9.36 SQM)	Student Space (4)	
B00A - R0013 - Clerical/Printing - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (17.03 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (12.96 SQM)	Office (3)	
B00A - R0017 - Deputy Principal - (13.23 SQM)	Office (3)	
B00A - R0018 - Interview - (17.88 SQM)	Office (4)	
B00A - R0019 - Clerical Office - (88.31 SQM)	Office (22)	
B00A - R0020 - Movement - (42.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Room - (124 SQM)	Office (31)	
B00A - R1005 - Special Programs Room - (29.18 SQM)	Student Space (13)	
B00A - R1006 - Special Programs Room - (29.3 SQM)	Student Space (13)	
B00A - R1007 - Reading Area - (164.57 SQM)	Student Space (76)	
B00A - R1010 - Staff Room - (27.88 SQM)	Office (6)	
B00A - R1013 - Staff Room Annexe - (30 SQM)	Office (7)	
B00A - R1016 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Movement - (23.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Staff Kitchen - (8.49 SQM)	Office (2)	
B00A - R1030 - Tiered Learning Space - (36.63 SQM)	Student Space (16)	
B00B - R0001 - Home Base - (59.68 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0002 - Withdrawal Space - 2hb - (13.05 SQM)	Student Space (6)	
B00B - R0005 - Home Base - (60.56 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0006 - Practical Activities - 2hb - (23.94 SQM)	Student Space (11)	
B00B - R0007 - Home Base - (57.91 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0009 - Withdrawal Space - 2hb - (12.63 SQM)	Student Space (5)	
B00B - R0010 - Home Base - (59.83 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0015 - Practical Activities - 2hb - (38.85 SQM)	Student Space (18)	
B00B - R0016 - Practical Activities - 2hb - (23.65 SQM)	Student Space (10)	
B00B - R1001 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1002 - Home Base - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1003 - Home Base - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1004 - Home Base - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1005 - Collaboration Space - (84.24 SQM)	Student Space (39)	
B00B - R1006 - Withdrawal Space - 2hb - (13.62 SQM)	Student Space (6)	
B00B - R1007 - Withdrawal Space - 2hb - (13.67 SQM)	Student Space (6)	
B00B - R1008 - Home Base - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1009 - Home Base - (61.01 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1010 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1011 - Home Base - (60.97 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1012 - Collaboration Space - (84.23 SQM)	Student Space (39)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1013 - Withdrawal Space - 2hb - (13.66 SQM)	Student Space (6)	
B00B - R1014 - Withdrawal Space - 2hb - (13.64 SQM)	Student Space (6)	
B00B - R1023 - Practical Activities - 2hb - (48.08 SQM)	Student Space (22)	
B00B - R1024 - Practical Activities - 2hb - (48.06 SQM)	Student Space (22)	
B00B - R2001 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2002 - Home Base - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2003 - Home Base - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R2004 - Home Base - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2005 - Practical Activities - 2hb - (48.08 SQM)	Student Space (22)	
B00B - R2006 - Withdrawal Space - 2hb - (13.62 SQM)	Student Space (6)	
B00B - R2007 - Withdrawal Space - 2hb - (13.67 SQM)	Student Space (6)	
B00B - R2008 - Home Base - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2009 - Home Base - (61.01 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2010 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R2011 - Home Base - (60.97 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R2012 - Practical Activities - 2hb - (48.06 SQM)	Student Space (22)	
B00B - R2013 - Withdrawal Space - 2hb - (13.66 SQM)	Student Space (6)	
B00B - R2014 - Withdrawal Space - 2hb - (13.64 SQM)	Student Space (6)	
B00B - R2015 - Collaboration Space - (84.24 SQM)	Student Space (39)	
B00B - R2016 - Collaboration Space - (84.23 SQM)	Student Space (39)	
B00C - R0001 - Home Base - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0002 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0003 - Home Base - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Home Base - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0005 - Practical Activities - 2hb - (49.34 SQM)	Student Space (22)	
B00C - R0006 - Withdrawal Space - 2hb - (13.71 SQM)	Student Space (6)	
B00C - R0007 - Withdrawal Space - 2hb - (13.66 SQM)	Student Space (6)	
B00C - R0008 - Collaboration Space - (83.1 SQM)	Student Space (38)	
B00C - R1001 - Home Base - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1002 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1003 - Home Base - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - Home Base - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1005 - Collaboration Space - (83.1 SQM)	Student Space (38)	
B00C - R1006 - Withdrawal Space - 2hb - (13.71 SQM)	Student Space (6)	
B00C - R1007 - Withdrawal Space - 2hb - (13.66 SQM)	Student Space (6)	
B00C - R1014 - Practical Activities - 2hb - (49.34 SQM)	Student Space (22)	
B00C - R2001 - Home Base - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R2002 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R2003 - Home Base - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R2004 - Home Base - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R2005 - Practical Activities - 2hb - (49.34 SQM)	Student Space (22)	
B00C - R2006 - Withdrawal Space - 2hb - (13.71 SQM)	Student Space (6)	
B00C - R2007 - Withdrawal Space - 2hb - (13.66 SQM)	Student Space (6)	
B00C - R2015 - Collaboration Space - (83.1 SQM)	Student Space (38)	
B00D - R0001 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0002 - Home Base - (58.94 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0004 - Home Base - (60.44 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0005 - Practical Activities - 2hb - (48.64 SQM)	● Student Space (22)	
B00D - R0006 - Withdrawal Space - 2hb - (13.54 SQM)	● Student Space (6)	
B00D - R0007 - Withdrawal Space - 2hb - (13.64 SQM)	● Student Space (6)	
B00D - R0009 - Collaboration Space - (83.58 SQM)	● Student Space (38)	
B00D - R1001 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1002 - Home Base - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1003 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1004 - Home Base - (60.44 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1005 - Collaboration Space - (83.58 SQM)	● Student Space (38)	
B00D - R1006 - Withdrawal Space - 2hb - (13.54 SQM)	● Student Space (6)	
B00D - R1007 - Withdrawal Space - 2hb - (13.64 SQM)	● Student Space (6)	
B00D - R2001 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R2002 - Home Base - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R2003 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R2004 - Home Base - (60.44 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R2005 - Practical Activities - 2hb - (48.64 SQM)	● Student Space (22)	
B00D - R2006 - Withdrawal Space - 2hb - (13.54 SQM)	● Student Space (6)	
B00D - R2007 - Withdrawal Space - 2hb - (13.64 SQM)	● Student Space (6)	
B00D - R2008 - Collaboration Space - (83.58 SQM)	● Student Space (38)	
B00E - R0008 - Communal Space - (288.08 SQM)	● Student Space (133)	
B00E - R0009 - Canteen - (53.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (15.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Raised Platform - (62.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.