

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Barrenjoey High School (8454)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Pittwater</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8454 - Barrenjoey High School  
Site Plan (10172)



1:1,225













Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Administration - Clerical - (25.04 SQM)	Office (6)	
B00A - R0006 - Laboratory L.S. - (85.87 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0007 - Preparation - Science - (28.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Laboratory L.S. - (93.56 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R0013 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0017 - General Learning Space - (58.53 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0021 - Administration - Clerical - (24.49 SQM)	Office (6)	
B00A - R0022 - Principal Office - (19.59 SQM)	Office (4)	
B00A - R0034 - Ancillary Staff - (12.8 SQM)	Office (3)	
B00A - R0037 - Public Reception - (47.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Deputy Principal Office - (17.96 SQM)	Office (4)	
B00A - R0039 - Deputy Principal Office - (20.42 SQM)	Office (5)	
B00A - R0040 - Clinic - (6.16 SQM)	Office (1)	
B00A - R0042 - Administration - Clerical - (14.51 SQM)	Office (3)	
B00A - R0043 - Interview/Meeting - (24.28 SQM)	Office (6)	
B00A - R1001 - Leading Teacher - (12.92 SQM)	Office (3)	
B00A - R1007 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - Textiles Technology L.S. - (71.87 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1018 - Computer Learning Space - (66.24 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1020 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1022 - General Learning Space - (58.37 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1028 - Staff Study - (34.08 SQM)	Office (8)	
B00A - R1030 - Commonroom - (126.44 SQM)	Office (31)	
B00A - R1031 - Staff Kitchen - (11.35 SQM)	Office (2)	
B00B - R0001 - Music Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Computer Learning Space - (58.37 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0008 - Metal Technology L.S. - (92.94 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0011 - Wood Technology L.S. - (85.39 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0013 - Music Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0023 - Food Technology L.S. - (66.3 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0030 - Welding Area - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Wood Technology Bay - (16.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Preparation - Materials - (26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Food Technology L.S. - (66.74 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0037 - Practice/Seminar - (43.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Staff Study - (56.51 SQM)	Office (14)	
B00B - R1006 - Wood Technology L.S. - (79.46 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1008 - Wood Technology L.S. - (85.06 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R1012 - Music Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1016 - Art Learning Space - (71.72 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1027 - Wood Technology Bay - (46.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R1032 - Wood Technology L.S. - (52.1 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1033 - Staff Study - (41.09 SQM)	Office (10)	
B00B - R1036 - Visual Arts Workshop - (52.51 SQM)	Student Space (24)	
B00B - R1038 - Art Learning Space - (79.53 SQM) - Teaching Space: 1	Student Space (36)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1039 - Art Learning Space - (65.91 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0003 - Practice/Seminar - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Student Canteen - (54.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Fitness Laboratory - (21.8 SQM)	● Student Space (10)	
B00C - R0012 - Movement - (16.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Multi-Purpose Space - (314.03 SQM)	● Student Space (145)	
B00C - R0022 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0005 - Laboratory L.S. - (84.91 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0006 - Preparation - Science - (29.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (92.74 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0009 - General Learning Space - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0010 - Staff Study - (12.96 SQM)	○ Office (3)	
B00D - R0012 - Computer Learning Space - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0019 - Leading Teacher - (19.28 SQM)	○ Office (4)	
B00D - R0021 - Laboratory L.S. - (92.66 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0030 - Staff Study - (33.45 SQM)	○ Office (8)	
B00D - R1002 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - General Learning Space - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1007 - Staff Study - (25.64 SQM)	○ Office (6)	
B00D - R1009 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1010 - General Learning Space - (51.42 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1011 - General Learning Space - (57.63 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1014 - General Learning Space - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - General Learning Space - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1019 - Staff Study - (25.71 SQM)	○ Office (6)	
B00D - R1020 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1021 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1028 - Leading Teacher - (19.13 SQM)	○ Office (4)	
B00E - R0008 - Audio Visual Workroom - (24.42 SQM)	● Student Space (11)	
B00E - R0015 - General Learning Space - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0016 - General Learning Space - (57.66 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0017 - Staff Study - (25.42 SQM)	○ Office (6)	
B00E - R0018 - Staff Study - (19.68 SQM)	○ Office (4)	
B00E - R0019 - Leading Teacher - (12.67 SQM)	○ Office (3)	
B00E - R0021 - Performance Workspace - (97.72 SQM) - Teaching Space: 1	● Student Space (45)	
B00E - R0031 - Main Area - (271.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0032 - General Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0033 - Computer Learning Space - (62.02 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0034 - Senior Study - (49.65 SQM)	○ Office (12)	
B00E - R1003 - General Learning Space - (50.93 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1006 - Leading Teacher - (12.79 SQM)	○ Office (3)	
B00E - R1007 - General Learning Space - (57.58 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1008 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1009 - General Learning Space - (52.15 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1010 - Staff Study - (25.68 SQM)	 Office (6)	
B00E - R1011 - General Learning Space - (57.59 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R1015 - General Learning Space - (51.07 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R1020 - Laboratory L.S. - (91.5 SQM) - Teaching Space: 1	 Student Space (42)	
B00E - R1021 - Preparation - Science - (22.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Laboratory L.S. - (84.05 SQM) - Teaching Space: 1	 Student Space (38)	
B00F - M0001 - Tiered Learning Area - (100.22 SQM)	 Student Space (46)	
B00F - R0005 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Staff Kitchen - (14.27 SQM)	 Office (3)	
B00F - R0010 - Multi-Purpose Space - (612.53 SQM)	 Student Space (284)	
B00F - R0029 - Stage - (140.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0033 - Movement - (64.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0034 - Movement - (55.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0035 - Stage - (32.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0036 - Movement - (14.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Art Learning Space - (57.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0003 - Art Learning Space - (58.82 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0004 - General Assistants - (58.36 SQM)	 Office (14)	