

VENTILATION AUDIT REPORT

SCHOOL:	Baryulgil Public School (1146)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley

1146 - Baryulgil Public School
Site Plan (10174)














1:927

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (79.25 SQM) - Teaching Space: 1	 Student Space (36)	
B00A - R0002 - Practical Activities - 1hb - (9.86 SQM)	 Student Space (4)	
B00A - R0009 - Movement - (33.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (15.7 SQM)	 Office (3)	
B00A - R0011 - Principal - (13.35 SQM)	 Office (3)	
B00A - R0013 - Clerical Office - (7.8 SQM)	 Office (1)	
B00A - R0015 - Entry Vestibule - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (47.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Withdrawal Space - 2hb - (27.99 SQM)	 Student Space (12)	
B00A - R0019 - Practical Activities - 1hb - (21.47 SQM)	 Student Space (9)	
B00A - R0020 - Home Base - (47.54 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0021 - Duplicating Workroom - (5.76 SQM)	 Office (1)	
B00A - R0022 - Staff Kitchen - (18.5 SQM)	 Office (4)	
B00A - R0024 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (20.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (71.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (60.01 SQM)	 Student Space (27)	