

VENTILATION AUDIT REPORT

SCHOOL:	Bass High School (8223)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Staff Study - (18.59 SQM)	Office (4)	
B00A - R0006 - Special Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0007 - Special Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0008 - Special Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0009 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0011 - Deputy Principal Office - (12.57 SQM)	Office (3)	
B00A - R0014 - Staff Study - (15.87 SQM)	Office (3)	
B00A - R0016 - Principal Office - (17.62 SQM)	Office (4)	
B00A - R0028 - Deputy Principal Office - (12.61 SQM)	Office (3)	
B00A - R0033 - Public Reception - (27.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Student Waiting - (26.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Leading Teacher - (9.63 SQM)	Office (2)	
B00A - R0037 - Deputy Principal Office - (9.72 SQM)	Office (2)	
B00A - R0038 - Clinic - Boys - (8.4 SQM)	Office (2)	
B00A - R0039 - Interview/Office - Type 1 - (10.61 SQM)	Office (2)	
B00A - R0040 - Movement - (77.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Administration - Clerical - (35.18 SQM)	Office (8)	
B00A - R1003 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - Multi Media Workshop - (24.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Dark Room - (27.05 SQM)	Office (6)	
B00A - R1009 - Art Learning Space - (64.05 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1013 - Art Learning Space - (65.69 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1014 - Movement - (85.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Movement - (44.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Food Technology L.S. - (63.7 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0018 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Kitchen - (11.25 SQM)	Office (2)	
B00B - R0020 - Commonroom - (74.4 SQM)	Office (18)	
B00B - R0021 - Movement - (37.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Seminar - (25.35 SQM)	Office (6)	
B00B - R0023 - Food Technology L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0027 - Preparation - Materials - (24.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Student Reception - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (27.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - General Learning Space - (78.33 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1010 - Design/Technology L.S. - (65.08 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1013 - Movement - (75.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Staff Study - (23.75 SQM)	Office (5)	
B00B - R1017 - Staff Study - (35.54 SQM)	Office (8)	
B00B - R1019 - General Learning Space - (65.2 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0002 - Movement - (45.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Study - (24.67 SQM)	Office (6)	
B00C - R0006 - Preparation - Science - (26.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Laboratory L.S. - (87.02 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0009 - Movement - (36.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Student Canteen - (37.71 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0017 - Food Technology L.S. - (104.8 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0019 - Movement - (31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Staff Study - (21.15 SQM)	● Office (5)	
B00C - R0038 - Movement - (43.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Computer Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1004 - Art Learning Space - (78.62 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1006 - General Learning Space - (65.2 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1007 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1010 - Staff Study - (21.64 SQM)	● Office (5)	
B00C - R1011 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1012 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1013 - General Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1015 - Staff Study - (18.66 SQM)	● Office (4)	
B00C - R1022 - Movement - (161.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (51.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (91.66 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0016 - Laboratory L.S. - (93.66 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0017 - Preparation - Science - (21.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Staff Study - (24.37 SQM)	● Office (6)	
B00D - R0021 - Movement - (36.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1007 - General Learning Space - (38.79 SQM) - Teaching Space: 1	● Student Space (17)	
B00D - R1009 - Staff Study - (25.39 SQM)	● Office (6)	
B00D - R1010 - General Learning Space - (65.29 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1011 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1014 - Movement - (82.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (96.48 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R0002 - Preparation - Science - (38.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (91.51 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0004 - General Learning Space - (50.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0008 - Movement - (68.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - General Learning Space - (65.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1005 - General Learning Space - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1006 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1007 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1008 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - Movement - (71.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Music Learning Space - (78.45 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0012 - General Learning Space - (64.94 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0001 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Wood Technology L.S. - (77.85 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R0015 - Metal Technology L.S. - (72.16 SQM) - Teaching Space: 1	● Student Space (33)	
B00G - R0017 - Metal Technology Bay - (10.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Metal Technology L.S. - (71.6 SQM) - Teaching Space: 1	● Student Space (33)	
B00H - R0001 - General Assistants - (19.09 SQM)	● Office (4)	
B00I - R0001 - Multi-Purpose Space - (458.36 SQM)	● Student Space (212)	
B00I - R0002 - Stage - (96.6 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0005 - Movement - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Staff Kitchen - (15.93 SQM)	Office (3)	
B00K - R0001 - Main Entry - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (33.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Multi Media Workshop - (49.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Tiered Learning Area - (11.1 SQM)	Student Space (5)	
B00K - R0019 - Main Area - (203.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R1004 - Leading Teacher - (16.25 SQM)	Office (4)	
B00K - R1017 - Study Space - (57.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R1018 - Independent Learning Space - (74.21 SQM) - Teaching Space: 1	Student Space (34)	
B00K - R1019 - Seminar - (33.1 SQM)	Office (8)	
B00K - R1022 - Independent Learning Space - (86.99 SQM) - Teaching Space: 1	Student Space (40)	
B00K - R1023 - Movement - (14.85 SQM)	Not Applicable	Circulation or storage space.
B00K - R1026 - Ancillary Staff - (10.2 SQM)	Office (2)	
B00O - R0006 - General Learning Space - (65.26 SQM) - Teaching Space: 1	Student Space (30)	
B00O - R0007 - Fitness Laboratory - (75.74 SQM)	Student Space (35)	
B00Q - R0001 - General Learning Space - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0002 - General Learning Space - (60.91 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0003 - Movement Studio - (104.25 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Staff Study - (19.45 SQM)	Office (4)	
B00Q - R0012 - Movement Studio - (130.53 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0015 - Performance Workshop - (31.88 SQM)	Student Space (14)	
OS 601 10672 - OS 601 10672 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14104 - OS 601 14104 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	