

VENTILATION AUDIT REPORT

SCHOOL:	Bathurst South Public School (3847)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Bathurst

3847 - Bathurst South Public School
Site Plan (12312)



1:1,216

Printed: 14-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (8.49 SQM)	Office (2)	
B00A - R0006 - Clerical Office - (12.5 SQM)	Office (3)	
B00A - R0007 - Movement - (30.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (16.74 SQM)	Office (4)	
B00A - R0011 - Staff Room - (56.83 SQM)	Office (14)	
B00A - R0021 - Principal - (16.87 SQM)	Office (4)	
B00B - R0001 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0007 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Movement - (68.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (40 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Special Programs Room - (80.94 SQM)	Student Space (37)	
B00C - R0011 - Withdrawal Space - 2hb - (64.51 SQM)	Student Space (29)	
B00D - R0001 - Withdrawal Space - 1hb - (20.78 SQM)	Student Space (9)	
B00D - R0006 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0008 - Deputy Principal - (15.26 SQM)	Office (3)	
B00D - R0009 - Movement - (24.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Staff Room Annexe - (14.56 SQM)	Office (3)	
B00D - R0012 - Duplicating Workroom - (7.9 SQM)	Office (1)	
B00D - R0013 - Movement - (40.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (63.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0007 - Home Base - (85.78 SQM) - Teaching Space: 1	Student Space (39)	
B00F - R0004 - Movement - (32.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Practical Activities - 1hb - (13.29 SQM)	Student Space (6)	
B00F - R0006 - Home Base - (60.72 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0007 - Home Base - (60.38 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Practical Activities - 1hb - (13.45 SQM)	Student Space (6)	
B00H - R0002 - Movement - (42.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Reading Area - (123.07 SQM)	Student Space (57)	
B00H - R0010 - Practical Activities - (91.47 SQM)	Student Space (42)	
B00J - R0005 - Canteen - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Raised Platform - (60.02 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Communal Space - (144.96 SQM)	Student Space (67)	
B00K - R0017 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
OS 602 13967 - OS 602 13967 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	