

VENTILATION AUDIT REPORT

SCHOOL:	Bathurst West Public School (3824)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Bathurst

3824 - Bathurst West Public School
Site Plan (12316)




































1:1,131

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Staff Room Annexe - (15.62 SQM)	Office (3)	
B00A - R0010 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0011 - Withdrawal Space - 1hb - (11.99 SQM)	Student Space (5)	
B00A - R0012 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0014 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0015 - Withdrawal Space - 1hb - (12.04 SQM)	Student Space (5)	
B00A - R0016 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Practical Activities - 1hb - (125.72 SQM)	Student Space (58)	
B00A - R0028 - Movement - (46.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (12.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (12.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Staff Room Annexe - (15.6 SQM)	Office (3)	
B00B - R0010 - Home Base - (56.34 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Withdrawal Space - 1hb - (11.92 SQM)	Student Space (5)	
B00B - R0013 - Home Base - (57.75 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0015 - Withdrawal Space - 1hb - (5.89 SQM)	Student Space (2)	
B00B - R0016 - Movement - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Practical Activities - 1hb - (130.19 SQM)	Student Space (60)	
B00B - R0024 - Special Programs Room - (70.19 SQM)	Student Space (32)	
B00B - R0026 - Movement - (35.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room Annexe - (15.35 SQM)	Office (3)	
B00C - R0003 - Home Base - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0004 - Movement - (8.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Withdrawal Space - 1hb - (11.96 SQM)	Student Space (5)	
B00C - R0006 - Home Base - (57.66 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Movement - (16.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.69 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Withdrawal Space - 1hb - (5.46 SQM)	Student Space (2)	
B00C - R0018 - Practical Activities - 1hb - (75.55 SQM)	Student Space (35)	
B00D - R0001 - Reading Area - (273.68 SQM)	Student Space (126)	
B00D - R0003 - Movement - (12.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Special Programs Room - (31.09 SQM)	Student Space (14)	
B00D - R0009 - Movement - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (50.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (11.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Room Annexe - (15.66 SQM)	Office (3)	
B00E - R0009 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Home Base - (56.83 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0011 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Withdrawal Space - 1hb - (11.94 SQM)	Student Space (5)	
B00E - R0013 - Home Base - (57.88 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0014 - Movement - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0017 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0023 - Practical Activities - 1hb - (124.12 SQM)	 Student Space (57)	
B00E - R0026 - Withdrawal Space - 1hb - (11.92 SQM)	 Student Space (5)	
B00E - R0028 - Movement - (35.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Room Annexe - (15.38 SQM)	 Office (3)	
B00F - R0010 - Home Base - (56.63 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0011 - Withdrawal Space - 1hb - (11.96 SQM)	 Student Space (5)	
B00F - R0012 - Home Base - (57.58 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0014 - Home Base - (57.51 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0015 - Withdrawal Space - 1hb - (11.96 SQM)	 Student Space (5)	
B00F - R0016 - Home Base - (56.43 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0020 - Practical Activities - 1hb - (123.78 SQM)	 Student Space (57)	
B00F - R0027 - Movement - (50.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Room - (69.78 SQM)	 Office (17)	
B00G - R0004 - Movement - (24.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Staff Kitchen - (9.4 SQM)	 Office (2)	
B00G - R0011 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Communal Space - (234.78 SQM)	 Student Space (108)	
B00G - R0014 - Raised Platform - (42.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Movement - (34.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Room Annexe - (15.46 SQM)	 Office (3)	
B00H - R0004 - Home Base - (56.83 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0005 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Withdrawal Space - 1hb - (12.01 SQM)	 Student Space (5)	
B00H - R0007 - Home Base - (57.64 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0009 - Home Base - (56.6 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0010 - Withdrawal Space - 1hb - (5.69 SQM)	 Student Space (2)	
B00H - R0016 - Practical Activities - 1hb - (83.23 SQM)	 Student Space (38)	
B00H - R0021 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0002 - Canteen - (30.25 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0001 - Clerical Office/Workroom - (17.73 SQM)	 Office (4)	
B00Z - R0003 - Duplicating Workroom - (8.27 SQM)	 Office (2)	
B00Z - R0004 - Deputy Principal - (15.62 SQM)	 Office (3)	
B00Z - R0005 - Clerical Office/Workroom - (20.63 SQM)	 Office (5)	
B00Z - R0006 - Interview - (15.05 SQM)	 Office (3)	
B00Z - R0007 - Principal - (20.48 SQM)	 Office (5)	
B00Z - R0010 - Clerical Office - (13.93 SQM)	 Office (3)	
B00Z - R0014 - Staff Room - (17.32 SQM)	 Office (4)	
B00Z - R0020 - Movement - (13.49 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0024 - Movement - (20.14 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0028 - Entry Vestibule - (18.72 SQM)	Not Applicable	Circulation or storage space.
B00Z - R0029 - Staff Room Annexe - (15.98 SQM)	 Office (3)	
B00Z - R0031 - Sick Bay - (11.08 SQM)	 Student Space (5)	
OS 602 13422 - OS 602 13422 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 11365 - OS 606 11365 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 15657 - OS 606 15657 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	