

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Batlow Technology School (1152)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wagga Wagga</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Snowy Valleys</b>

1152 - Batlow Technology School  
Site Plan (12317)



1:1,072

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (134.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Computer Learning Space - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0003 - Staff Room Annexe - (43.58 SQM)	○ Office (10)	
B00A - R0004 - Staff Room Annexe - (7.28 SQM)	○ Office (1)	
B00A - R0009 - Laboratory L.S. - (91.22 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0010 - Laboratory L.S. - (91.52 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1001 - Movement - (51.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Computer Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1004 - Reading Area - (186.46 SQM)	● Student Space (86)	
B00A - R1011 - Duplicating Workroom - (12.28 SQM)	○ Office (3)	
B00A - R1013 - Seminar/Study - (12.96 SQM)	○ Office (3)	
B00A - R1014 - Staff Room Annexe - (12.89 SQM)	○ Office (3)	
B00A - R1016 - Staff Kitchen - (8.28 SQM)	○ Office (2)	
B00B - R0002 - Interview - (12.24 SQM)	○ Office (3)	
B00B - R0003 - Principal - (14.39 SQM)	○ Office (3)	
B00B - R0004 - Sick Bay - (7.52 SQM)	● Student Space (3)	
B00B - R0005 - Clerical Office - (36.8 SQM)	○ Office (9)	
B00B - R0006 - Interview - (18.51 SQM)	○ Office (4)	
B00B - R0008 - Entry Vestibule - (8.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room - (20.3 SQM)	○ Office (5)	
B00C - R0003 - Staff Room Annexe - (13.31 SQM)	○ Office (3)	
B00C - R0004 - Movement - (78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (78.2 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0008 - Home Base - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0011 - Special Programs Room - (55.49 SQM)	● Student Space (25)	
B00C - R9007 - Art Learning Space - (70.89 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0002 - Movement - (34.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (8.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (39.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Practical Activities - 1hb - (12.45 SQM)	● Student Space (5)	
B00D - R0008 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0009 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - Practical Activities - 1hb - (13.09 SQM)	● Student Space (6)	
B00D - R0011 - Practical Activities - 1hb - (9.45 SQM)	● Student Space (4)	
B00D - R0013 - Home Base - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0014 - Home Base - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0002 - Movement - (39.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Darkroom Space - (5.78 SQM)	○ Office (1)	
B00E - R0005 - Staff Room - (68.55 SQM)	○ Office (17)	
B00E - R0006 - General Learning Space - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0007 - Staff Room Annexe - (12.73 SQM)	○ Office (3)	
B00E - R0008 - General Learning Space - (53.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0009 - Computer Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0010 - Seminar/Study - (17.53 SQM)	○ Office (4)	
B00E - R0013 - Movement - (39.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R9002 - Movement - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R9004 - Movement - (41.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R9005 - Canteen - (43.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Seminar/Study - (5.83 SQM)	Office (1)	
B00F - R0006 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Food Technology L.S. - (85.77 SQM) - Teaching Space: 1	Student Space (39)	
B00G - R0008 - Materials Technology L.S. - (103.22 SQM) - Teaching Space: 1	Student Space (47)	
B00G - R0012 - Welding Area - (8.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Seminar/Technology Space - (23.85 SQM)	Office (5)	
B00G - R0014 - Design L.S. - (49.98 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0016 - Staff Room - (26.61 SQM)	Office (6)	
B00H - R0001 - Music Learning Space - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0002 - General Learning Space - (43.9 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0003 - General Learning Space - (43.82 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0005 - Movement - (25.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00K - M0002 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (258.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Movement - (39.46 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Movement - (23.63 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Staff Kitchen - (15.18 SQM)	Office (3)	
B00K - R0016 - Staff Room Annexe - (11.58 SQM)	Office (2)	
B00K - R0018 - Communal Space - (459.82 SQM)	Student Space (213)	
B00K - R0019 - Raised Platform - (62.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (13.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Seminar/Study - (29.95 SQM)	Office (7)	