


VENTILATION AUDIT REPORT

SCHOOL:	Baulkham Hills North Public School (4377)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Baulkham Hills
LOCAL GOVERNMENT AREA:	The Hills

4377 - Baulkham Hills North Public School
Site Plan (10198)



























1:1,142

Printed: 20-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0004 - Home Base - (57.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0002 - Home Base - (69.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0003 - Home Base - (69.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0004 - Home Base - (69.48 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R0004 - Home Base - (57.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0005 - Home Base - (56.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0008 - Home Base - (57.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0003 - Principal - (23.48 SQM)	● Office (5)	
B00D - R0004 - Interview - (15.32 SQM)	● Office (3)	
B00D - R0006 - Entry Vestibule - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (37.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Deputy Principal - (14.14 SQM)	● Office (3)	
B00D - R0009 - Interview - (8.06 SQM)	● Office (2)	
B00D - R0010 - Clerical Office - (12.93 SQM)	● Office (3)	
B00D - R0018 - Sick Bay - (6.42 SQM)	● Student Space (2)	
B00D - R0020 - Duplicating Workroom - (10.87 SQM)	● Office (2)	
B00D - R0021 - Clerical Office - (16.18 SQM)	● Office (4)	
B00E - R0003 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0004 - Home Base - (57.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0007 - Home Base - (71.46 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0008 - Movement - (13.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Special Programs Room - (57.85 SQM)	● Student Space (26)	
B00F - R0006 - Staff Room - (70.47 SQM)	● Office (17)	
B00F - R0008 - Movement - (25.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Canteen - (39.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (74.65 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0006 - Practical Activities - 1hb - (9.79 SQM)	● Student Space (4)	
B00G - R0007 - Home Base - (57.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0002 - Practical Activities - 1hb - (14.96 SQM)	● Student Space (6)	
B00H - R0003 - Home Base - (75.58 SQM) - Teaching Space: 1	● Student Space (35)	
B00H - R0004 - Home Base - (54.29 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0005 - Practical Activities - 1hb - (17.79 SQM)	● Student Space (8)	
B00H - R0006 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0008 - Practical Activities - 1hb - (14.63 SQM)	● Student Space (6)	
B00H - R0010 - Home Base - (57.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0001 - Movement - (74.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - (87.93 SQM) - Teaching Space: 1	● Student Space (40)	
B00J - R0004 - Home Base - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0007 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0008 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Interview - (15.82 SQM)	● Office (3)	
B00J - R0014 - Staff Room Annexe - (31.64 SQM)	● Office (7)	
B00J - R0024 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (198.23 SQM)	● Student Space (91)	
B00K - R0002 - Movement - (16.95 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Raised Platform - (59.19 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0005 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Seminar/Study - (29.84 SQM)	 Office (7)	
B00L - R0006 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Reading Area - (166.77 SQM)	 Student Space (77)	
B00L - R9007 - Home Base - (52.49 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R9008 - Home Base - (52.5 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R9009 - Practical Activities - 1hb - (27.88 SQM)	 Student Space (12)	
B00L - R9010 - Practical Activities - 1hb - (27.88 SQM)	 Student Space (12)	
B00L - R9013 - Movement - (15.3 SQM)	Not Applicable	Circulation or storage space.
OH 060 17017 - OH 060 17017 - OSHC Hub 60 - (SQM)	 Student Space ()	
OS 601 15936 - OS 601 15936 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10291 - OS 602 10291 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12004 - OS 602 12004 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12509 - OS 602 12509 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13398 - OS 602 13398 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13545 - OS 602 13545 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14922 - OS 602 14922 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14950 - OS 602 14950 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15815 - OS 602 15815 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17129 - OS 602 17129 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19699 - OS 602 19699 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 10093 - OS 603 10093 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 11265 - OS 603 11265 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 12767 - OS 603 12767 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 13035 - OS 603 13035 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19563 - OS 606 19563 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 750 17702 - OS 750 17702 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	