

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Beacon Hill Public School (3971)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wakehurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

3971 - Beacon Hill Public School  
Site Plan (10869)



Printed: 22-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (16.02 SQM)	Office (4)	
B00A - R0011 - Duplicating Workroom - (16.77 SQM)	Office (4)	
B00A - R0013 - Movement - (20.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Interview - (17.7 SQM)	Office (4)	
B00A - R0015 - Movement - (45.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Sick Bay - (10.65 SQM)	Student Space (4)	
B00A - R0017 - Interview - (12.04 SQM)	Office (3)	
B00A - R0018 - Interview - (12.35 SQM)	Office (3)	
B00A - R0019 - Interview - (7.13 SQM)	Office (1)	
B00A - R0020 - Movement - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (42.45 SQM)	Office (10)	
B00A - R0022 - Staff Room - (61.16 SQM)	Office (15)	
B00A - R0024 - Duplicating Workroom - (24.8 SQM)	Office (6)	
B00A - R0025 - Movement - (16.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Home Base - (57.57 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Movement - (138.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Canteen - (37.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Home Base - (57.32 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1006 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1007 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1012 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1013 - Movement - (89.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (225.09 SQM)	Student Space (104)	
B00C - R0008 - Special Programs Room - (43.85 SQM)	Student Space (20)	
B00C - R0011 - Movement - (161.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (5.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (8.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (67.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base - (79.32 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R0012 - Home Base - (56.79 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Home Base - (92.31 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0003 - Movement - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Home Base - (94.85 SQM) - Teaching Space: 1	Student Space (44)	
B00F - R0016 - Home Base - (92.83 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0017 - Movement - (98.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (85.64 SQM) - Teaching Space: 1	Student Space (39)	
B00G - R0007 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0011 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Home Base - (57.35 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R9001 - Staff Room Annexe - (11.5 SQM)	Office (2)	
B00G - R9002 - Withdrawal Space - 2hb - (30.21 SQM)	Student Space (14)	
B00G - R9003 - Staff Room Annexe - (13.93 SQM)	Office (3)	
B00J - M0001 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00J - M0002 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Movement - (44.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Raised Platform - (66.22 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0008 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (16.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Staff Kitchen - (15.89 SQM)	Office (3)	
B00J - R0015 - Staff Room Annexe - (14.6 SQM)	Office (3)	
B00J - R0017 - Communal Space - (485.04 SQM)	Student Space (225)	
B00J - R0018 - Movement - (254.49 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base - (65.08 SQM) - Teaching Space: 1	Student Space (30)	
B00K - R0004 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0008 - Home Base - (64.55 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R0011 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Home Base - (64.82 SQM) - Teaching Space: 1	Student Space (30)	
B00K - R9002 - Special Programs Room - (57.54 SQM)	Student Space (26)	
B00K - R9004 - Special Programs Room - (61.6 SQM)	Student Space (28)	
B00L - R0013 - Special Programs Room - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0014 - Home Base - (56.66 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R0020 - Home Base - (57.06 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R9004 - Canteen - (19.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R9005 - Movement - (26.04 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (26)	
B00N - R0012 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00N - R0013 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00N - R0022 - Child Care Centre - (57.21 SQM)	Student Space (26)	
B00N - R0023 - Child Care Centre - (13.94 SQM)	Student Space (6)	
B00N - R0024 - Child Care Centre - (11.28 SQM)	Student Space (5)	
B00N - R0027 - Child Care Centre - (12.99 SQM)	Student Space (6)	
B00N - R0028 - Child Care Centre - (87.82 SQM)	Student Space (40)	
B00N - R0029 - Child Care Centre - (12.32 SQM)	Student Space (5)	
B00N - R0033 - Child Care Centre - (10.02 SQM)	Student Space (4)	
B00N - R0034 - Home Base - (69.59 SQM) - Teaching Space: 1	Student Space (32)	
B00N - R0035 - Movement - (8.92 SQM)	Not Applicable	Circulation or storage space.
B00O - R0003 - Canteen - (12.15 SQM)	Not Applicable	Circulation or storage space.