

VENTILATION AUDIT REPORT

SCHOOL:	Beaumont Road Public School (3956)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3956 - Beaumont Road Public School
Site Plan (10201)






1:985

Printed: 25-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (7.14 SQM)	Office (1)	
B00A - R0003 - Movement - (6.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Duplicating Workroom - (18.61 SQM)	Office (4)	
B00A - R0009 - Movement - (30.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (16.49 SQM)	Office (4)	
B00A - R0015 - Clerical Office - (17.84 SQM)	Office (4)	
B00A - R0016 - Staff Room - (67.92 SQM)	Office (16)	
B00A - R0018 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Staff Kitchen - (8.02 SQM)	Office (2)	
B00A - R0023 - Home Base - (67.93 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0009 - Reading Area - (196.93 SQM)	Student Space (91)	
B00B - R0010 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Staff Room Annexe - (10.46 SQM)	Office (2)	
B00B - R0015 - Staff Room Annexe - (10.88 SQM)	Office (2)	
B00C - R0001 - Home Base - (57.44 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0005 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (57.3 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (57.08 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0005 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Home Base - (57.08 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Home Base - (57.4 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0005 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Home Base - (57.4 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (66.46 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0008 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Home Base - (66.84 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0023 - Special Programs Room - (51.5 SQM)	Student Space (23)	
B00G - R0004 - Home Base - (53.47 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0005 - Home Base - (53.46 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0002 - Communal Space - (218.16 SQM)	Student Space (101)	
B00I - R0008 - Raised Platform - (49.23 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Movement - (20.96 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Canteen - (18.65 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - (19.25 SQM)	Student Space (8)	
B00M - R0003 - Withdrawal Space - 2hb - (11.62 SQM)	Student Space (5)	
B00M - R0005 - Home Base - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0006 - Home Base - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0008 - Practical Activities - (19.17 SQM)	Student Space (8)	
B00M - R0009 - Practical Activities - (19.09 SQM)	Student Space (8)	
B00M - R0010 - Withdrawal - M - (11.62 SQM)	Student Space (5)	
B00M - R0012 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0013 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0015 - Practical Activities - (19.17 SQM)	Student Space (8)	
B00N - R0001 - Home Base - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0002 - Practical Activities - (11.39 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0005 - Home Base - (97.13 SQM) - Teaching Space: 1	 Student Space (45)	
OS 603 10095 - OS 603 10095 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 14945 - OS 603 14945 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	