

VENTILATION AUDIT REPORT

SCHOOL:	Beechwood Public School (1165)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

1165 - Beechwood Public School
Site Plan (10202)



1:829

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0004 - Sick Bay - (5.7 SQM)	● Student Space (2)	
B00A - R0007 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0008 - Principal - (13.32 SQM)	● Office (3)	
B00A - R0009 - Clerical Office - (21.61 SQM)	● Office (5)	
B00B - R0002 - Staff Room - (54.05 SQM)	● Office (13)	
B00B - R0004 - Interview - (14.71 SQM)	● Office (3)	
B00B - R0005 - Clerical Office - (8.18 SQM)	● Office (2)	
B00C - R0002 - Home Base - (73.03 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0003 - Practical Activities - 1hb - (12.68 SQM)	● Student Space (5)	
B00C - R0006 - Movement - (5.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Withdrawal Space - 1hb - (6.61 SQM)	● Student Space (3)	
B00D - R0004 - Home Base - (63.51 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0005 - Practical Activities - 1hb - (16.51 SQM)	● Student Space (7)	
B00D - R0006 - Home Base - (63.36 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0007 - Practical Activities - 1hb - (16.51 SQM)	● Student Space (7)	
B00D - R0008 - Withdrawal Space - 1hb - (6.61 SQM)	● Student Space (3)	
B00F - R0006 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Withdrawal Space - 1hb - (31.35 SQM)	● Student Space (14)	
B00J - R0001 - Reading Area - (91.56 SQM)	● Student Space (42)	
B00J - R0002 - Special Programs Room - (20.35 SQM)	● Student Space (9)	
OS 602 18089 - OS 602 18089 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18355 - OS 602 18355 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 801 16820 - OS 801 16820 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.