

VENTILATION AUDIT REPORT

SCHOOL:	Bella Vista Public School (4663)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Baulkham Hills
LOCAL GOVERNMENT AREA:	The Hills

4663 - Bella Vista Public School
Site Plan (14727)



1:1,235

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (34.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (73.57 SQM)	Office (18)	
B00A - R0004 - Clerical Office - (14.09 SQM)	Office (3)	
B00A - R0005 - Clerical Office - (15.78 SQM)	Office (3)	
B00A - R0006 - Sick Bay - (9.61 SQM)	Student Space (4)	
B00A - R0007 - Movement - (16.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Clerical Office - (11.76 SQM)	Office (2)	
B00A - R0010 - Clerical Office - (16.76 SQM)	Office (4)	
B00A - R0011 - Clerical Office - (12.92 SQM)	Office (3)	
B00A - R0012 - Clerical Office - (21.12 SQM)	Office (5)	
B00A - R0017 - Movement - (9.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clerical Office - (12.53 SQM)	Office (3)	
B00A - R0021 - Staff Room - (123.22 SQM)	Office (30)	
B00A - R0022 - Canteen - (54.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Clerical/Printing - (23.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base X3 - (195.87 SQM) - Teaching Space: 3	Student Space (90)	
B00A - R1002 - Withdrawal Space - 2hb - (9.17 SQM)	Student Space (4)	
B00A - R1003 - Withdrawal Space - 2hb - (9.49 SQM)	Student Space (4)	
B00A - R1004 - Practical Activities - 3hb - (32.36 SQM)	Student Space (15)	
B00A - R1006 - Presentation Area - (62.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Practical Activities - 3hb - (51.39 SQM)	Student Space (23)	
B00A - R1011 - Home Base - (41.87 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1013 - Home Base - (43.95 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0012 - Home Base - (60.85 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0013 - Withdrawal Space - 2hb - (14.58 SQM)	Student Space (6)	
B00B - R0015 - Practical Activities - 2hb - (31.81 SQM)	Student Space (14)	
B00B - R0016 - Home Base - (60.88 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0018 - Withdrawal Space - 2hb - (14.13 SQM)	Student Space (6)	
B00B - R0019 - Practical Activities - 3hb - (53.55 SQM)	Student Space (24)	
B00B - R0020 - Presentation Area - (51.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base X3 - (166.9 SQM) - Teaching Space: 3	Student Space (77)	
B00B - R0023 - Withdrawal Space - 1hb - (9.52 SQM)	Student Space (4)	
B00B - R0024 - Withdrawal Space - 1hb - (9.52 SQM)	Student Space (4)	
B00B - R0025 - Home Base X3 - (160.65 SQM) - Teaching Space: 3	Student Space (74)	
B00B - R0026 - Withdrawal Space - 1hb - (9.47 SQM)	Student Space (4)	
B00B - R0027 - Withdrawal Space - 2hb - (10.14 SQM)	Student Space (4)	
B00B - R0028 - Practical Activities - 3hb - (55 SQM)	Student Space (25)	
B00B - R0029 - Presentation Area - (48.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Practical Activities - 3hb - (51.15 SQM)	Student Space (23)	
B00B - R1015 - Home Base X3 - (200.12 SQM) - Teaching Space: 3	Student Space (92)	
B00B - R1016 - Withdrawal Space - 1hb - (8.74 SQM)	Student Space (4)	
B00B - R1017 - Withdrawal Space - 1hb - (8.74 SQM)	Student Space (4)	
B00B - R1018 - Presentation Area - (53.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Practical Activities - 2hb - (32.08 SQM)	Student Space (14)	
B00B - R1022 - Home Base X3 - (202.69 SQM) - Teaching Space: 3	Student Space (94)	
B00B - R1023 - Practical Activities - 2hb - (34.7 SQM)	Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1025 - Presentation Area - (53.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Withdrawal Space - 1hb - (9.04 SQM)	● Student Space (4)	
B00B - R1027 - Withdrawal Space - 1hb - (9.04 SQM)	● Student Space (4)	
B00B - R1028 - Practical Activities - 3hb - (51.35 SQM)	● Student Space (23)	
B00C - R0001 - Home Base X2 - (125.77 SQM) - Teaching Space: 2	● Student Space (58)	
B00C - R0002 - Withdrawal Space - 2hb - (10.47 SQM)	● Student Space (4)	
B00C - R0003 - Practical Activities - 4hb - (53.99 SQM)	● Student Space (25)	
B00C - R0004 - Presentation Area - (50.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base X2 - (126.64 SQM) - Teaching Space: 2	● Student Space (58)	
B00C - R0006 - Withdrawal Space - 2hb - (9.53 SQM)	● Student Space (4)	
B00C - R1001 - Reading Area - (330.98 SQM)	● Student Space (153)	
B00D - R0013 - Home Base X2 - (131.58 SQM) - Teaching Space: 2	● Student Space (61)	
B00D - R0014 - Withdrawal Space - 2hb - (10.64 SQM)	● Student Space (4)	
B00D - R0015 - Practical Activities - 4hb - (59.16 SQM)	● Student Space (27)	
B00D - R0016 - Presentation Area - (55.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Home Base X2 - (126.08 SQM) - Teaching Space: 2	● Student Space (58)	
B00D - R0018 - Withdrawal Space - 2hb - (10.14 SQM)	● Student Space (4)	
B00D - R0026 - Home Base X2 - (125.8 SQM) - Teaching Space: 2	● Student Space (58)	
B00D - R0027 - Withdrawal Space - 2hb - (9.79 SQM)	● Student Space (4)	
B00D - R0028 - Practical Activities - 4hb - (53.73 SQM)	● Student Space (24)	
B00D - R0029 - Presentation Area - (49.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Home Base X2 - (123.68 SQM) - Teaching Space: 2	● Student Space (57)	
B00D - R0031 - Withdrawal Space - 2hb - (10.46 SQM)	● Student Space (4)	
B00D - R1001 - Special Programs Room - (37.03 SQM)	● Student Space (17)	
B00D - R1002 - Special Programs Room - (36.9 SQM)	● Student Space (17)	
B00D - R1003 - Home Base X2 - (126.12 SQM) - Teaching Space: 2	● Student Space (58)	
B00D - R1004 - Withdrawal Space - 2hb - (10.46 SQM)	● Student Space (4)	
B00D - R1005 - Practical Activities - 4hb - (54.41 SQM)	● Student Space (25)	
B00D - R1006 - Presentation Area - (51.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R1007 - Home Base X2 - (129.29 SQM) - Teaching Space: 2	● Student Space (59)	
B00D - R1008 - Withdrawal Space - 2hb - (12.2 SQM)	● Student Space (5)	
B00D - R1016 - Home Base - (68.23 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R1017 - Practical Activities - 1hb - (22.82 SQM)	● Student Space (10)	
B00D - R1018 - Withdrawal Space - 1hb - (14.77 SQM)	● Student Space (6)	
B00D - R1019 - Practical Activities - 3hb - (52.39 SQM)	● Student Space (24)	
B00D - R1020 - Presentation Area - (49.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Home Base X3 - (160.16 SQM) - Teaching Space: 3	● Student Space (74)	
B00D - R1022 - Withdrawal Space - 1hb - (9.53 SQM)	● Student Space (4)	
B00D - R1023 - Withdrawal Space - 1hb - (9.53 SQM)	● Student Space (4)	
B00E - R0001 - Communal Space - (1389.36 SQM)	● Student Space (644)	
B00E - R0004 - Clerical Office - (26.8 SQM)	● Office (6)	
B00E - R0005 - Staff Kitchen - (23.9 SQM)	● Office (5)	
B00E - R0029 - Canteen - (24.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Movement - (15.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Movement - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0042 - Movement - (28 SQM)	Not Applicable	Circulation or storage space.