

VENTILATION AUDIT REPORT

SCHOOL:	Bellambi Public School (3979)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

















3979 - Bellambi Public School
Site Plan (11134)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0001 - Reading Area - (268.44 SQM)	● Student Space (124)	
B00B - R0009 - Movement - (11.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (150.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Principal - (21.78 SQM)	● Office (5)	
B00D - R0002 - Interview - (13.04 SQM)	● Office (3)	
B00D - R0003 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Clerical Office - (13.07 SQM)	● Office (3)	
B00D - R0006 - Entry Vestibule - (22.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Interview - (13.03 SQM)	● Office (3)	
B00D - R0009 - Interview - (13.04 SQM)	● Office (3)	
B00D - R0010 - Movement - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Staff Room - (93.42 SQM)	● Office (23)	
B00D - R0015 - Clerical Office/Workroom - (36.67 SQM)	● Office (9)	
B00D - R0016 - Sick Bay - (20.06 SQM)	● Student Space (9)	
B00D - R0019 - Movement - (139.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (86.02 SQM)	● Student Space (39)	
B00E - R0004 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Practical Activities - 1hb - (21.46 SQM)	● Student Space (9)	
B00F - R0001 - Practical Activities - 1hb - (48.28 SQM)	● Student Space (22)	
B00F - R0002 - Withdrawal Space - 1hb - (9.91 SQM)	● Student Space (4)	
B00F - R0004 - Movement - (26.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (75.84 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0010 - Home Base - (75.92 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0012 - Home Base - (75.91 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0014 - Withdrawal Space - 1hb - (13.04 SQM)	● Student Space (6)	
B00F - R0015 - Movement - (46.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (10.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (15.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (58.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0011 - Movement - (9.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (32.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Home Base - (57.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0014 - Practical Activities - 1hb - (58.54 SQM)	● Student Space (27)	
B00G - R0015 - Home Base - (57.94 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0001 - Home Base - (58.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Movement - (20.07 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (58.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0007 - Home Base - (58.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0010 - Movement - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Home Base - (57.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0012 - Practical Activities - 1hb - (58.91 SQM)	● Student Space (27)	
B00K - R0003 - Movement - (70.26 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (38.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Communal Space - (234.32 SQM)	● Student Space (108)	
B00K - R0007 - Raised Platform - (53.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Canteen - (43.29 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Withdrawal Space - 1hb - (11.59 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0003 - Home Base - (60.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00L - R0004 - Home Base - (60.49 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0005 - Practical Activities - 1hb - (118.98 SQM)	 Student Space (55)	
B00L - R0007 - Home Base - (60.55 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0009 - Home Base - (60.54 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0010 - Home Base - (60.63 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0011 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Staff Room Annexe - (17.34 SQM)	 Office (4)	
B00L - R0014 - Movement - (73.29 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Home Base - (61.07 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0003 - Practical Activities - 1hb - (19.28 SQM)	 Student Space (8)	
B00N - R0004 - Withdrawal Space - 2hb - (11.74 SQM)	 Student Space (5)	
B00N - R0005 - Home Base - (61.06 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0007 - Practical Activities - 1hb - (19.19 SQM)	 Student Space (8)	
B00N - R0008 - Home Base - (59.62 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0010 - Withdrawal Space - 1hb - (8.7 SQM)	 Student Space (4)	
B00N - R0011 - Practical Activities - 1hb - (19.2 SQM)	 Student Space (8)	
B00P - R0001 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Special Programs Room - (32.52 SQM)	 Student Space (15)	