

VENTILATION AUDIT REPORT

SCHOOL:	Bellbird Public School (1177)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Cessnock



1177 - Bellbird Public School
Site Plan (12323)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (27.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room - (47.63 SQM)	Office (11)	
B00A - R0007 - Principal - (24.11 SQM)	Office (6)	
B00A - R0009 - Staff Room Annexe - (12.94 SQM)	Office (3)	
B00A - R0010 - Entry Vestibule - (21.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (29.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Interview - (13.27 SQM)	Office (3)	
B00A - R0014 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Sick Bay - (9.36 SQM)	Student Space (4)	
B00A - R0020 - Duplicating Workroom - (25.52 SQM)	Office (6)	
B00A - R0021 - Clerical Office - (13.77 SQM)	Office (3)	
B00A - R0022 - Entry Vestibule - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (28.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (19.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Withdrawal Space - 1hb - (27.24 SQM)	Student Space (12)	
B00A - R0026 - Practical Activities - 1hb - (5.71 SQM)	Student Space (2)	
B00A - R0028 - Practical Activities - 1hb - (65.88 SQM)	Student Space (30)	
B00A - R0029 - Home Base - (44.34 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0031 - Withdrawal Space - 2hb - (42.78 SQM)	Student Space (19)	
B00A - R0032 - Home Base - (43.67 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0034 - Home Base - (47.47 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0036 - Practical Activities - 1hb - (13.22 SQM)	Student Space (6)	
B00A - R0037 - Home Base - (47.09 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0001 - Movement - (89.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Reading Area - (89.74 SQM)	Student Space (41)	
B00C - R0002 - Movement - (26.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (17.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (33.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Communal Space - (94.84 SQM)	Student Space (44)	
B00C - R0011 - Canteen - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (19.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (35.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (17.92 SQM)	Student Space (8)	
B00D - R0003 - Home Base - (59.54 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Withdrawal Space - 1hb - (12.02 SQM)	Student Space (5)	
B00D - R0007 - Home Base - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0008 - Practical Activities - 1hb - (17.88 SQM)	Student Space (8)	
B00D - R0009 - Movement - (14.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Communal Space - (143.8 SQM)	Student Space (66)	
B00F - R0003 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Raised Platform - (62.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - (19.41 SQM)	Student Space (9)	
B00H - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	Student Space (5)	
B00H - R0006 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 12652 - OS 601 12652 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15426 - OS 601 15426 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	