


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bellevue Hill Public School (1179)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Vaucluse</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Woollahra</b>

1179 - Bellevue Hill Public School  
Site Plan (11260)





































1:693

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0008 - Home Base - (47.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - Home Base - (47.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0010 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0021 - Clerical Office - (13.47 SQM)	● Office (3)	
B00A - R0022 - Clerical Office - (12.66 SQM)	● Office (3)	
B00A - R0027 - Sick Bay - (9.88 SQM)	● Student Space (4)	
B00A - R0028 - Principal - (22.37 SQM)	● Office (5)	
B00A - R0029 - Clerical Office - (37.42 SQM)	● Office (9)	
B00A - R0031 - Deputy Principal - Type 1 - (13.26 SQM)	● Office (3)	
B00A - R0033 - Clerical/Printing - (18.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Home Base - (47.99 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0037 - Home Base - (48.26 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0039 - Sick Bay - (7.05 SQM)	● Student Space (3)	
B00A - R0040 - Movement - (155.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Deputy Principal - Type 1 - (20.39 SQM)	● Office (5)	
B00A - R0042 - Principal - (11.62 SQM)	● Office (2)	
B00A - R0043 - Clerical Office/Workroom - (46.93 SQM)	● Office (11)	
B00A - R0044 - Entry Vestibule - (24.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1002 - Home Base - (49.47 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1003 - Staff Room Annexe - (18.15 SQM)	● Office (4)	
B00A - R1004 - Home Base - (49.77 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1005 - Home Base - (49.75 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1006 - Home Base - (49.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1007 - Home Base - (49.12 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1008 - Home Base - (65.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1009 - Staff Room Annexe - (8.04 SQM)	● Office (2)	
B00A - R1012 - Movement - (113.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Duplicating Workroom - (13.67 SQM)	● Office (3)	
B00A - R1020 - Movement - (14.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Staff Room - (54.83 SQM)	● Office (13)	
B00A - R1022 - Staff Room Annexe - (27.13 SQM)	● Office (6)	
B00A - R1023 - Special Programs Room - (19.49 SQM)	● Student Space (9)	
B00A - R1024 - Special Programs Room - (21.27 SQM)	● Student Space (9)	
B00H - R0001 - Communal Space - (146.86 SQM)	● Student Space (68)	
B00H - R0002 - Raised Platform - (60.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Canteen - (40.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Withdrawal Space - 1hb - (13.26 SQM)	● Student Space (6)	
B00J - R0006 - Withdrawal Space - 1hb - (13.7 SQM)	● Student Space (6)	
B00J - R0007 - Reading Area - (241.13 SQM)	● Student Space (111)	
B00J - R0008 - Special Programs Room - (25.28 SQM)	● Student Space (11)	
B00J - R0014 - Withdrawal Space - 1hb - (14.03 SQM)	● Student Space (6)	
B00J - R0015 - Home Base X4 - (165.05 SQM) - Teaching Space: 4	● Student Space (76)	
B00J - R0016 - Withdrawal Space - 2hb - (10.74 SQM)	● Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0017 - Withdrawal Space - 2hb - (10.42 SQM)	 Student Space (4)	
B00J - R0018 - Presentation Area - (59.13 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Withdrawal Space - 1hb - (5.46 SQM)	 Student Space (2)	
B00J - R0020 - Practical Activities - 4hb - (39.75 SQM)	 Student Space (18)	
B00J - R0025 - Movement - (186.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0029 - Movement - (8.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Presentation Area - (92.7 SQM)	Not Applicable	Circulation or storage space.
B00J - R1003 - Withdrawal Space - 2hb - (9.57 SQM)	 Student Space (4)	
B00J - R1004 - Withdrawal Space - 2hb - (11.13 SQM)	 Student Space (5)	
B00J - R1005 - Home Base X4 - (167.42 SQM) - Teaching Space: 4	 Student Space (77)	
B00J - R1006 - Withdrawal Space - 1hb - (13.16 SQM)	 Student Space (6)	
B00J - R1013 - Withdrawal Space - 2hb - (14.1 SQM)	 Student Space (6)	
B00J - R1014 - Home Base X3 - (166.85 SQM) - Teaching Space: 3	 Student Space (77)	
B00J - R1015 - Withdrawal Space - 1hb - (10.4 SQM)	 Student Space (4)	
B00J - R1016 - Withdrawal Space - 1hb - (9.96 SQM)	 Student Space (4)	
B00J - R1017 - Presentation Area - (68.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R1018 - Withdrawal Space - 1hb - (5.41 SQM)	 Student Space (2)	
B00J - R1019 - Practical Activities - 4hb - (40.2 SQM)	 Student Space (18)	
B00J - R1020 - Practical Activities - 3hb - (39.59 SQM)	 Student Space (18)	
B00J - R2002 - Presentation Area - (92.73 SQM)	Not Applicable	Circulation or storage space.
B00J - R2003 - Withdrawal Space - 1hb - (9.63 SQM)	 Student Space (4)	
B00J - R2004 - Withdrawal Space - 1hb - (11.16 SQM)	 Student Space (5)	
B00J - R2005 - Home Base X4 - (166.84 SQM) - Teaching Space: 4	 Student Space (77)	
B00J - R2006 - Withdrawal Space - 1hb - (13.16 SQM)	 Student Space (6)	
B00J - R2013 - Withdrawal Space - 1hb - (13.99 SQM)	 Student Space (6)	
B00J - R2014 - Home Base X3 - (166.6 SQM) - Teaching Space: 3	 Student Space (77)	
B00J - R2015 - Withdrawal Space - 1hb - (10.42 SQM)	 Student Space (4)	
B00J - R2016 - Withdrawal Space - 1hb - (9.88 SQM)	 Student Space (4)	
B00J - R2017 - Presentation Area - (68.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R2018 - Outdoor Learning Area - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R2019 - Practical Activities - 4hb - (40.77 SQM)	 Student Space (18)	
B00J - R2020 - Practical Activities - 4hb - (39.65 SQM)	 Student Space (18)	
B00J - R3002 - Presentation Area - (92.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R3003 - Withdrawal Space - 1hb - (11.16 SQM)	 Student Space (5)	
B00J - R3004 - Withdrawal Space - 1hb - (9.65 SQM)	 Student Space (4)	
B00J - R3005 - Home Base X4 - (166.71 SQM) - Teaching Space: 4	 Student Space (77)	
B00J - R3006 - Withdrawal Space - 1hb - (13.23 SQM)	 Student Space (6)	
B00J - R3013 - Withdrawal Space - 1hb - (13.99 SQM)	 Student Space (6)	
B00J - R3014 - Home Base X3 - (167.99 SQM) - Teaching Space: 3	 Student Space (77)	
B00J - R3015 - Withdrawal Space - 1hb - (9.74 SQM)	 Student Space (4)	
B00J - R3016 - Withdrawal Space - 1hb - (10.46 SQM)	 Student Space (4)	
B00J - R3017 - Presentation Area - (68.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R3018 - Outdoor Learning Area - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R3019 - Practical Activities - 4hb - (40.37 SQM)	 Student Space (18)	
B00J - R3020 - Practical Activities - 4hb - (39.75 SQM)	 Student Space (18)	
B00J - R9001 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.