


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bellingen Public School (1181)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Oxley</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bellingen</b>

1181 - Bellingen Public School  
Site Plan (10208)













1:1,214

Printed: 25-Aug-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Home Base - (56.74 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0004 - Home Base - (56.34 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0012 - Home Base - (85.71 SQM) - Teaching Space: 1	Student Space (39)	
B001 - R0013 - Practical Activities - 1hb - (14.92 SQM)	Student Space (6)	
B001 - R0014 - Movement - (121.56 SQM)	Not Applicable	Circulation or storage space.
B002 - R0003 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0004 - Home Base - (56.2 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0012 - Home Base - (85.7 SQM) - Teaching Space: 1	Student Space (39)	
B002 - R0013 - Practical Activities - 1hb - (14.92 SQM)	Student Space (6)	
B002 - R0014 - Movement - (121.57 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Interview - (15.87 SQM)	Office (3)	
B003 - R0003 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B003 - R0004 - Staff Kitchen - (5.92 SQM)	Office (1)	
B003 - R0005 - Staff Room - (97.19 SQM)	Office (24)	
B003 - R0006 - Staff Room Annexe - (9.52 SQM)	Office (2)	
B003 - R0009 - Movement - (11.11 SQM)	Not Applicable	Circulation or storage space.
B003 - R0012 - Withdrawal Space - 1hb - (14.58 SQM)	Student Space (6)	
B003 - R0020 - Canteen - (27.45 SQM)	Not Applicable	Circulation or storage space.
B003 - R0023 - Movement - (23.84 SQM)	Not Applicable	Circulation or storage space.
B003 - R0025 - Movement - (41.1 SQM)	Not Applicable	Circulation or storage space.
B003 - R0026 - Movement - (71.04 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Seminar/Study - (53.81 SQM)	Office (13)	
B004 - R0003 - Reading Area - (92.67 SQM)	Student Space (42)	
B004 - R0004 - Duplicating Workroom - (12.77 SQM)	Office (3)	
B004 - R0006 - Sick Bay - (9.38 SQM)	Student Space (4)	
B004 - R0007 - Clerical Office - (22.21 SQM)	Office (5)	
B004 - R0008 - Entry Vestibule - (12.66 SQM)	Not Applicable	Circulation or storage space.
B004 - R0009 - Interview - (10.18 SQM)	Office (2)	
B004 - R0010 - Principal - (15.6 SQM)	Office (3)	
B004 - R0013 - Deputy Principal - (16.28 SQM)	Office (4)	
B004 - R0014 - Movement - (68.63 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Home Base - (63.57 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0003 - Special Programs Room - (78.47 SQM)	Student Space (36)	
B005 - R0005 - Home Base - (63.57 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0006 - Home Base - (63.56 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0010 - Home Base - (63.55 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0013 - Movement - (142.92 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - Withdrawal Space - 1hb - (10.9 SQM)	Student Space (5)	
B006 - R0003 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B006 - R0005 - Practical Activities - 1hb - (12.89 SQM)	Student Space (5)	
B006 - R0006 - Movement - (33.09 SQM)	Not Applicable	Circulation or storage space.
B006 - R0010 - Practical Activities - 1hb - (12.89 SQM)	Student Space (5)	
B006 - R0011 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B007 - R0001 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B007 - R0002 - Withdrawal Space - 1hb - (10.9 SQM)	Student Space (5)	
B007 - R0003 - Movement - (14 SQM)	Not Applicable	Circulation or storage space.
B007 - R0004 - Home Base - (60.41 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0005 - Practical Activities - 1hb - (12.89 SQM)	 Student Space (5)	
B007 - R0006 - Movement - (33.09 SQM)	Not Applicable	Circulation or storage space.
B007 - R0010 - Practical Activities - 1hb - (12.89 SQM)	 Student Space (5)	
B007 - R0011 - Home Base - (60.41 SQM) - Teaching Space: 1	 Student Space (28)	
B008 - R0002 - Movement - (79.1 SQM)	Not Applicable	Circulation or storage space.
B012 - R0001 - Communal Space - (146.58 SQM)	 Student Space (68)	
B012 - R0002 - Raised Platform - (61.79 SQM)	Not Applicable	Circulation or storage space.
B012 - R0016 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B012 - R0017 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B012 - R0018 - Movement - (11.63 SQM)	Not Applicable	Circulation or storage space.
B013 - R0002 - Special Programs Room - (10.55 SQM)	 Student Space (4)	
B013 - R0003 - Special Programs Room - (12.62 SQM)	 Student Space (5)	
B013 - R0005 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B013 - R0008 - Special Programs Room - Type 2 - (20.97 SQM)	 Student Space (9)	
B013 - R0009 - Special Programs Room - Type 2 - (18.36 SQM)	 Student Space (8)	
OS 602 14182 - OS 602 14182 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19511 - OS 602 19511 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	