


VENTILATION AUDIT REPORT

SCHOOL:	Belmore South Public School (1186)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Canterbury
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

1186 - Belmore South Public School
Site Plan (12326)



1:1,384

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (63.56 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0003 - Special Programs Room - (23.12 SQM)	● Student Space (10)	
B00A - R0004 - Special Programs Room - (23.22 SQM)	● Student Space (10)	
B00A - R0008 - Movement - (34.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (67.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Home Base - (48.85 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0014 - Home Base - (50.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0015 - Home Base - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0016 - Home Base - (40.19 SQM) - Teaching Space: 1	● Student Space (18)	
B00A - R0017 - Practical Activities - 1hb - (8.3 SQM)	● Student Space (3)	
B00A - R0021 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (55.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Home Base - (48.67 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0026 - Home Base - (48.47 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0027 - Staff Room Annexe - (6.55 SQM)	● Office (1)	
B00A - R1001 - Home Base - (50.51 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1003 - Home Base - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1004 - Movement - (72.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Withdrawal Space - 1hb - (13.22 SQM)	● Student Space (6)	
B00A - R1008 - Home Base - (49.17 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1010 - Reading Area - (154.43 SQM)	● Student Space (71)	
B00A - R1012 - Seminar/Study - (12.76 SQM)	● Office (3)	
B00A - R1013 - Movement - (52.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Home Base - (48.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1015 - Home Base - (50.36 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0001 - Movement - (120.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0006 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0007 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0008 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0009 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0011 - Movement - (18.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Canteen - (15.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Raised Platform - (21.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Communal Space - (118.47 SQM)	● Student Space (54)	
B00B - R1001 - Special Programs Room - (15.4 SQM)	● Student Space (7)	
B00B - R1002 - Movement - (79.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Home Base - (48.41 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1006 - Home Base - (48.83 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1007 - Home Base - (48.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1008 - Home Base - (48.55 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1009 - Home Base - (48.61 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1013 - Special Programs Room - (15 SQM)	● Student Space (6)	
B00C - R0001 - Movement - (167.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Entry Vestibule - (21.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Clerical Office - (17.36 SQM)	● Office (4)	
B00C - R0004 - Sick Bay - (8.65 SQM)	● Student Space (4)	
B00C - R0006 - Interview - (13.09 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0007 - Deputy Principal - (13.16 SQM)	Office (3)	
B00C - R0008 - Interview - (13.16 SQM)	Office (3)	
B00C - R0009 - Staff Room Annexe - (19.53 SQM)	Office (4)	
B00C - R0010 - Staff Room - (45.24 SQM)	Office (11)	
B00C - R0017 - Principal - (16.78 SQM)	Office (4)	
B00C - R0018 - Duplicating Workroom - (20.33 SQM)	Office (5)	
B00C - R0019 - Movement - (35.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (39.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (146.67 SQM)	Student Space (68)	
B00F - R0002 - Raised Platform - (62.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Canteen - (26.37 SQM)	Not Applicable	Circulation or storage space.