

VENTILATION AUDIT REPORT

SCHOOL:	Ben Venue Public School (1198)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

1198 - Ben Venue Public School
Site Plan (13480)



1:930




Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (72.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Practical Activities - 1hb - (18.74 SQM)	● Student Space (8)	
B00G - R0026 - Withdrawal Space - 1hb - (5.74 SQM)	● Student Space (2)	
B00G - R0027 - Practical Activities - 1hb - (16.25 SQM)	● Student Space (7)	
B00G - R0028 - Home Base - (53.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0029 - Withdrawal Space - 1hb - (11.41 SQM)	● Student Space (5)	
B00G - R0030 - Home Base - (56.46 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0031 - Practical Activities - 1hb - (15.7 SQM)	● Student Space (7)	
B00G - R0032 - Practical Activities - 1hb - (18.08 SQM)	● Student Space (8)	
B00G - R0033 - Home Base - (43.92 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0035 - Withdrawal Space - 1hb - (9.82 SQM)	● Student Space (4)	
B00G - R0037 - Withdrawal Space - 1hb - (11.39 SQM)	● Student Space (5)	
B00G - R0040 - Home Base - (49.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0041 - Practical Activities - 1hb - (16.73 SQM)	● Student Space (7)	
B00G - R0043 - Withdrawal Space - 1hb - (8.01 SQM)	● Student Space (3)	
B00G - R0045 - Withdrawal Space - 1hb - (5.65 SQM)	● Student Space (2)	
B00G - R0046 - Home Base - (60.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0047 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B00G - R0048 - Movement - (24.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0049 - Movement - (43.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0050 - Home Base - (59.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Withdrawal Space - 1hb - (13.39 SQM)	● Student Space (6)	
B00H - R0017 - Home Base - (70.8 SQM) - Teaching Space: 1	● Student Space (32)	
B00H - R0019 - Withdrawal Space - 1hb - (6.91 SQM)	● Student Space (3)	
B00H - R0021 - Withdrawal Space - 1hb - (6.95 SQM)	● Student Space (3)	
B00H - R0022 - Home Base - (65.27 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0023 - Practical Activities - 1hb - (19.54 SQM)	● Student Space (9)	
B00H - R0024 - Practical Activities - 1hb - (21.81 SQM)	● Student Space (10)	
B00H - R0025 - Home Base - (61.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0027 - Withdrawal Space - 1hb - (7.99 SQM)	● Student Space (3)	
B00H - R0028 - Movement - (57.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Practical Activities - 1hb - (23.21 SQM)	● Student Space (10)	
B00J - R0002 - Home Base - (53.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0004 - Withdrawal Space - 1hb - (11.87 SQM)	● Student Space (5)	
B00J - R0005 - Practical Activities - 1hb - (24.57 SQM)	● Student Space (11)	
B00J - R0006 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0008 - Practical Activities - 1hb - (27.59 SQM)	● Student Space (12)	
B00J - R0009 - Home Base - (50.2 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0010 - Withdrawal Space - 1hb - (5.18 SQM)	● Student Space (2)	
B00J - R0015 - Movement - (87.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (64.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Practical Activities - 1hb - (22.92 SQM)	● Student Space (10)	
B00J - R1002 - Home Base - (54.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00J - R1004 - Withdrawal Space - 1hb - (11.03 SQM)	● Student Space (5)	
B00J - R1005 - Practical Activities - 1hb - (23.82 SQM)	● Student Space (11)	
B00J - R1006 - Home Base - (54.97 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1008 - Practical Activities - 1hb - (27.98 SQM)	Student Space (12)	
B00J - R1009 - Home Base - (49.92 SQM) - Teaching Space: 1	Student Space (23)	
B00J - R1010 - Withdrawal Space - 1hb - (5.29 SQM)	Student Space (2)	
B00J - R1013 - Movement - (86.93 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - Movement - (64.23 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - 1hb - (27.13 SQM)	Student Space (12)	
B00K - R0002 - Home Base - (50.34 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R0004 - Withdrawal Space - 1hb - (5.29 SQM)	Student Space (2)	
B00K - R0005 - Practical Activities - 1hb - (24.38 SQM)	Student Space (11)	
B00K - R0006 - Home Base - (54.48 SQM) - Teaching Space: 1	Student Space (25)	
B00K - R0008 - Withdrawal Space - 1hb - (11.9 SQM)	Student Space (5)	
B00K - R0009 - Practical Activities - 1hb - (23.35 SQM)	Student Space (10)	
B00K - R0010 - Home Base - (53.34 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0014 - Movement - (86.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Practical Activities - 1hb - (27.69 SQM)	Student Space (12)	
B00K - R1002 - Home Base - (49.98 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R1004 - Withdrawal Space - 1hb - (5.37 SQM)	Student Space (2)	
B00K - R1005 - Practical Activities - 1hb - (23.73 SQM)	Student Space (11)	
B00K - R1006 - Home Base - (55.16 SQM) - Teaching Space: 1	Student Space (25)	
B00K - R1008 - Withdrawal Space - 1hb - (11.03 SQM)	Student Space (5)	
B00K - R1009 - Practical Activities - 1hb - (22.83 SQM)	Student Space (10)	
B00K - R1010 - Home Base - (54.86 SQM) - Teaching Space: 1	Student Space (25)	
B00K - R1013 - Movement - (86.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Staff Room - (58.74 SQM)	Office (14)	
B00M - R0002 - Staff Room Annexe - (25.27 SQM)	Office (6)	
B00M - R0006 - Movement - (36.86 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Principal - (16.81 SQM)	Office (4)	
B00M - R0009 - Clerical Office - (32.63 SQM)	Office (8)	
B00M - R0010 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.
B00M - R0011 - Entry Vestibule - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Duplicating Workroom - (17.52 SQM)	Office (4)	
B00M - R0013 - Sick Bay - (8.66 SQM)	Student Space (4)	
B00M - R0015 - Interview - (13.13 SQM)	Office (3)	
B00M - R0016 - Deputy Principal - (13.16 SQM)	Office (3)	
B00M - R0017 - Deputy Principal - (13.16 SQM)	Office (3)	
B00N - R0005 - Reading Area - (232.51 SQM)	Student Space (107)	
B00N - R0010 - Special Programs Room - (42.46 SQM)	Student Space (19)	
B00P - R0001 - Movement - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Canteen - (43.55 SQM)	Not Applicable	Circulation or storage space.
B00P - R0009 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Raised Platform - (49.95 SQM)	Not Applicable	Circulation or storage space.
B00P - R0011 - Movement - (10.75 SQM)	Not Applicable	Circulation or storage space.
B00P - R0018 - Communal Space - (298.79 SQM)	Student Space (138)	
B00P - R0021 - Movement - (198.05 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Special Programs Room - Type 1 - (32.43 SQM)	Student Space (15)	
B00S - R0002 - Practical Activities - 1hb - (19.93 SQM)	Student Space (9)	
B00S - R0004 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
B00S - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R0006 - Home Base - (59.15 SQM) - Teaching Space: 1	 Student Space (27)	
B00S - R0008 - Practical Activities - 1hb - (19.86 SQM)	 Student Space (9)	
B00U - R0001 - Special Programs Room - (81.25 SQM)	 Student Space (37)	