

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Berala Public School (1199)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Auburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cumberland</b>

1199 - Berala Public School  
Site Plan (11915)



1:932



















Printed: 04-Jun-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Withdrawal Space - 2hb - (38.6 SQM)	Student Space (17)	
B00A - R0004 - Home Base - (47.65 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - Practical Activities - 1hb - (47.33 SQM)	Student Space (21)	
B00A - R0006 - Home Base - (47.33 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0007 - Staff Room Annexe - (11.82 SQM)	Office (2)	
B00A - R0010 - Staff Room Annexe - (18.46 SQM)	Office (4)	
B00A - R0012 - Home Base - (47.7 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0014 - Movement - (27.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Home Base - (62.43 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0022 - Movement - (55.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (55.88 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0032 - Movement - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Movement - (18.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (11.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (48.81 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1002 - Home Base - (48.88 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - Home Base - (49.35 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1004 - Home Base - (49.01 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - Home Base - (48.88 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Home Base - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - Movement - (104.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Withdrawal Space - 1hb - (8.74 SQM)	Student Space (4)	
B00A - R1012 - Withdrawal Space - 2hb - (41.74 SQM)	Student Space (19)	
B00A - R1013 - Special Programs Room - (60.92 SQM)	Student Space (28)	
B00F - R0001 - Home Base - (79.31 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0002 - Practical Activities - 1hb - (31.96 SQM)	Student Space (14)	
B00F - R0007 - Home Base - (87.54 SQM) - Teaching Space: 1	Student Space (40)	
B00F - R0009 - Practical Activities - 1hb - (16.86 SQM)	Student Space (7)	
B00F - R0012 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Staff Kitchen - (8.65 SQM)	Office (2)	
B00F - R0014 - Staff Room - (49.96 SQM)	Office (12)	
B00F - R0016 - Movement - (200.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Home Base - (66.62 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1005 - Movement - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - Home Base - (66.77 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1008 - Withdrawal Space - 2hb - (27.74 SQM)	Student Space (12)	
B00F - R1009 - Home Base - (67.08 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R1011 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R1013 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R1015 - Home Base - (67.07 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R1016 - Practical Activities - 1hb - (7.49 SQM)	Student Space (3)	
B00F - R1017 - Practical Activities - 1hb - (7.54 SQM)	Student Space (3)	
B00F - R1018 - Practical Activities - 1hb - (7.53 SQM)	Student Space (3)	
B00F - R1019 - Practical Activities - 1hb - (7.49 SQM)	Student Space (3)	
B00G - R0001 - Home Base - (47.2 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Home Base - (47.27 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0003 - Home Base - (47.49 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0004 - Home Base - (47.35 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0005 - Home Base - (47.49 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0006 - Movement - (86.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Home Base - (66.8 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0014 - Duplicating Workroom - (6.51 SQM)	Office (1)	
B00G - R0017 - Staff Room Annexe - (15.36 SQM)	Office (3)	
B00G - R0018 - Interview - (12.28 SQM)	Office (3)	
B00J - R0008 - Movement - (36.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Raised Platform - (49.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Communal Space - (215.28 SQM)	Student Space (99)	
B00J - R0017 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B00J - R0020 - Canteen - (44.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (130.3 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Reading Area - (285.84 SQM)	Student Space (132)	
B00K - R0009 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0012 - Withdrawal Space - 1hb - (8.96 SQM)	Student Space (4)	
B00K - R0013 - Practical Activities - 2hb - (20.75 SQM)	Student Space (9)	
B00K - R1001 - Practical Activities - 1hb - (19.16 SQM)	Student Space (8)	
B00K - R1003 - Home Base - (60.09 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1004 - Withdrawal Space - 2hb - (11.76 SQM)	Student Space (5)	
B00K - R1005 - Home Base - (59.85 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1007 - Practical Activities - 1hb - (18.86 SQM)	Student Space (8)	
B00K - R1009 - Practical Activities - 1hb - (18.29 SQM)	Student Space (8)	
B00K - R1011 - Home Base - (59.98 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1012 - Withdrawal Space - 2hb - (11.72 SQM)	Student Space (5)	
B00K - R1013 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1015 - Practical Activities - 1hb - (18.82 SQM)	Student Space (8)	
B00K - R1016 - Withdrawal Space - 1hb - (8.87 SQM)	Student Space (4)	
B00K - R1018 - Home Base - (57.51 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R1019 - Practical Activities - 1hb - (19.53 SQM)	Student Space (9)	
B00K - R1022 - Movement - (112.78 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Entry Vestibule - (23.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Clerical Office/Workroom - (58.3 SQM)	Office (14)	
B00M - R0003 - Sick Bay - (9.1 SQM)	Student Space (4)	
B00M - R0008 - Movement - (28.04 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Deputy Principal - (12.87 SQM)	Office (3)	
B00M - R0010 - Deputy Principal - (12.92 SQM)	Office (3)	
B00M - R0011 - Principal - (17.13 SQM)	Office (4)	
B00M - R0012 - Interview - (12.63 SQM)	Office (3)	
B00M - R0015 - Movement - (140.46 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Staff Room - (79.57 SQM)	Office (19)	
B00M - R1002 - Staff Room Annexe - (26.18 SQM)	Office (6)	
B00M - R1007 - Interview - (12.72 SQM)	Office (3)	
B00M - R1008 - Clerical Office - (18.92 SQM)	Office (4)	
B00M - R1009 - Movement - (15.11 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R1011 - Movement - (43.72 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Practical Activities - 1hb - (18.87 SQM)	 Student Space (8)	
B00N - R0002 - Home Base - (59.48 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0004 - Withdrawal Space - 1hb - (7.62 SQM)	 Student Space (3)	
B00N - R0005 - Practical Activities - 2hb - (18.61 SQM)	 Student Space (8)	
B00N - R0006 - Home Base - (60.47 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0008 - Withdrawal Space - 2hb - (11.71 SQM)	 Student Space (5)	
B00N - R0009 - Practical Activities/Movement - 1hb - (19.11 SQM)	 Student Space (8)	
B00N - R0010 - Home Base - (60.91 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R1001 - Home Base - (59.35 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R1003 - Withdrawal Space - 2hb - (7.72 SQM)	 Student Space (3)	
B00N - R1004 - Practical Activities - 4hb - (19.31 SQM)	 Student Space (8)	
B00N - R1005 - Home Base - (60.47 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R1007 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00N - R1008 - Practical Activities - 4hb - (19.28 SQM)	 Student Space (8)	
B00N - R1009 - Home Base - (60.75 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R1012 - Practical Activities - 3hb - (19.14 SQM)	 Student Space (8)	
OS 601 11430 - OS 601 11430 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12260 - OS 601 12260 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 12010 - OS 602 12010 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14989 - OS 602 14989 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 18244 - OS 606 18244 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 751 12128 - OS 751 12128 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	