

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Berkeley Vale Public School (1203)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>The Entrance</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

1203 - Berkeley Vale Public School  
Site Plan (11888)



1:1,167

Printed: 01-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Interview - (15.09 SQM)	Office (3)	
B00A - R0001 - Staff Room - (75.34 SQM)	Office (18)	
B00A - R0003 - Interview - (22 SQM)	Office (5)	
B00A - R0007 - Interview - (12.15 SQM)	Office (3)	
B00A - R0008 - Deputy Principal - (14.08 SQM)	Office (3)	
B00A - R0009 - Principal - (21.28 SQM)	Office (5)	
B00A - R0010 - Sick Bay - (10.86 SQM)	Student Space (5)	
B00A - R0012 - Interview - (13.8 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (13.91 SQM)	Office (3)	
B00A - R0014 - Entry Vestibule - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Duplicating Workroom - (35.4 SQM)	Office (8)	
B00A - R0016 - Movement - (21.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (31.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (123.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (32.04 SQM)	Not Applicable	Circulation or storage space.
B00B - M0003 - Reading Area - (12.58 SQM)	Student Space (5)	
B00B - M0005 - Special Programs Room - (9.36 SQM)	Student Space (4)	
B00B - R0003 - Movement - (87.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Seminar/Study - (16.91 SQM)	Office (4)	
B00B - R0006 - Reading Area - (244.24 SQM)	Student Space (113)	
B00B - R0012 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Communal Space - (227.21 SQM)	Student Space (105)	
B00C - R0009 - Raised Platform - (52.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Canteen - (42.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (62.51 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0004 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00D - R0006 - Practical Activities - 1hb - (31.02 SQM)	Student Space (14)	
B00D - R0007 - Home Base - (61.44 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - (61.53 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0010 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00D - R0013 - Practical Activities - 1hb - (31.02 SQM)	Student Space (14)	
B00D - R0015 - Staff Room Annexe - (11.7 SQM)	Office (2)	
B00D - R0020 - Home Base - (63.3 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0001 - Home Base - (62.41 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0003 - Practical Activities - 1hb - (31.01 SQM)	Student Space (14)	
B00E - R0004 - Home Base - (61.53 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00E - R0007 - Movement - (10.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Practical Activities - 1hb - (31.01 SQM)	Student Space (14)	
B00E - R0014 - Home Base - (61.53 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0018 - Home Base - (61.62 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0001 - Movement - (12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (62.43 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0004 - Withdrawal Space - 1hb - (12.02 SQM)	Student Space (5)	
B00F - R0007 - Home Base - (62.43 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Practical Activities - 1hb - (30.73 SQM)	Student Space (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1001 - Movement - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Home Base - (62.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R1006 - Withdrawal Space - 1hb - (12.02 SQM)	● Student Space (5)	
B00F - R1007 - Home Base - (62.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R1008 - Practical Activities - 1hb - (30.73 SQM)	● Student Space (14)	
B00G - R0003 - Practical Activities - 1hb - (8.22 SQM)	● Student Space (3)	
B00G - R0006 - Practical Activities - 1hb - (8.22 SQM)	● Student Space (3)	
B00G - R0008 - Home Base - (91.81 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0009 - Home Base - (92.33 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0005 - Staff Room Annexe - (13.11 SQM)	● Office (3)	
B00H - R0006 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0009 - Practical Activities - 1hb - (13.99 SQM)	● Student Space (6)	
B00H - R0011 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00I - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00M - R0003 - Communal Space - (103.79 SQM)	● Student Space (48)	
B00N - R0002 - Practical Activities - 1hb - (19.1 SQM)	● Student Space (8)	
B00N - R0006 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0007 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00N - R0008 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0010 - Practical Activities - 1hb - (18.22 SQM)	● Student Space (8)	
B00O - R0002 - Practical Activities - 1hb - (19.64 SQM)	● Student Space (9)	
B00O - R0004 - Home Base - (58.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0005 - Withdrawal Space - 2hb - (10.94 SQM)	● Student Space (5)	
B00O - R0006 - Home Base - (58.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0008 - Practical Activities - 1hb - (19.64 SQM)	● Student Space (9)	
B00P - R0002 - Practical Activities - 1hb - (19.64 SQM)	● Student Space (9)	
B00P - R0004 - Home Base - (58.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0005 - Withdrawal Space - 2hb - (10.94 SQM)	● Student Space (5)	
B00P - R0006 - Home Base - (58.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0008 - Practical Activities - 1hb - (19.64 SQM)	● Student Space (9)	
B00Q - R0001 - Canteen - (16.39 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Home Base - (98.79 SQM) - Teaching Space: 1	● Student Space (45)	
NS 020 13148 - NS 020 13148 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 602 10514 - OS 602 10514 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11860 - OS 602 11860 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	