

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Berry Public School (1211)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Kiama</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shoalhaven</b>

1211 - Berry Public School  
Site Plan (12333)







1:1,258

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0015 - Movement - (51.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Duplicating Workroom - (17.86 SQM)	Office (4)	
B00A - R0017 - Clerical Office/Workroom - (15.55 SQM)	Office (3)	
B00A - R0018 - Sick Bay - (7.15 SQM)	Student Space (3)	
B00A - R0021 - Principal - (20.56 SQM)	Office (5)	
B00A - R0022 - Entry Vestibule - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Deputy Principal - (13.17 SQM)	Office (3)	
B00A - R0025 - Staff Kitchen - (10.4 SQM)	Office (2)	
B00A - R0026 - Staff Room - (36.92 SQM)	Office (9)	
B00A - R0027 - Staff Room Annexe - (19.72 SQM)	Office (4)	
B00A - R0029 - Interview - (13.13 SQM)	Office (3)	
B00B - R0003 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Home Base - (86.19 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0002 - Home Base - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - Home Base - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0008 - Computer Room - (41.59 SQM)	Student Space (19)	
B00D - R0009 - Seminar/Study - (17.58 SQM)	Office (4)	
B00D - R0011 - Movement - (35.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Reading Area - (111.45 SQM)	Student Space (51)	
B00E - R0001 - Home Base - (59.28 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Practical Activities - 1hb - (38.05 SQM)	Student Space (17)	
B00E - R0007 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Staff Room Annexe - (6.77 SQM)	Office (1)	
B00E - R0009 - Movement - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (14.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (41.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Special Programs Room - (61.43 SQM)	Student Space (28)	
B00J - R0002 - Practical Activities - 1hb - (17.47 SQM)	Student Space (8)	
B00J - R0003 - Home Base - (74.61 SQM) - Teaching Space: 1	Student Space (34)	
B00J - R0005 - Withdrawal Space - 1hb - (12.67 SQM)	Student Space (5)	
B00J - R0006 - Home Base - (75.1 SQM) - Teaching Space: 1	Student Space (34)	
B00J - R0008 - Practical Activities - 1hb - (17.05 SQM)	Student Space (7)	
B00J - R0010 - Movement - (35.77 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (17.18 SQM)	Student Space (7)	
B00K - R0003 - Home Base - (75.14 SQM) - Teaching Space: 1	Student Space (34)	
B00K - R0005 - Withdrawal Space - 1hb - (12.91 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (75.22 SQM) - Teaching Space: 1	Student Space (34)	
B00K - R0008 - Practical Activities - 1hb - (17.18 SQM)	Student Space (7)	
B00K - R0010 - Movement - (35.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Special Programs Room - (69.39 SQM)	Student Space (32)	
B00L - R0002 - Special Programs Room - (93.93 SQM)	Student Space (43)	
B00L - R0003 - Movement - (55.71 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Communal Space - (158.61 SQM)	Student Space (73)	
B00M - R0002 - Raised Platform - (49.38 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Special Programs Room - (119.5 SQM)	Student Space (55)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 13495 - OS 601 13495 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10238 - OS 602 10238 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13737 - OS 602 13737 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14039 - OS 602 14039 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	