

VENTILATION AUDIT REPORT

SCHOOL:	Beverly Hills Girls High School (8255)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Lakemba
LOCAL GOVERNMENT AREA:	Georges River

8255 - Beverly Hills Girls High School
Site Plan (10878)



1:1,426

Printed: 19-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (54.18 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0002 - General Learning Space - (54.77 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0003 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - General Learning Space - (57.35 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0008 - Design L.S. - (68.57 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0010 - General Learning Space - (68.36 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0011 - Computer Learning Space - (60.97 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0012 - General Learning Space - (53.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0013 - Food Technology L.S. - (80.03 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0017 - General Learning Space - (47.55 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0018 - Performance Workspace - (54.62 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0019 - General Learning Space - (53.94 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0020 - General Learning Space - (60.87 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0029 - General Learning Space - (61.3 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0037 - Staff Study - (15.93 SQM)	Office (3)	
B00A - R0039 - Administration - Clerical - (15.84 SQM)	Office (3)	
B00A - R0048 - Interview/Meeting - (6.71 SQM)	Office (1)	
B00A - R0057 - General Assistants - (10.01 SQM)	Office (2)	
B00A - R0059 - Interview/Meeting - (32.07 SQM)	Office (8)	
B00A - R0062 - Stage - (57.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (45.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Computer Room - (17.58 SQM)	Student Space (8)	
B00A - R0078 - Staff Study - (54.14 SQM)	Office (13)	
B00A - R0079 - Staff Study - (24.74 SQM)	Office (6)	
B00A - R0087 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0088 - Kitchen - Type 1 - (89.16 SQM)	Student Space (41)	
B00A - R0089 - Preparation - Materials - (19.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0090 - Hospitality Space - (58.33 SQM)	Student Space (27)	
B00A - R0091 - Movement - (258.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0092 - Student Reception - (30.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0093 - Movement - (328.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0094 - Administration - Clerical - (71.4 SQM)	Office (17)	
B00A - R0095 - Principal Office - (21.44 SQM)	Office (5)	
B00A - R0096 - Deputy Principal Office - (21.5 SQM)	Office (5)	
B00A - R0097 - Staff Study - (31.75 SQM)	Office (7)	
B00A - R0098 - Interview/Office - Type 2 - (16.47 SQM)	Office (4)	
B00A - R0099 - Interview/Meeting - (27.69 SQM)	Office (6)	
B00A - R0100 - Commonroom - (19.24 SQM)	Office (4)	
B00A - R0101 - Interview/Office - Type 2 - (11.96 SQM)	Office (2)	
B00A - R0102 - Deputy Principal Office - (20.56 SQM)	Office (5)	
B00A - R0103 - Multi-Purpose Space - (574.59 SQM)	Student Space (266)	
B00A - R1001 - Staff Study - (26.31 SQM)	Office (6)	
B00A - R1002 - General Learning Space - (54.52 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1003 - General Learning Space - (47.61 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1004 - Art Learning Space - (67.91 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1007 - Performance Workspace - (79.25 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1008 - General Learning Space - (46.87 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1009 - Darkroom Space - (21.58 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1011 - Darkroom Space - (10.16 SQM)	Office (2)	
B00A - R1012 - Laboratory L.S. - (100.18 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R1013 - Laboratory L.S. - (108.79 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1017 - General Learning Space - (46.91 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1018 - Staff Study - (22.88 SQM)	Office (5)	
B00A - R1019 - General Learning Space - (62.83 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1020 - General Learning Space - (61.96 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1022 - Staff Study - (26.72 SQM)	Office (6)	
B00A - R1023 - General Learning Space - (54.46 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1024 - Staff Study - (20.21 SQM)	Office (5)	
B00A - R1025 - General Learning Space - (67.62 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1028 - General Learning Space - (61.59 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1029 - General Learning Space - (54.46 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1030 - General Learning Space - (61.59 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1031 - General Learning Space - (47.76 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1032 - General Learning Space - (60.77 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1033 - General Learning Space - (61.52 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1044 - Design L.S. - (54.67 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1047 - General Learning Space - (67.78 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1051 - Movement - (497.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R1060 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1063 - Art Learning Space - (77.35 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R9002 - Movement - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Student Canteen - (36.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R9014 - Movement - (11.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R9020 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00B - M1003 - Seminar - (32.66 SQM)	Office (8)	
B00B - M1004 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00B - M1005 - Main Area - (67.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0002 - Preparation - (44.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Laboratory L.S. - (90.93 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0007 - Laboratory L.S. - (90.93 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0008 - Staff Study - (44.41 SQM)	Office (11)	
B00B - R0010 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0011 - Movement - (40.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (12.38 SQM)	Office (3)	
B00B - R1002 - Workroom - (27.48 SQM)	Office (6)	
B00B - R1004 - Audio Visual Workroom - (17.61 SQM)	Student Space (8)	
B00B - R1007 - Main Area - (70.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Main Area - (322.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Seminar - (24.55 SQM)	Office (6)	
B00B - R1022 - Darkroom Space - (11.8 SQM)	Office (2)	
B00B - R1023 - Darkroom Space - (12.55 SQM)	Office (3)	
B00C - R0005 - Staff Study - (26.3 SQM)	Office (6)	
B00C - R0007 - Gymnasium - (277.04 SQM)	Student Space (128)	
B00C - R0010 - Movement - (43.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Performance Workspace - (83.62 SQM) - Teaching Space: 1	Student Space (38)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Performance Workspace - (249.33 SQM) - Teaching Space: 1	● Student Space (115)	
B00D - R0004 - Study Space - (32.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Staff Study - (17.62 SQM)	● Office (4)	
B00D - R0014 - Movement - (22.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (64.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Study Space - (35.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Study Space - (36.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Main Area - (91.98 SQM)	Not Applicable	Circulation or storage space.
NS 110 12181 - NS 110 12181 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 110 12182 - NS 110 12182 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 220 16331 - NS 220 16331 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 502 12075 - OS 502 12075 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 510 16332 - OS 510 16332 - Staff Common Room - (114 SQM)	● Office (28)	
OS 520 16831 - OS 520 16831 - Staff Study - (57 SQM)	● Office (14)	
OS 521 16333 - OS 521 16333 - Staff Study - (76 SQM)	● Office (19)	
OS 600 12089 - OS 600 12089 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 12090 - OS 600 12090 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 12091 - OS 600 12091 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 11059 - OS 601 11059 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11081 - OS 601 11081 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11290 - OS 601 11290 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11352 - OS 601 11352 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11887 - OS 601 11887 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12077 - OS 601 12077 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12078 - OS 601 12078 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12079 - OS 601 12079 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12080 - OS 601 12080 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12082 - OS 601 12082 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12083 - OS 601 12083 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12084 - OS 601 12084 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12085 - OS 601 12085 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12086 - OS 601 12086 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12087 - OS 601 12087 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 710 12097 - OS 710 12097 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	
OS 750 12304 - OS 750 12304 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 750 16335 - OS 750 16335 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 750 16336 - OS 750 16336 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 750 16337 - OS 750 16337 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 760 15388 - OS 760 15388 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.