

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Beverly Hills North Public School (3944)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Lakemba</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

3944 - Beverly Hills North Public School  
Site Plan (11905)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (70.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0002 - Practical Activities - 1hb - (8.79 SQM)	● Student Space (4)	
B00A - R0005 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Practical Activities - 1hb - (8.91 SQM)	● Student Space (4)	
B00A - R0009 - Home Base - (66.64 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0010 - Home Base - (66.99 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0012 - Practical Activities - 1hb - (7.38 SQM)	● Student Space (3)	
B00A - R0014 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Home Base - (66.75 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0018 - Practical Activities - 1hb - (9.33 SQM)	● Student Space (4)	
B00A - R0019 - Practical Activities - 1hb - (9.36 SQM)	● Student Space (4)	
B00A - R0020 - Home Base - (67.08 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0021 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Home Base - (67.43 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0023 - Practical Activities - 1hb - (8.05 SQM)	● Student Space (3)	
B00A - R0024 - Practical Activities - 1hb - (8.05 SQM)	● Student Space (3)	
B00A - R0025 - Home Base - (67.99 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0027 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (137.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Room - (25.3 SQM)	● Office (6)	
B00B - R0003 - Staff Room Annexe - (58.82 SQM)	● Office (14)	
B00B - R0010 - Principal - (16.85 SQM)	● Office (4)	
B00B - R0011 - Clerical Office - (32.59 SQM)	● Office (8)	
B00B - R0013 - Duplicating Workroom - (17.65 SQM)	● Office (4)	
B00B - R0014 - Sick Bay - (8.62 SQM)	● Student Space (3)	
B00B - R0016 - Interview - (13.16 SQM)	● Office (3)	
B00B - R0017 - Deputy Principal - (13.12 SQM)	● Office (3)	
B00B - R0018 - Staff Room Annexe - (13.16 SQM)	● Office (3)	
B00B - R0020 - Movement - (33.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (18.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (96.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Reading Area - (224.83 SQM)	● Student Space (104)	
B00E - R0006 - Withdrawal Space - 1hb - (13.31 SQM)	● Student Space (6)	
B00E - R0007 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0009 - Practical Activities - 1hb - (18.19 SQM)	● Student Space (8)	
B00E - R0010 - Home Base - (53.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0012 - Withdrawal Space - 1hb - (13.49 SQM)	● Student Space (6)	
B00E - R0013 - Practical Activities - 1hb - (18.24 SQM)	● Student Space (8)	
B00E - R0014 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0017 - Withdrawal Space - 1hb - (13.31 SQM)	● Student Space (6)	
B00E - R0018 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Home Base - (53.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0006 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - Home Base - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0011 - Movement - (63.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0013 - Special Programs Room - (35.96 SQM)	● Student Space (16)	
B00F - R0016 - Practical Activities - 1hb - (17.31 SQM)	● Student Space (8)	
B00F - R0017 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Withdrawal Space - 1hb - (12.83 SQM)	● Student Space (5)	
B00G - R0005 - Practical Activities - 1hb - (14.38 SQM)	● Student Space (6)	
B00G - R0006 - Home Base - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0007 - Home Base - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0008 - Practical Activities - 1hb - (16.65 SQM)	● Student Space (7)	
B00G - R0011 - Withdrawal Space - 1hb - (16.5 SQM)	● Student Space (7)	
B00G - R0013 - Outdoor Learning Area - (49.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Raised Platform - (57.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Staff Kitchen - (11.28 SQM)	● Office (2)	
B00H - R0005 - Movement - (26.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Communal Space - (223.15 SQM)	● Student Space (103)	
B00H - R0007 - Movement - (21.06 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Canteen - (44.73 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (29.8 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Staff Room Annexe - (7.85 SQM)	● Office (1)	
B00K - R0005 - Staff Kitchen - (9.55 SQM)	● Office (2)	
B00O - R0004 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00O - R0007 - Movement - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00O - R0009 - Home Base - (91.83 SQM) - Teaching Space: 1	● Student Space (42)	
B00O - R0010 - Practical Activities - 1hb - (23.4 SQM)	● Student Space (10)	
B00O - R0012 - Withdrawal Space - 1hb - (10.63 SQM)	● Student Space (4)	
B00O - R0013 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Special Programs Room - (42.64 SQM)	● Student Space (19)	
B00R - R0001 - Movement - (38.51 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00R - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00R - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B00S - R0001 - Practical Activities - 3hb - (18.62 SQM)	● Student Space (8)	
B00S - R0002 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0004 - Withdrawal Space - 1hb - (7.76 SQM)	● Student Space (3)	
B00S - R0005 - Practical Activities - 2hb - (18.55 SQM)	● Student Space (8)	
B00S - R0006 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0008 - Withdrawal Space - 1hb - (11.78 SQM)	● Student Space (5)	
B00S - R0009 - Practical Activities - 1hb - (19.26 SQM)	● Student Space (8)	
B00S - R0010 - Home Base - (60.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0001 - Practical Activities - 3hb - (18.59 SQM)	● Student Space (8)	
B00T - R0002 - Home Base - (59.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0004 - Withdrawal Space - 1hb - (7.76 SQM)	● Student Space (3)	
B00T - R0005 - Practical Activities - 2hb - (18.55 SQM)	● Student Space (8)	
B00T - R0006 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00T - R0008 - Withdrawal Space - 1hb - (11.78 SQM)	● Student Space (5)	
B00T - R0009 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
B00T - R0010 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 17697 - OS 602 17697 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	