

# VENTILATION AUDIT REPORT

SCHOOL:	Beverly Hills Public School (1215)
AMU REGION:	Sydney
STATE ELECTORATE:	Kogarah
LOCAL GOVERNMENT AREA:	Georges River

























1215 - Beverly Hills Public School  
Site Plan (12334)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0004 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0008 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0009 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0011 - Special Programs Room - (34.47 SQM)	● Student Space (15)	
B00A - R0014 - Special Programs Room - (32.75 SQM)	● Student Space (15)	
B00A - R0016 - Practical Activities - 1hb - (19.1 SQM)	● Student Space (8)	
B00A - R0017 - Withdrawal Space - 2hb - (11.93 SQM)	● Student Space (5)	
B00A - R0018 - Practical Activities - 1hb - (18.87 SQM)	● Student Space (8)	
B00A - R0019 - Practical Activities - 1hb - (19.05 SQM)	● Student Space (8)	
B00A - R0020 - Withdrawal Space - 2hb - (11.93 SQM)	● Student Space (5)	
B00A - R0021 - Practical Activities - 1hb - (19.19 SQM)	● Student Space (8)	
B00B - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00B - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00B - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00C - R0007 - Practical Activities - 1hb - (8.25 SQM)	● Student Space (3)	
B00C - R0035 - Movement - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0037 - Home Base - (56.54 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0038 - Practical Activities - 1hb - (18.29 SQM)	● Student Space (8)	
B00C - R0040 - Practical Activities - 1hb - (18.06 SQM)	● Student Space (8)	
B00C - R0041 - Home Base - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0044 - Withdrawal Space - 1hb - (7.32 SQM)	● Student Space (3)	
B00C - R0046 - Practical Activities - 1hb - (13.64 SQM)	● Student Space (6)	
B00C - R0047 - Home Base - (59.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0048 - Withdrawal Space - 2hb - (13.02 SQM)	● Student Space (6)	
B00C - R0049 - Home Base - (87.12 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0050 - Practical Activities - 1hb - (15.62 SQM)	● Student Space (7)	
B00C - R0057 - Withdrawal Space - 1hb - (7.58 SQM)	● Student Space (3)	
B00C - R0058 - Home Base - (62.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0059 - Practical Activities - 1hb - (23.01 SQM)	● Student Space (10)	
B00C - R0060 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0061 - Home Base - (57.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0062 - Practical Activities - 1hb - (20.14 SQM)	● Student Space (9)	
B00C - R0063 - Withdrawal Space - 1hb - (8.81 SQM)	● Student Space (4)	
B00D - R0001 - Reading Area - (162.53 SQM)	● Student Space (75)	
B00E - R0002 - Entry Vestibule - (18.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Clerical Office - (27.83 SQM)	● Office (6)	
B00E - R0004 - Sick Bay - (10.24 SQM)	● Student Space (4)	
B00E - R0006 - Duplicating Workroom - (19.68 SQM)	● Office (4)	
B00E - R0013 - Staff Room Annexe - (20.5 SQM)	● Office (5)	
B00E - R0014 - Staff Room - (45.77 SQM)	● Office (11)	
B00E - R0015 - Movement - (42.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Deputy Principal - (13.04 SQM)	● Office (3)	
B00E - R0017 - Deputy Principal - (13.12 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0018 - Principal - (17.34 SQM)	 Office (4)	
B00E - R0019 - Interview - (12.85 SQM)	 Office (3)	
B00F - R0015 - Communal Space - (180.56 SQM)	 Student Space (83)	
B00F - R0021 - Raised Platform - (48.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Movement - (20.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Canteen - (27.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0002 - Home Base - (60.23 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0003 - Home Base - (60.26 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0004 - Withdrawal Space - 1hb - (35.97 SQM)	 Student Space (16)	
B00G - R0005 - Practical Activities - (19.08 SQM)	 Student Space (8)	
B00G - R0006 - Practical Activities - (19.1 SQM)	 Student Space (8)	
B00G - R0007 - Practical Activities - (19.63 SQM)	 Student Space (9)	
B00G - R0008 - Withdrawal Space - 1hb - (9.01 SQM)	 Student Space (4)	
B00G - R0009 - Withdrawal Space - 2hb - (12.32 SQM)	 Student Space (5)	
B00G - R1001 - Home Base - (59.16 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1002 - Home Base - (60.25 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1003 - Home Base - (60.27 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1004 - Practical Activities - (19.77 SQM)	 Student Space (9)	
B00G - R1005 - Practical Activities - (19.29 SQM)	 Student Space (8)	
B00G - R1006 - Practical Activities - (19.63 SQM)	 Student Space (9)	
B00G - R1007 - Withdrawal Space - 1hb - (9.01 SQM)	 Student Space (4)	
B00G - R1008 - Withdrawal Space - 2hb - (12.21 SQM)	 Student Space (5)	
NS 100 10629 - NS 100 10629 - Learning Unit - Single Primary/PAA - (76 SQM)	 Student Space (35)	
OS 602 15434 - OS 602 15434 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15977 - OS 602 15977 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 750 11915 - OS 750 11915 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	