

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Biddabah Public School (4206)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>












4206 - Biddabah Public School  
Site Plan (11311)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (19.04 SQM)	Office (4)	
B00A - R0010 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Practical Activities - 1hb - (11.7 SQM)	Student Space (5)	
B00A - R0021 - Home Base - (71.22 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R0022 - Special Programs Room - (12.93 SQM)	Student Space (5)	
B00A - R0023 - Special Programs Room - (26.96 SQM)	Student Space (12)	
B00A - R0024 - Special Programs Room - (30.19 SQM)	Student Space (14)	
B00B - R0002 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (5.72 SQM)	Student Space (2)	
B00B - R0006 - Home Base - (68.07 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0007 - Home Base - (68.01 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0008 - Practical Activities - 1hb - (5.55 SQM)	Student Space (2)	
B00B - R0015 - Practical Activities - 1hb - (5.6 SQM)	Student Space (2)	
B00B - R0016 - Home Base - (94.11 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0017 - Home Base - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0018 - Practical Activities - 1hb - (10.48 SQM)	Student Space (4)	
B00B - R0020 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Home Base - (53.27 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0023 - Practical Activities - 1hb - (10.6 SQM)	Student Space (4)	
B00B - R0025 - Canteen - (23.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (10.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (33.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Home Base - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0007 - Movement - (7.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (23.57 SQM)	Student Space (10)	
B00E - R0004 - Home Base - (54.62 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0005 - Withdrawal Space - 1hb - (10.4 SQM)	Student Space (4)	
B00E - R0006 - Home Base - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0008 - Practical Activities - 1hb - (23.54 SQM)	Student Space (10)	
B00F - R0004 - Special Programs Room - (33.16 SQM)	Student Space (15)	
B00F - R0005 - Reading Area - (191.77 SQM)	Student Space (88)	
B00G - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00G - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00G - R0009 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00G - R0011 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0012 - Withdrawal Space - 2hb - (11.37 SQM)	Student Space (5)	
B00G - R0013 - Home Base - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0015 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00H - R0002 - Entry Vestibule - (23.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (56.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Interview - (13.13 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Principal - (17.17 SQM)	 Office (4)	
B00H - R0006 - Deputy Principal - (12.64 SQM)	 Office (3)	
B00H - R0009 - Staff Room - (48.56 SQM)	 Office (12)	
B00H - R0010 - Staff Room Annexe - (19.39 SQM)	 Office (4)	
B00H - R0012 - Interview/Office - Type 3 - (16.58 SQM)	 Office (4)	
B00H - R0016 - Sick Bay - (8.96 SQM)	 Student Space (4)	
B00H - R0017 - Duplicating Workroom - (23.97 SQM)	 Office (5)	
B00H - R0018 - Clerical Office - (27.21 SQM)	 Office (6)	
B00H - R0020 - Home Base/Practical Activities - (78.66 SQM) - Teaching Space: 1	 Student Space (36)	
B00H - R0021 - Withdrawal Space - 1hb - (8.58 SQM)	 Student Space (3)	
B00J - R0001 - Canteen - (41.47 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (196.27 SQM)	 Student Space (91)	
B00K - R0002 - Raised Platform - (65.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Movement - (15.95 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Outdoor Learning Area - (216.32 SQM)	Not Applicable	Circulation or storage space.