


VENTILATION AUDIT REPORT

SCHOOL:	Bilpin Public School (1228)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

1228 - Bilpin Public School
Site Plan (14587)















1:614

Printed: 23-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (10.57 SQM)	 Office (2)	
B00A - R0004 - Withdrawal Space - 1hb - (15.85 SQM)	 Student Space (7)	
B00A - R0005 - Home Base - (47.48 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0007 - Entry Vestibule - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Withdrawal Space - 1hb - (9.9 SQM)	 Student Space (4)	
B00A - R0009 - Home Base - (53 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0010 - Principal - (10.83 SQM)	 Office (2)	
B00A - R0011 - Clerical Office - (11.19 SQM)	 Office (2)	
B00A - R0012 - Staff Kitchen - (8.78 SQM)	 Office (2)	
B00B - R0001 - Home Base - (67.31 SQM) - Teaching Space: 1	 Student Space (31)	
B00B - R0003 - Withdrawal Space - 1hb - (7.72 SQM)	 Student Space (3)	
B00D - R0002 - Canteen - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (31.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Reading Area - (91.95 SQM)	 Student Space (42)	
OS 502 14464 - OS 502 14464 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	