


VENTILATION AUDIT REPORT

SCHOOL:	Binnaway Central School (1237)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warrumbungle

1237 - Binnaway Central School
Site Plan (12340)



1:903

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Seminar/Technology Space - (6.12 SQM)	Office (1)	
B00A - R0004 - Food Technology L.S. - (65.58 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0005 - Food/Research Space - (9.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Darkroom Space - (16.18 SQM)	Office (4)	
B00B - R0007 - Workshop Area - (119.91 SQM)	Student Space (55)	
B00C - R0002 - Movement - (47.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - General Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Laboratory L.S. - (69.54 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0006 - Preparation - (19.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Movement - (101.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Seminar - Type 1 - (15.51 SQM)	Office (3)	
B00E - R0004 - Home Base - (67.15 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0006 - Practical Activities - 1hb - (16 SQM)	Student Space (7)	
B00E - R0007 - Home Base - (43.56 SQM) - Teaching Space: 1	Student Space (20)	
B00E - R0008 - Home Base - (43.69 SQM) - Teaching Space: 1	Student Space (20)	
B00E - R0011 - General Learning Space - (47.43 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0012 - General Learning Space - (31.96 SQM) - Teaching Space: 1	Student Space (14)	
B00E - R0013 - Practical Activities - 1hb - (15.06 SQM)	Student Space (6)	
B00F - R0001 - Movement - (72.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (210.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Canteen - (32.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Raised Platform - (39.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Multi-Purpose Space - (152.06 SQM)	Student Space (70)	
B00K - R0002 - Public Entry - (17.06 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Clerical Office - (12.96 SQM)	Office (3)	
B00K - R0005 - Duplicating Workroom - (19.13 SQM)	Office (4)	
B00K - R0006 - Principal - (18.62 SQM)	Office (4)	
B00K - R0007 - Deputy Principal - (14.69 SQM)	Office (3)	
B00K - R0011 - Staff Room Annexe - (22.19 SQM)	Office (5)	
B00K - R0014 - Movement - (6.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Interview - (12 SQM)	Office (3)	
B00K - R0017 - Movement - (19.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Withdrawal Space - 1hb - (10.44 SQM)	Student Space (4)	
B00K - R0021 - Computer Learning Space - (70.8 SQM) - Teaching Space: 1	Student Space (32)	
B00K - R0022 - Practical Activities - 1hb - (12.45 SQM)	Student Space (5)	
B00K - R0025 - Commonroom - (53.56 SQM)	Office (13)	
B00K - R1001 - Seminar/Study - (9.66 SQM)	Office (2)	
B00K - R1002 - Seminar/Study - (9.66 SQM)	Office (2)	
B00K - R1003 - Reading Area - (176.08 SQM)	Student Space (81)	
B00K - R1008 - Movement - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R1012 - Practical Activities - 1hb - (12.45 SQM)	Student Space (5)	
B00K - R1013 - Home Base - (70.79 SQM) - Teaching Space: 1	Student Space (32)	
B00M - R0001 - General Assistants - (25.24 SQM)	Office (6)	