


VENTILATION AUDIT REPORT

SCHOOL:	Birrong Girls High School (8854)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

8854 - Birrong Girls High School
Site Plan (13022)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1001 - Multi-Purpose Space - (277.93 SQM)	● Student Space (128)	
B00A - R1002 - Stage - (66.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Movement - (17.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Staff Study - (27.02 SQM)	● Office (6)	
B00A - R1008 - Staff Kitchen - (7.29 SQM)	● Office (1)	
B00B - R0001 - Workshop - (52.66 SQM)	● Student Space (24)	
B00B - R0002 - Workshop - (27.76 SQM)	● Student Space (12)	
B00B - R0003 - Movement - (14.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Principal Office - (18.64 SQM)	● Office (4)	
B00B - R1006 - Leading Teacher - (11.32 SQM)	● Office (2)	
B00B - R1020 - Movement - (39.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Administration - Clerical - (49.33 SQM)	● Office (12)	
B00B - R1023 - General Learning Space - (49.06 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1024 - General Learning Space - (49.19 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1025 - General Learning Space - (49.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1026 - General Learning Space - (49.26 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1027 - General Learning Space - (49.39 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1031 - Staff Study - (28.48 SQM)	● Office (7)	
B00B - R1035 - Movement - (145.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Staff Study - (16.14 SQM)	● Office (4)	
B00B - R1043 - Staff Study - (33.15 SQM)	● Office (8)	
B00B - R1044 - Tea Room - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1047 - Deputy Principal Office - (20.64 SQM)	● Office (5)	
B00B - R1048 - Deputy Principal Office - (23.91 SQM)	● Office (5)	
B00B - R1049 - Public Reception - (95.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1050 - Administration - Clerical - (32.52 SQM)	● Office (8)	
B00B - R2001 - Commonroom - (150.15 SQM)	● Office (37)	
B00B - R2002 - Interview/Meeting - (19.13 SQM)	● Office (4)	
B00B - R2003 - Staff Kitchen - (19.13 SQM)	● Office (4)	
B00B - R2004 - Interview/Office - Type 1 - (14.62 SQM)	● Office (3)	
B00B - R2005 - Movement - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R2006 - Movement - (10.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R2009 - Computer Learning Space - (49.27 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2010 - General Learning Space - (49.19 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2011 - General Learning Space - (49.12 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2012 - General Learning Space - (49.33 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2013 - General Learning Space - (49.31 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2014 - General Learning Space - (49.34 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2017 - Staff Study - (28.64 SQM)	● Office (7)	
B00B - R2018 - Interview/Meeting - (18.34 SQM)	● Office (4)	
B00B - R2021 - Movement - (147.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R2023 - Staff Study - (33.58 SQM)	● Office (8)	
B00C - M1001 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00C - M1003 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Student Canteen - (30.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (40.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (9.06 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0014 - General Assistants - (36.42 SQM)	Office (9)	
B00C - R0021 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - General Learning Space - (49.84 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1006 - Computer Learning Space - (49.81 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1007 - General Learning Space - (100.64 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R1010 - General Learning Space - (49.71 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1011 - General Learning Space - (31.76 SQM) - Teaching Space: 1	Student Space (14)	
B00C - R1012 - Seminar - Type 1 - (20.48 SQM)	Office (5)	
B00C - R1017 - Movement - (135.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R2003 - Design/Technology L.S. - (49.54 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R2004 - General Learning Space - (49.34 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R2006 - Movement - (43.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Multi Media Workshop - (30.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Interview/Office - Type 1 - (23.07 SQM)	Office (5)	
B00D - R0006 - Computer Learning Space - (49.57 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0008 - Food Technology L.S. - (67.36 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0009 - Preparation - Materials - (19.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Food Technology L.S. - (67.02 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0014 - Food Technology L.S. - (70.02 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0016 - Staff Kitchen - (11.3 SQM)	Office (2)	
B00D - R0017 - Staff Study - (51.95 SQM)	Office (12)	
B00D - R0022 - Movement - (129.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (9.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Interview/Office - Type 1 - (16.5 SQM)	Office (4)	
B00D - R1002 - Staff Study - (17.9 SQM)	Office (4)	
B00D - R1004 - Seminar - Type 1 - (23.08 SQM)	Office (5)	
B00D - R1006 - Music Learning Space - (49.5 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1009 - Music Learning Space - (66.85 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R1010 - Practice/Seminar - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Practice/Seminar - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Workroom - (10.09 SQM)	Office (2)	
B00D - R1018 - Movement - (127.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R1022 - Design/Technology L.S. - (65.7 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1024 - Design/Technology L.S. - (70.16 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1026 - Staff Study - (25.1 SQM)	Office (6)	
B00E - M0001 - Movement - (9.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Computer Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0002 - Preparation - Science - (25.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (93.36 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0005 - Movement - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (43.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Laboratory L.S. - (93.67 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R1004 - Laboratory L.S. - (93.69 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R1006 - Movement - (48.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Preparation - Science - (45.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Performance Workshop - (46.95 SQM)	Student Space (21)	
B00G - R0002 - Performance Workshop - (47.09 SQM)	Student Space (21)	
B00H - R0001 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Workshop - (101.76 SQM)	Student Space (47)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0007 - Movement - (71.04 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Art Learning Space - (59.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0009 - Art Learning Space - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0011 - Staff Study - (33.74 SQM)	● Office (8)	
B00H - R0012 - Art Learning Space - (58.89 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0014 - Dark Room - (24.06 SQM)	● Office (6)	
B00H - R0015 - Staff Study - (27.23 SQM)	● Office (6)	
B00H - R0020 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Movement - (41.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Movement - (41.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Senior Study - (13.83 SQM)	● Office (3)	
B00H - R1007 - Senior Study - (13.79 SQM)	● Office (3)	
B00H - R1008 - Senior Study - (13.9 SQM)	● Office (3)	
B00H - R1014 - Main Area - (344.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R1019 - Interview/Office - Type 1 - (8.16 SQM)	● Office (2)	
B00H - R9005 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
NS 200 11563 - NS 200 11563 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 11556 - OS 600 11556 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 11047 - OS 601 11047 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11082 - OS 601 11082 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11557 - OS 601 11557 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11558 - OS 601 11558 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11646 - OS 601 11646 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11778 - OS 601 11778 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11780 - OS 601 11780 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 10513 - OS 720 10513 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 12355 - OS 720 12355 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.