

VENTILATION AUDIT REPORT

SCHOOL:	Blacktown Boys High School (8244)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

8244 - Blacktown Boys High School
Site Plan (10885)



1:2,222

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Laboratory L.S. - (100.5 SQM) - Teaching Space: 1	● Student Space (46)	
B00A - R0002 - Preparation - (23.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - General Learning Space - (42.67 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0007 - Movement - (79.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Tiered Learning Area - (42.83 SQM)	● Student Space (19)	
B00A - R0009 - Preparation - (23.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Study - (13.46 SQM)	○ Office (3)	
B00A - R0011 - Laboratory L.S. - (101.25 SQM) - Teaching Space: 1	● Student Space (46)	
B00A - R0012 - Commonroom - (93.13 SQM)	○ Office (23)	
B00A - R0013 - Administration - Clerical - (12.18 SQM)	○ Office (3)	
B00A - R0014 - Staff Kitchen - (5.85 SQM)	○ Office (1)	
B00A - R0017 - Duplicating Workroom - (25.5 SQM)	○ Office (6)	
B00A - R0019 - Administration - Clerical - (12.75 SQM)	○ Office (3)	
B00A - R0020 - Principal Office - (25.21 SQM)	○ Office (6)	
B00A - R0021 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (40.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Interview/Office - Type 1 - (12.36 SQM)	○ Office (3)	
B00A - R0026 - Ancillary Staff - (21.47 SQM)	○ Office (5)	
B00A - R0027 - Entry - (8.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Audio Visual Workroom - (41.2 SQM)	● Student Space (19)	
B00A - R0030 - Workroom - (42.71 SQM)	○ Office (10)	
B00A - R0031 - Main Area - (420.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Seminar - (11.49 SQM)	○ Office (2)	
B00A - R0034 - Seminar - (11.56 SQM)	○ Office (2)	
B00A - R0035 - Seminar - (11.76 SQM)	○ Office (2)	
B00A - R0036 - Movement - (69.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Administration - Clerical - (37.76 SQM)	○ Office (9)	
B00A - R0039 - Clinic - Boys - (15.13 SQM)	○ Office (3)	
B00A - R0040 - Deputy Principal Office - (18.61 SQM)	○ Office (4)	
B00A - R0041 - Administration - Clerical - (12.92 SQM)	○ Office (3)	
B00A - R0043 - Movement - (43.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - General Learning Space - (52.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0049 - Staff Study - (65.91 SQM)	○ Office (16)	
B00A - R0050 - General Learning Space - (65.91 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0051 - General Learning Space - (65.91 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0052 - Computer Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0057 - Computer Learning Space - (70.25 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0058 - Movement - (163.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1002 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1005 - Staff Study - (17.33 SQM)	○ Office (4)	
B00A - R1009 - General Learning Space - (51.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1010 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1011 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1012 - Movement - (114.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - General Learning Space - (69.65 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1014 - Interview/Office - Type 1 - (18.42 SQM)	○ Office (4)	
B00A - R1017 - Movement - (61.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1019 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1020 - Staff Study - (69.09 SQM)	● Office (17)	
B00A - R1021 - General Learning Space - (69.85 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1022 - Music Learning Space - (52.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1023 - Movement - (44.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Staff Study - (18.73 SQM)	● Office (4)	
B00A - R1027 - Music Learning Space - (70.25 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0004 - Student Canteen - (40.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (236.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (49.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Computer Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0005 - Design L.S. - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0007 - Materials Technology L.S. - (76 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0008 - Welding Area - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Materials Technology L.S. - (76.01 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0013 - Materials Technology L.S. - (84.77 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0014 - Materials Technology L.S. - (89.29 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0016 - Staff Study - (18.65 SQM)	● Office (4)	
B00C - R0019 - Staff Study - (25.69 SQM)	● Office (6)	
B00C - R0020 - Materials Technology L.S. - (72.14 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0022 - Movement - (113.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Preparation - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0040 - Food Technology L.S. - (111.45 SQM) - Teaching Space: 1	● Student Space (51)	
B00C - R0041 - General Learning Space - (41.33 SQM) - Teaching Space: 1	● Student Space (19)	
B00C - R0042 - Movement - (24.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0045 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Stage - (94.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (29.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Multi-Purpose Space - (392.39 SQM)	● Student Space (182)	
B00D - R0015 - Movement - (29.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Staff Kitchen - (8.8 SQM)	● Office (2)	
B00D - R0018 - Movement - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R9001 - General Assistants - (47.3 SQM)	● Office (11)	
B00K - R0002 - Darkroom Space - (10.47 SQM)	● Office (2)	
B00K - R0007 - Staff Study - (21.08 SQM)	● Office (5)	
B00K - R0011 - Art Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R0012 - Laboratory L.S. - (92.13 SQM) - Teaching Space: 1	● Student Space (42)	
B00K - R0013 - Commonroom - (28.53 SQM)	● Office (7)	
B00K - R0014 - Preparation - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Laboratory L.S. - (99.62 SQM) - Teaching Space: 1	● Student Space (46)	
B00K - R0018 - Staff Study - (25.5 SQM)	● Office (6)	
B00K - R0019 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Laboratory L.S. - (99.63 SQM) - Teaching Space: 1	● Student Space (46)	
B00K - R0027 - Preparation - (28.53 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Art Learning Space - (58.62 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0031 - Art Learning Space - (59 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0032 - Movement - (243.74 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R1001 - General Learning Space - (46.42 SQM) - Teaching Space: 1	● Student Space (21)	
B00K - R1004 - Interview/Office - Type 1 - (11.83 SQM)	● Office (2)	
B00K - R1005 - Staff Study - (19.84 SQM)	● Office (4)	
B00K - R1006 - Art Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1008 - General Learning Space - (59.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1011 - General Learning Space - (51.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1012 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1013 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1016 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1017 - Staff Study - (52.15 SQM)	● Office (13)	
B00K - R1020 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R1023 - Study Space - (16.77 SQM)	Not Applicable	Circulation or storage space.
B00K - R1024 - General Learning Space - (59.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1025 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1026 - General Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1028 - Study Space - (22.73 SQM)	Not Applicable	Circulation or storage space.
B00K - R1029 - Interview/Office - Type 1 - (12.36 SQM)	● Office (3)	
B00K - R1031 - General Learning Space - (38.08 SQM) - Teaching Space: 1	● Student Space (17)	
B00K - R1032 - Movement - (227.74 SQM)	Not Applicable	Circulation or storage space.