

VENTILATION AUDIT REPORT

SCHOOL:	Blacktown South Public School (4193)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

4193 - Blacktown South Public School
Site Plan (10160)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B001 - R0005 - Home Base - (89.98 SQM) - Teaching Space: 1	● Student Space (41)	
B001 - R0006 - Home Base - (64.66 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0009 - Deputy Principal - (17.33 SQM)	○ Office (4)	
B001 - R0012 - Movement - (17.89 SQM)	Not Applicable	Circulation or storage space.
B001 - R0016 - Home Base - (64.74 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0017 - Home Base - (65.27 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0020 - Withdrawal Space - 1hb - (26.25 SQM)	● Student Space (12)	
B001 - R0022 - Movement - (5.1 SQM)	Not Applicable	Circulation or storage space.
B002 - R0004 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Special Programs Room - (21.54 SQM)	● Student Space (9)	
B002 - R0007 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B002 - R0008 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B002 - R0010 - Movement - (15.87 SQM)	Not Applicable	Circulation or storage space.
B002 - R0015 - Home Base - (56.45 SQM) - Teaching Space: 1	● Student Space (26)	
B002 - R0016 - Home Base - (56.76 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0033 - Clerical Office - (12.97 SQM)	○ Office (3)	
B003 - R0034 - Entry Vestibule - (25.48 SQM)	Not Applicable	Circulation or storage space.
B003 - R0035 - Clerical Office - (30.54 SQM)	○ Office (7)	
B003 - R0036 - Duplicating Workroom - (15.04 SQM)	○ Office (3)	
B003 - R0037 - Sick Bay - (8.52 SQM)	● Student Space (3)	
B003 - R0041 - Principal - (20.34 SQM)	○ Office (5)	
B003 - R0042 - Clerical Office - (17.21 SQM)	○ Office (4)	
B003 - R0045 - Staff Kitchen - (14.24 SQM)	○ Office (3)	
B003 - R0046 - Deputy Principal - (15.14 SQM)	○ Office (3)	
B003 - R0047 - Deputy Principal - (15.25 SQM)	○ Office (3)	
B003 - R0051 - Clerical Office/Workroom - (21.34 SQM)	○ Office (5)	
B003 - R0052 - Movement - (15.02 SQM)	Not Applicable	Circulation or storage space.
B003 - R0053 - Movement - (39.95 SQM)	Not Applicable	Circulation or storage space.
B003 - R0054 - Staff Room - (43.36 SQM)	○ Office (10)	
B004 - R0001 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B004 - R0004 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B004 - R0010 - Home Base - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B004 - R0011 - Home Base - (57.06 SQM) - Teaching Space: 1	● Student Space (26)	
B005 - R0001 - Interview - (18.1 SQM)	○ Office (4)	
B005 - R0002 - Staff Room Annexe - (7.59 SQM)	○ Office (1)	
B005 - R0005 - Movement - (40.87 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Home Base - (56.02 SQM) - Teaching Space: 1	● Student Space (25)	
B005 - R0008 - Home Base - (56.19 SQM) - Teaching Space: 1	● Student Space (26)	
B005 - R0010 - Movement - (16.98 SQM)	Not Applicable	Circulation or storage space.
B005 - R0011 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B005 - R0014 - Practical Activities - 1hb - (6.7 SQM)	● Student Space (3)	
B005 - R0017 - Deputy Principal - (15.81 SQM)	○ Office (3)	
B005 - R0018 - Special Programs Room - (15.85 SQM)	● Student Space (7)	
B005 - R0021 - Withdrawal Space - 1hb - (9.23 SQM)	● Student Space (4)	
B006 - R0001 - Home Base - (56.86 SQM) - Teaching Space: 1	● Student Space (26)	
B006 - R0005 - Movement - (5.61 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0009 - Home Base - (56.79 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0001 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B007 - R0005 - Movement - (7.69 SQM)	Not Applicable	Circulation or storage space.
B007 - R0007 - Home Base - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0001 - Home Base - (56.58 SQM) - Teaching Space: 1	Student Space (26)	
B008 - R0005 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B008 - R0007 - Home Base - (56.67 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0001 - Canteen - (41.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (194.11 SQM)	Student Space (90)	
B00H - R0010 - Raised Platform - (56.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (25.42 SQM)	Not Applicable	Circulation or storage space.
B010 - R0001 - E.S.L. - (46.66 SQM)	Student Space (21)	
B014 - R0001 - Home Base - (86.35 SQM) - Teaching Space: 1	Student Space (40)	
B014 - R0003 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B014 - R0004 - Special Programs Room - (69 SQM)	Student Space (32)	
B015 - R0004 - Canteen - (17.86 SQM)	Not Applicable	Circulation or storage space.
B015 - R0005 - Movement - (10.19 SQM)	Not Applicable	Circulation or storage space.
B018 - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B018 - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B018 - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B018 - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B018 - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B019 - R0002 - Practical Activities - 1hb - (19.37 SQM)	Student Space (8)	
B019 - R0004 - Home Base - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B019 - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	Student Space (4)	
B019 - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B019 - R0008 - Practical Activities - 1hb - (19.37 SQM)	Student Space (8)	
B020 - R0001 - Reading Area - (227.9 SQM)	Student Space (105)	
B021 - R0002 - Practical Activities - 1hb - (19.66 SQM)	Student Space (9)	
B021 - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B021 - R0005 - Withdrawal Space - 2hb - (10.84 SQM)	Student Space (5)	
B021 - R0006 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B021 - R0008 - Practical Activities - 1hb - (19.66 SQM)	Student Space (9)	
OS 601 10861 - OS 601 10861 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14595 - OS 601 14595 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 12537 - OS 602 12537 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13866 - OS 602 13866 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13965 - OS 602 13965 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14165 - OS 602 14165 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14468 - OS 602 14468 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14652 - OS 602 14652 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14934 - OS 602 14934 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 17821 - OS 602 17821 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19794 - OS 602 19794 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19821 - OS 602 19821 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 13149 - OS 606 13149 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19049 - OS 606 19049 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 19119 - OS 606 19119 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19233 - OS 606 19233 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 15857 - OS 750 15857 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	