

VENTILATION AUDIT REPORT

SCHOOL:	Blacktown West Public School (4116)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

4116 - Blacktown West Public School
Site Plan (10895)












1:939

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Kitchen - (6.14 SQM)	Office (1)	
B00A - R0004 - Reading Area - (57.71 SQM)	Student Space (26)	
B00A - R0005 - Reading Area - (57.23 SQM)	Student Space (26)	
B00A - R0009 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Reading Area - (57.31 SQM)	Student Space (26)	
B00A - R0011 - Movement - (54.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (57.19 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0009 - Staff Room Annexe - (17.01 SQM)	Office (4)	
B00B - R0010 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (56.64 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0016 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0022 - Special Programs Room - (72.89 SQM)	Student Space (33)	
B00C - R0001 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0010 - Home Base - (56.82 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0014 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Home Base - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Clerical Office/Workroom - (28.53 SQM)	Office (7)	
B00D - R0007 - Principal - (16.73 SQM)	Office (4)	
B00D - R0009 - Deputy Principal - (13.25 SQM)	Office (3)	
B00D - R0014 - Staff Room - (57.7 SQM)	Office (14)	
B00D - R0017 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Duplicating Workroom - (7.39 SQM)	Office (1)	
B00D - R0021 - Staff Room Annexe - (58.03 SQM)	Office (14)	
B00D - R0022 - Movement - (25.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (36.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Home Base - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0015 - Withdrawal Space - 2hb - (16.41 SQM)	Student Space (7)	
B00E - R0016 - Movement - (39.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Home Base - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0001 - Home Base - (66.73 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0004 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (8.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (66.91 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0002 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Communal Space - (86.41 SQM)	Student Space (40)	
B00I - R0005 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0006 - Home Base - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0009 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Home Base - (56.84 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0005 - Home Base - (57.06 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0006 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0007 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0002 - Home Base - (47.14 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0003 - Home Base - (47.01 SQM) - Teaching Space: 1	 Student Space (21)	
B00K - R0004 - Movement - (21.01 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (57.15 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0004 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Home Base - (57.16 SQM) - Teaching Space: 1	 Student Space (26)	
B00M - R0001 - Movement - (24.35 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Communal Space - (75.47 SQM)	 Student Space (35)	
B00M - R0003 - Raised Platform - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Staff Room Annexe - (28.24 SQM)	 Office (7)	
B00N - R0002 - Staff Room Annexe - (21.09 SQM)	 Office (5)	
B00N - R0006 - Movement - (18.95 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Home Base - (56.32 SQM) - Teaching Space: 1	 Student Space (26)	
B00N - R0010 - Home Base - (66.89 SQM) - Teaching Space: 1	 Student Space (31)	
B00N - R0013 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00N - R0016 - Movement - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Movement - (15.14 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Movement - (10.97 SQM)	Not Applicable	Circulation or storage space.
B00O - R0003 - Canteen - (19.17 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Communal Space - (204.74 SQM)	 Student Space (94)	
B00R - R0002 - Raised Platform - (61.36 SQM)	Not Applicable	Circulation or storage space.
B00R - R0003 - Movement - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00R - R0004 - Movement - (5.43 SQM)	Not Applicable	Circulation or storage space.
B00R - R0019 - Canteen - (41.41 SQM)	Not Applicable	Circulation or storage space.